

### 水質試験結果表(取水分)

2016年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	19.6	19.0	2.0	7.4	27.3	30.4	54.0	8.2	0.19	ND	79.4
2	日	26.6	19.5	2.7	7.4	29.1	32.4	54.8	8.7	0.25	ND	81.5
3	月	28.2	20.6	2.4	7.3	30.0	33.2	59.2	10.2	0.23	ND	84.6
4	火	25.0	19.8	2.4	7.2	31.7	31.2	52.0	7.9	0.23	ND	85.9
5	水	25.5	19.5	2.1	7.2	31.5	32.4	54.4	8.4	0.20	ND	86.7
6	木	25.3	19.9	2.7	7.3	31.4	36.6	53.2	6.7	0.25	0.01	89.2
7	金	24.1	19.8	1.7	7.3	34.4	37.4	55.6	5.7	0.22	ND	89.7
8	土	25.6	19.0	1.2	7.3	33.5	33.0	58.8	8.5	0.32	ND	93.4
9	日	19.3	19.7	4.9	7.3	35.0	31.8	51.2	8.4	0.22	ND	81.7
10	月	22.4	18.2	3.0	7.2	28.7	32.2	56.0	8.2	0.31	ND	83.3
11	火	16.6	17.2	3.6	7.1	32.0	32.8	62.8	8.9	0.15	ND	88.9
12	水	17.4	16.8	1.7	7.2	33.4	33.0	52.8	9.0	0.16	ND	89.1
13	木	17.5	16.3	1.4	7.2	33.2	34.0	54.4	8.8	0.14	ND	91.7
14	金	14.3	16.0	1.4	7.1	32.9	35.2	57.2	8.9	0.17	ND	91.6
15	土	18.0	15.9	1.1	7.3	35.0	36.2	61.2	9.4	0.12	ND	94.5
16	日	21.0	16.2	0.8	7.3	33.6	36.6	54.4	8.8	0.13	ND	95.9
17	月	21.4	17.2	1.3	7.2	33.9	35.6	58.4	8.3	0.16	ND	93.0
18	火	22.5	17.8	2.7	7.2	30.8	31.8	56.0	7.8	0.19	ND	85.6
19	水	23.9	18.2	1.7	7.1	32.2	34.0	53.6	8.8	0.16	ND	89.6
20	木	26.4	18.8	1.3	6.9	34.6	37.4	57.2	9.3	0.12	ND	94.7
21	金	18.7	17.8	1.2	7.3	34.6	35.6	64.4	10.4	0.34	ND	96.6
22	土	17.1	16.8	0.8	7.3	34.8	37.4	56.4	8.6	0.10	ND	97.2
23	日	21.7	16.5	0.7	7.4	36.0	37.8	52.0	9.4	0.11	ND	100.2
24	月	19.0	16.1	0.9	7.3	37.0	36.8	58.0	9.6	0.17	ND	101.4
25	火	17.3	15.3	0.9	7.3	37.0	38.6	59.2	11.2	0.12	ND	101.1
26	水	23.4	16.0	0.9	7.3	38.3	36.8	66.4	10.4	0.12	ND	102.0
27	木	21.5	17.0	1.3	7.3	35.8	37.8	59.2	8.4	0.15	ND	98.7
28	金	14.5	16.2	1.3	7.3	36.8	37.2	65.2	9.4	0.12	ND	100.0
29	土	16.0	15.8	10.0	7.3	27.4	31.2	62.4	9.6	0.37	0.04	81.3
30	日	14.3	15.0	1.7	7.3	28.9	31.6	49.6	8.8	0.15	0.01	83.5
31	月	12.1	14.0	1.1	7.3	32.2	34.4	62.8	10.4	0.14	0.01	89.9
最大値		28.2	20.6	10.0	7.4	38.3	38.6	66.4	11.2	0.37	0.04	102.0
最小値		12.1	14.0	0.7	6.9	27.3	30.4	49.6	5.7	0.10	ND	79.4
平均値		20.5	17.5	2.0	7.3	33.0	34.6	57.2	8.9	0.19	ND	91.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2016年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	19.6	18.6	1.1	7.3	28.1	32.0	49.6	10.0	0.05	ND	82.2
2	日	26.6	19.5	1.0	7.2	27.3	31.6	48.0	9.8	0.08	ND	82.7
3	月	28.2	20.5	0.7	7.2	28.7	32.4	60.4	10.9	0.05	ND	86.5
4	火	25.0	19.7	1.1	7.1	30.1	30.2	48.0	10.2	0.05	ND	88.3
5	水	25.5	19.6	1.3	7.1	31.0	31.4	56.0	9.2	0.06	ND	89.0
6	木	25.3	19.8	0.9	7.2	30.9	33.8	48.4	7.3	0.07	ND	90.3
7	金	24.1	20.5	1.4	7.2	32.4	39.6	50.0	6.7	0.12	ND	91.5
8	土	25.6	19.0	1.2	7.4	33.9	33.6	58.0	10.0	0.10	ND	94.1
9	日	19.3	19.5	1.1	7.3	35.9	34.2	57.6	10.6	0.07	ND	94.6
10	月	22.4	18.4	2.8	7.1	26.4	30.6	57.6	10.3	0.15	ND	84.6
11	火	16.6	17.3	2.3	7.2	30.7	32.2	58.0	9.6	0.16	ND	88.5
12	水	17.4	16.7	1.6	7.1	31.6	34.4	50.0	10.1	0.10	ND	90.3
13	木	17.5	16.3	1.5	7.2	31.9	35.0	59.6	10.7	0.11	ND	93.5
14	金	14.3	16.1	1.5	7.2	32.3	33.6	52.8	9.6	0.10	ND	91.9
15	土	18.0	15.8	1.3	7.3	34.8	35.0	60.0	10.2	0.11	ND	95.2
16	日	21.0	16.3	0.8	7.4	35.2	35.6	54.8	9.4	0.12	ND	96.4
17	月	21.4	17.1	1.7	7.3	34.2	34.8	62.8	8.5	0.15	ND	95.1
18	火	22.5	17.7	1.7	7.1	28.9	33.2	60.0	8.8	0.09	ND	87.2
19	水	23.9	18.3	1.2	7.1	32.4	32.8	52.0	11.1	0.09	ND	90.5
20	木	26.4	18.9	1.1	7.0	33.9	35.6	56.4	11.6	0.07	ND	95.8
21	金	18.7	18.0	1.1	7.3	34.3	35.4	52.8	11.4	0.11	ND	96.9
22	土	17.1	16.5	0.9	7.4	34.1	36.4	54.8	10.1	0.10	ND	98.8
23	日	21.7	16.7	0.8	7.4	36.3	36.4	48.0	11.1	0.10	ND	101.3
24	月	19.0	16.3	0.8	7.4	37.5	38.4	62.4	11.1	0.14	ND	101.8
25	火	17.3	15.3	1.0	7.3	36.7	38.6	55.6	12.0	0.09	ND	102.0
26	水	23.4	15.7	0.9	7.3	37.4	39.0	70.4	11.5	0.10	ND	105.1
27	木	21.5	17.0	0.9	7.3	36.0	38.0	54.4	9.9	0.09	ND	100.2
28	金	14.5	16.2	1.0	7.3	35.5	36.8	64.0	9.8	0.10	ND	100.9
29	土	16.0	15.4	1.0	7.2	31.5	36.4	58.0	10.9	0.04	ND	99.3
30	日	14.3	15.0	1.7	7.2	28.6	30.2	50.0	10.1	0.13	0.01	84.1
31	月	12.1	14.1	1.0	7.3	31.1	34.0	58.8	9.9	0.12	0.01	88.5
最大値		28.2	20.5	2.8	7.4	37.5	39.6	70.4	12.0	0.16	0.01	105.1
最小値		12.1	14.1	0.7	7.0	26.4	30.2	48.0	6.7	0.04	ND	82.2
平均値		20.5	17.5	1.2	7.2	32.6	34.6	55.8	10.1	0.10	ND	93.1

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 濁度およびpH以外の基準については参考値とする。  
 本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所