

## 水質試験結果表(取水分)

2017年2月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	水	2.9	6.1	6.7	7.2	21.9	31.8	67.6	18.0	0.32	0.02	102.8
2	木	2.9	6.8	5.1	7.3	25.5	30.8	70.8	23.0	0.28	0.01	117.6
3	金	10.4	7.0	4.3	7.3	26.6	31.4	63.2	20.9	0.25	0.01	127.8
4	土	7.0	7.0	3.3	7.3	27.8	33.2	81.2	19.4	0.23	0.01	125.5
5	日	6.3	7.1	2.7	7.5	27.8	35.2	70.8	18.5	0.21	0.01	122.1
6	月	6.3	7.0	3.6	7.4	27.7	31.0	68.0	15.5	0.19	0.01	105.0
7	火	3.2	6.2	22.9	7.2	17.5	29.3	70.0	14.5	0.83	0.09	89.7
8	水	2.7	6.0	8.3	7.2	21.7	28.7	65.2	18.1	0.41	0.03	107.0
9	木	2.7	6.3	3.9	7.1	24.7	31.0	63.6	18.8	0.27	0.01	113.2
10	金	2.3	6.0	14.9	7.2	23.8	30.2	82.0	19.5	0.52	0.04	116.9
11	土	1.3	4.1	6.7	7.2	26.0	32.8	80.0	20.1	0.42	0.02	116.3
12	日	1.6	4.0	3.0	7.4	29.7	36.2	71.2	16.7	0.22	0.01	122.2
13	月	4.7	4.2	2.8	7.3	28.1	36.0	69.2	19.3	0.20	0.01	121.0
14	火	1.5	5.0	3.3	7.2	27.2	37.8	78.4	17.4	0.22	0.01	123.4
15	水	4.4	5.0	3.7	7.2	29.7	36.6	80.8	20.0	0.23	0.01	127.0
16	木	7.5	5.8	4.4	7.2	28.4	35.8	75.2	21.0	0.30	0.01	135.1
17	金	10.2	6.9	5.0	7.1	27.8	34.0	76.0	19.8	0.30	0.02	129.6
18	土	6.0	6.0	13.4	7.1	19.8	25.7	76.8	15.7	0.59	0.06	91.8
19	日	4.5	6.8	5.3	7.2	19.9	32.2	57.2	15.6	0.34	0.03	96.4
20	月	11.9	6.9	3.5	7.2	23.0	30.4	64.0	16.4	0.24	0.02	101.5
21	火	2.7	6.2	36.7	7.1	17.5	23.9	80.0	14.7	1.19	0.12	82.3
22	水	4.3	5.8	9.2	7.1	20.1	29.1	62.8	18.6	0.39	0.04	99.4
23	木	12.0	7.4	6.6	7.1	22.5	29.3	64.0	17.8	0.30	0.02	108.6
24	金	6.1	7.0	25.1	7.1	16.9	27.5	69.2	15.0	1.04	0.18	84.9
25	土	7.5	6.8	8.1	7.2	21.2	27.5	58.4	16.5	0.36	0.02	96.7
26	日	5.9	7.1	3.6	7.2	24.2	26.1	48.0	15.9	0.25	0.01	101.3
27	月	9.1	7.0	4.4	7.2	24.4	30.6	49.2	16.5	0.29	0.01	101.9
28	火	6.3	7.0	4.3	7.2	25.2	33.0	43.6	16.1	0.27	0.01	106.2
最大値		12.0	7.4	36.7	7.5	29.7	37.8	82.0	23.0	1.19	0.18	135.1
最小値		1.3	4.0	2.7	7.1	16.9	23.9	43.6	14.5	0.19	0.01	82.3
平均値		5.5	6.2	8.0	7.2	24.2	31.3	68.1	17.8	0.38	0.03	109.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

