

## 水質試験結果表(取水分)

2017年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日											
1	月	18.0	13.4	7.5	7.3	22.2	29.1	49.6	9.3	0.31	0.02	66.0
2	火	20.3	11.6	9.4	7.2	24.5	28.3	46.4	9.8	0.41	0.06	65.4
3	水	19.4	13.2	3.5	7.5	23.7	28.3	41.2	11.3	0.24	0.01	70.8
4	木	21.9	13.9	4.4	7.3	23.4	25.3	41.6	10.0	0.22	ND	69.4
5	金	22.9	14.9	3.9	7.4	23.1	26.3	45.2	10.5	0.21	ND	69.1
6	土	18.4	15.2	4.1	7.3	23.3	26.1	40.4	9.9	0.23	0.01	69.9
7	日	20.8	13.8	13.6	7.3	20.6	27.5	68.8	11.4	0.53	0.06	63.8
8	月	23.0	14.2	7.9	7.3	23.3	26.7	42.8	11.3	0.38	0.01	66.5
9	火	17.5	14.2	7.2	7.3	23.8	25.3	44.0	9.6	0.30	0.02	68.7
10	水	19.2	13.9	7.4	7.3	23.1	25.9	44.0	10.2	0.30	0.02	69.1
11	木	19.4	13.8	11.5	7.3	22.5	26.3	48.4	10.1	0.47	0.02	68.4
12	金	21.6	13.8	8.6	7.3	21.2	26.3	45.2	8.3	0.40	0.05	63.6
13	土	17.3	14.5	4.1	7.4	22.2	23.9	40.4	9.7	0.22	0.02	68.2
14	日	17.9	13.8	8.2	7.4	21.4	23.9	42.0	7.8	0.37	0.02	61.5
15	月	22.2	15.2	9.1	7.3	23.1	28.3	52.8	8.7	0.23	0.03	68.0
16	火	24.6	14.5	5.4	7.3	23.9	25.1	40.4	9.8	0.26	0.01	71.2
17	水	22.4	14.7	4.5	7.4	24.9	27.1	44.0	9.4	0.24	0.01	71.9
18	木	24.0	14.8	8.4	7.4	25.2	26.5	44.8	8.5	0.31	0.01	74.8
19	金	22.7	15.9	4.4	7.3	25.5	26.5	42.0	9.5	0.27	0.02	75.2
20	土	24.7	16.0	3.1	7.4	25.7	27.9	42.0	9.0	0.17	0.01	76.2
21	日	27.2	17.0	3.4	7.4	27.1	29.7	40.0	9.5	0.24	0.01	77.7
22	月	29.0	17.9	3.3	7.3	27.4	28.9	40.8	10.1	0.20	0.01	76.4
23	火	26.1	18.3	3.1	7.3	27.0	29.3	47.6	10.5	0.25	ND	78.5
24	水	22.2	18.8	3.4	7.3	28.5	30.4	50.4	9.3	0.21	ND	82.6
25	木	20.0	17.4	4.7	7.3	27.4	29.7	49.6	10.7	0.22	0.01	81.1
26	金	25.8	17.4	4.2	7.3	28.0	28.9	51.6	9.4	0.22	0.01	78.2
27	土	18.7	16.8	1.9	7.4	28.6	31.0	53.2	10.0	0.16	ND	82.5
28	日	22.5	16.1	2.6	7.4	29.5	31.0	48.0	10.1	0.24	ND	82.7
29	月	23.3	17.2	2.3	7.3	31.1	33.6	52.0	10.3	0.23	ND	84.6
30	火	26.4	18.1	2.9	7.3	28.5	32.8	52.0	10.3	0.21	0.01	84.3
31	水	28.3	19.0	2.6	7.4	29.9	34.4	48.0	11.2	0.21	ND	84.1
最大値		29.0	19.0	13.6	7.5	31.1	34.4	68.8	11.4	0.53	0.06	84.6
最小値		17.3	11.6	1.9	7.2	20.6	23.9	40.0	7.8	0.16	ND	61.5
平均値		22.2	15.5	5.5	7.3	25.1	28.1	46.4	9.9	0.27	0.01	73.2

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2017年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	18.0	13.2	1.3	7.2	20.5	27.9	40.4	11.8	0.04	ND	69.2
2	火	20.3	12.0	2.2	7.3	23.3	28.5	43.2	12.7	0.08	ND	71.4
3	水	19.4	13.2	1.3	7.5	23.2	27.9	40.0	13.0	0.05	ND	75.4
4	木	21.9	14.0	1.7	7.5	24.0	26.7	40.8	12.0	0.05	ND	75.2
5	金	22.9	15.1	0.7	7.4	21.9	25.7	42.4	11.9	0.04	ND	72.8
6	土	18.4	15.2	1.0	7.3	21.9	25.5	40.0	12.6	0.03	ND	71.4
7	日	20.8	14.0	1.6	7.4	20.7	27.1	44.0	12.8	0.06	ND	72.2
8	月	23.0	14.5	1.1	7.4	22.6	24.9	40.8	13.4	0.04	ND	71.7
9	火	17.5	14.4	1.9	7.3	23.5	25.5	40.0	11.5	0.07	ND	72.3
10	水	19.2	13.8	2.0	7.2	21.3	25.5	40.8	11.3	0.06	ND	71.8
11	木	19.4	13.9	1.9	7.1	20.9	25.1	40.0	12.2	0.07	ND	70.4
12	金	21.6	14.0	2.2	7.3	21.0	24.9	40.4	12.6	0.07	0.01	68.5
13	土	17.3	14.7	1.5	7.3	21.4	25.1	38.0	10.7	0.06	0.01	68.7
14	日	17.9	14.0	2.1	7.4	21.5	23.5	40.0	10.3	0.07	0.01	68.5
15	月	22.2	15.2	1.4	7.2	21.3	26.3	38.8	11.5	0.06	ND	70.4
16	火	24.6	15.0	1.9	7.2	22.6	25.5	37.6	11.1	0.07	ND	70.2
17	水	22.4	15.0	1.7	7.2	24.0	28.7	40.0	13.2	0.07	ND	73.3
18	木	24.0	15.1	1.9	7.2	23.7	26.9	40.0	11.4	0.08	ND	75.7
19	金	22.7	15.6	1.7	7.2	24.5	26.5	40.0	12.7	0.07	ND	76.6
20	土	24.7	16.1	1.4	7.4	25.1	28.5	40.0	10.2	0.07	ND	76.2
21	日	27.2	17.2	1.2	7.4	26.8	28.3	40.8	10.5	0.08	ND	79.8
22	月	29.0	18.2	1.4	7.4	27.4	30.4	44.4	11.1	0.11	ND	78.6
23	火	26.1	18.5	1.6	7.3	27.5	29.3	50.4	11.1	0.11	ND	80.5
24	水	22.2	19.0	1.6	7.3	28.8	29.9	48.8	11.4	0.10	ND	83.4
25	木	20.0	17.5	2.5	7.3	27.4	29.7	46.4	11.1	0.11	ND	83.0
26	金	25.8	17.7	2.6	7.3	27.4	29.5	45.6	11.2	0.12	ND	78.1
27	土	18.7	16.8	1.7	7.4	30.3	31.4	51.2	10.0	0.12	ND	82.6
28	日	22.5	16.6	1.8	7.5	29.9	31.6	45.2	10.5	0.14	ND	83.7
29	月	23.3	18.0	1.4	7.4	31.2	32.4	49.2	11.8	0.14	ND	85.1
30	火	26.4	18.6	1.5	7.4	29.7	32.4	48.0	12.1	0.13	ND	85.2
31	水	28.3	19.2	1.2	7.3	30.3	32.8	40.0	11.3	0.10	ND	85.2
最大値		29.0	19.2	2.6	7.5	31.2	32.8	51.2	13.4	0.14	0.01	85.2
最小値		17.3	12.0	0.7	7.1	20.5	23.5	37.6	10.0	0.03	ND	68.5
平均値		22.2	15.7	1.6	7.3	24.7	27.9	42.5	11.6	0.08	ND	75.7

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所