

### 水質試験結果表(取水分)

2017年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
1	火	32.0	23.4	3.2	7.1	32.5	33.4	58.4	10.6	0.21	ND	88.3
2	水	32.8	23.0	2.2	7.0	30.9	33.6	59.6	8.9	0.20	ND	88.7
3	木	31.9	23.8	2.3	7.1	32.4	33.8	52.4	11.2	0.20	ND	92.0
4	金	33.8	24.3	1.5	7.1	33.0	34.8	59.2	10.7	0.20	ND	93.9
5	土	35.1	25.1	2.5	7.2	34.1	34.2	54.8	12.2	0.10	ND	97.6
6	日	34.8	26.0	3.0	7.2	33.9	35.0	54.4	11.7	0.13	0.01	95.9
7	月	32.0	26.0	2.8	7.1	33.7	34.2	56.0	11.9	0.19	ND	95.0
8	火	24.9	23.9	5.5	7.2	27.0	26.9	48.0	11.6	0.30	0.01	74.8
9	水	31.5	20.5	47.5	7.0	17.6	20.1	74.4	9.5	1.68	0.14	52.5
10	木	27.9	20.3	18.8	7.1	22.1	23.5	60.4	11.2	0.57	0.01	63.8
11	金	31.5	20.3	3.9	7.4	21.8	26.1	49.6	15.2	0.31	0.01	74.4
12	土	31.5	21.8	4.0	7.3	26.0	27.7	42.0	12.1	0.24	0.02	77.9
13	日	27.0	21.2	4.8	7.3	26.2	28.5	53.6	11.6	0.26	0.07	77.7
14	月	28.8	21.3	4.8	7.2	27.1	29.5	48.0	8.5	0.27	0.01	80.0
15	火	24.8	21.4	3.7	7.1	28.6	29.9	50.8	6.8	0.25	ND	81.5
16	水	26.0	20.8	3.8	7.1	28.0	30.2	49.2	7.7	0.20	ND	81.4
17	木	29.7	21.1	2.9	7.2	28.5	30.2	52.4	7.2	0.22	ND	83.3
18	金	26.5	21.7	3.0	7.2	26.0	26.9	48.0	7.7	0.19	ND	76.4
19	土	29.8	21.8	4.8	7.3	25.8	28.9	47.2	7.0	0.20	0.01	77.9
20	日	27.6	22.2	1.6	7.3	27.8	28.3	42.4	7.1	0.12	0.01	81.0
21	月	31.4	22.3	3.1	7.2	28.7	29.1	50.8	6.3	0.24	ND	81.0
22	火	30.6	22.8	2.5	7.2	26.2	29.1	41.2	7.1	0.18	ND	75.7
23	水	29.0	22.5	1.9	7.2	26.8	28.1	41.6	5.7	0.16	ND	74.5
24	木	30.6	22.6	13.5	7.2	20.8	23.3	51.2	5.4	0.54	0.04	64.4
25	金	27.0	22.0	4.1	7.2	25.1	25.1	42.4	5.9	0.22	ND	70.4
26	土	26.5	19.0	15.9	7.4	33.0	31.8	84.0	5.9	0.71	0.06	91.2
27	日	27.5	19.5	4.8	7.4	23.9	24.3	48.8	5.5	0.26	0.01	69.9
28	月	29.5	21.1	6.7	7.2	27.0	29.7	52.0	5.9	0.30	ND	75.4
29	火	31.9	21.0	3.7	7.3	26.8	25.7	57.2	6.0	0.21	0.01	75.9
30	水	27.4	21.6	5.1	7.3	25.1	30.6	58.4	7.4	0.31	0.01	76.8
31	木	26.8	21.0	3.0	7.3	26.4	27.1	50.8	6.1	0.17	0.01	74.8
最大値		35.1	26.0	47.5	7.4	34.1	35.0	84.0	15.2	1.68	0.14	97.6
最小値		24.8	19.0	1.5	7.0	17.6	20.1	41.2	5.4	0.10	ND	52.5
平均値		29.6	22.1	6.2	7.2	27.5	29.0	52.9	8.6	0.30	0.01	79.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2017年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	火	32.0	23.4	1.6	7.2	31.5	33.4	52.0	11.9	0.11	ND	90.4
2	水	32.8	23.1	1.7	7.0	31.4	33.0	44.8	9.8	0.14	ND	90.1
3	木	31.9	24.0	1.4	7.2	31.2	34.4	55.6	12.3	0.13	ND	92.5
4	金	33.8	24.5	1.3	7.2	32.5	36.2	56.0	13.0	0.13	ND	96.8
5	土	35.1	25.5	1.2	7.3	33.6	34.2	57.2	11.8	0.06	ND	96.8
6	日	34.8	26.1	1.0	7.4	34.1	34.2	60.4	11.9	0.11	ND	97.1
7	月	32.0	26.8	1.1	7.3	33.2	34.6	62.4	12.3	0.13	ND	94.1
8	火	24.9	24.0	2.4	7.2	28.3	30.2	40.0	12.1	0.12	ND	83.5
9	水	31.5	20.7	2.8	6.6	12.2	18.7	40.4	10.7	0.08	ND	58.7
10	木	27.9	20.6	2.3	6.8	18.0	21.7	54.0	13.3	0.07	0.01	65.0
11	金	31.5	20.5	1.3	7.3	21.8	26.9	46.0	14.8	0.04	0.01	75.4
12	土	31.5	22.0	0.8	7.2	24.5	28.1	43.2	14.2	0.02	ND	78.8
13	日	27.0	21.8	0.7	7.2	23.8	27.7	55.2	14.9	0.03	0.01	78.9
14	月	28.8	21.3	1.1	7.2	25.8	28.1	47.2	9.2	0.04	ND	80.4
15	火	24.8	21.4	0.8	7.1	26.7	31.2	44.4	8.1	0.05	ND	81.7
16	水	26.0	21.0	1.9	7.1	27.4	30.6	49.2	8.3	0.08	ND	82.5
17	木	29.7	21.2	1.0	7.2	28.1	30.8	42.4	7.2	0.08	ND	83.8
18	金	26.5	21.8	1.2	7.1	26.4	28.9	49.6	8.5	0.06	ND	78.0
19	土	29.8	21.8	1.7	7.3	25.4	29.1	45.2	7.4	0.08	ND	75.7
20	日	27.6	22.3	1.6	7.4	26.8	29.9	44.0	8.1	0.08	ND	80.8
21	月	31.4	22.5	1.5	7.3	28.4	29.7	43.6	6.8	0.10	ND	81.4
22	火	30.6	23.0	1.7	7.3	26.8	31.2	40.0	7.7	0.10	ND	76.9
23	水	29.0	22.5	1.8	7.2	27.0	30.6	42.0	7.7	0.12	ND	74.2
24	木	30.6	22.6	2.6	7.1	21.4	24.5	44.0	7.3	0.12	ND	69.8
25	金	27.0	22.2	3.4	7.1	23.5	25.9	46.8	7.4	0.15	ND	70.6
26	土	26.5	19.0	1.8	7.3	32.5	33.6	69.6	9.8	0.07	ND	99.9
27	日	27.5	19.8	1.4	7.2	22.1	24.9	48.0	8.7	0.04	ND	72.6
28	月	29.5	21.2	1.2	7.2	24.9	28.5	48.0	7.6	0.04	ND	77.0
29	火	31.9	21.1	1.7	7.2	26.1	28.1	56.0	6.9	0.07	ND	76.2
30	水	27.4	21.8	1.6	7.3	25.2	29.9	58.4	7.2	0.09	ND	75.6
31	木	26.8	21.2	3.0	7.2	25.7	27.5	46.4	6.9	0.11	ND	75.7
最大値		35.1	26.8	3.4	7.4	34.1	36.2	69.6	14.9	0.15	0.01	99.9
最小値		24.8	19.0	0.7	6.6	12.2	18.7	40.0	6.8	0.02	ND	58.7
平均値		29.6	22.3	1.6	7.2	26.7	29.6	49.4	9.8	0.09	ND	81.0

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 濁度およびpH以外の基準については参考値とする。  
 本試験結果はJIS.K.0101(工業用水試験法)による。