

水質試験結果表(取水分)

2017年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	19.7	17.2	1.2	7.5	28.8	28.5	45.6	7.0	0.16	ND	81.7
2	月	21.1	17.4	1.7	7.4	28.3	30.4	48.0	7.9	0.18	ND	78.9
3	火	21.6	17.2	2.3	7.4	25.9	26.7	44.0	7.0	0.16	ND	72.9
4	水	22.2	16.9	2.0	7.3	25.5	28.1	42.8	6.1	0.18	ND	72.2
5	木	19.0	16.3	1.7	7.3	28.4	29.3	46.4	7.9	0.15	ND	82.3
6	金	20.3	16.3	1.5	7.4	30.4	31.0	54.0	7.9	0.15	ND	86.1
7	土	19.3	16.0	2.2	7.4	26.3	28.1	45.6	6.0	0.12	ND	79.1
8	日	20.2	17.0	1.0	7.5	28.3	30.2	40.0	9.0	0.15	ND	83.0
9	月	25.7	18.5	0.7	7.5	31.8	32.2	44.0	8.2	0.14	ND	91.7
10	火	25.5	18.8	1.9	7.4	31.3	33.6	58.0	9.8	0.21	ND	92.0
11	水	22.4	18.8	1.7	7.4	31.5	32.0	56.0	9.4	0.15	ND	89.5
12	木	19.3	18.4	1.7	7.4	30.1	30.4	51.2	8.5	0.17	ND	85.6
13	金	15.1	17.2	1.3	7.4	30.1	31.4	55.2	8.1	0.15	ND	86.1
14	土	18.1	17.1	0.9	7.5	29.4	30.8	53.2	8.1	0.12	0.01	87.0
15	日	18.4	17.0	1.0	7.5	31.0	32.4	50.0	8.0	0.12	0.01	90.6
16	月	15.0	16.4	1.1	7.3	29.6	33.2	51.6	8.0	0.20	ND	86.4
17	火	18.0	16.0	2.0	7.4	31.8	33.4	59.2	7.4	0.25	ND	90.3
18	水	21.0	16.2	1.9	7.4	32.5	37.6	50.4	7.0	0.16	ND	93.7
19	木	15.0	16.0	2.0	7.4	32.5	32.8	46.8	7.3	0.16	0.01	92.0
20	金	20.4	15.9	1.8	7.4	28.5	30.2	49.6	6.5	0.16	ND	82.3
21	土	18.7	16.1	1.1	7.3	26.9	29.3	44.8	7.1	0.09	ND	75.6
22	日	17.8	16.1	1.2	7.5	27.4	30.2	40.8	8.6	0.10	ND	75.7
23	月	14.6	15.8	51.4	7.3	27.8	29.9	116.0	8.5	1.44	0.05	80.8
24	火	16.1	14.6	21.7	7.4	26.7	26.5	75.2	6.2	0.89	0.09	73.3
25	水	14.1	14.4	12.7	7.2	25.4	22.9	52.4	6.3	0.44	0.04	63.8
26	木	17.7	13.8	11.6	7.3	23.4	23.9	55.2	6.8	0.41	0.03	67.8
27	金	18.3	14.0	10.7	7.3	24.1	25.3	53.6	7.3	0.35	0.02	70.0
28	土	18.7	14.6	5.5	7.4	25.1	24.7	43.2	6.4	0.27	0.01	71.6
29	日	15.9	14.8	7.4	7.3	25.5	26.1	44.0	7.0	0.23	0.01	71.6
30	月	13.8	14.9	25.9	7.3	20.3	23.3	64.4	7.2	0.91	0.05	56.3
31	火	14.7	13.0	10.1	7.3	20.2	23.5	46.0	6.6	0.33	0.01	59.2
最大値		25.7	18.8	51.4	7.5	32.5	37.6	116.0	9.8	1.44	0.09	93.7
最小値		13.8	13.0	0.7	7.2	20.2	22.9	40.0	6.0	0.09	ND	56.3
平均値		18.6	16.2	6.2	7.4	27.9	29.3	52.5	7.5	0.28	0.01	79.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2017年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	19.7	17.4	0.8	7.5	29.5	28.1	36.8	7.7	0.10	ND	81.6
2	月	21.1	17.3	0.9	7.4	27.9	29.9	48.8	8.1	0.11	ND	80.2
3	火	21.6	17.2	1.3	7.3	25.6	26.1	40.0	8.4	0.07	ND	75.0
4	水	22.2	17.0	1.4	7.4	26.2	26.9	36.4	6.9	0.11	ND	73.0
5	木	19.0	16.7	1.3	7.4	27.5	28.9	46.0	8.2	0.12	ND	79.7
6	金	20.3	16.3	1.4	7.4	29.1	30.2	52.0	8.9	0.10	ND	85.8
7	土	19.3	16.0	1.1	7.5	27.6	29.9	46.4	8.5	0.10	ND	84.8
8	日	20.2	16.9	1.1	7.5	27.6	29.5	36.0	8.9	0.13	ND	81.8
9	月	25.7	18.4	0.7	7.5	30.8	31.4	44.4	8.6	0.12	ND	90.5
10	火	25.5	19.0	1.0	7.5	32.8	34.8	49.6	9.5	0.11	ND	91.5
11	水	22.4	18.9	1.1	7.4	31.1	33.0	54.4	9.8	0.11	ND	91.6
12	木	19.3	18.4	1.1	7.4	30.2	31.2	46.8	10.4	0.11	ND	86.9
13	金	15.1	17.3	1.3	7.4	29.8	31.2	57.2	8.4	0.12	ND	88.0
14	土	18.1	17.1	0.9	7.5	31.5	32.8	45.6	8.5	0.13	0.01	89.0
15	日	18.4	17.1	1.0	7.6	31.3	33.8	47.2	8.0	0.14	ND	90.6
16	月	15.0	16.5	1.0	7.5	30.9	31.0	45.6	8.7	0.16	ND	87.4
17	火	18.0	16.0	1.2	7.5	30.3	31.0	49.2	7.2	0.15	ND	88.1
18	水	21.0	16.0	1.4	7.4	33.9	35.4	45.6	6.9	0.12	ND	94.4
19	木	15.0	16.0	1.7	7.4	32.4	33.6	51.6	8.2	0.10	ND	94.1
20	金	20.4	15.8	1.2	7.4	29.3	31.2	44.4	7.7	0.10	ND	82.5
21	土	18.7	16.0	0.9	7.4	28.0	29.1	42.8	7.3	0.07	ND	77.4
22	日	17.8	16.1	1.0	7.5	29.1	30.4	40.0	8.5	0.08	ND	76.9
23	月	14.6	15.9	1.5	7.1	20.4	25.1	41.2	10.2	0.07	ND	73.0
24	火	16.1	14.6	1.9	7.2	22.8	28.1	40.8	8.8	0.06	ND	77.7
25	水	14.1	14.4	2.2	7.1	21.9	22.9	40.4	8.9	0.07	ND	68.1
26	木	17.7	14.0	2.5	7.2	22.9	24.7	46.0	8.7	0.08	ND	72.4
27	金	18.3	14.2	2.5	7.1	22.5	26.1	44.4	8.6	0.08	ND	73.2
28	土	18.7	14.8	1.7	7.3	23.2	24.9	40.0	8.3	0.06	ND	73.6
29	日	15.9	14.8	1.3	7.2	24.0	24.9	41.6	9.7	0.04	ND	73.6
30	月	13.8	14.8	1.6	7.0	20.4	24.1	40.4	10.1	0.06	ND	66.4
31	火	14.7	13.2	2.4	7.1	17.6	22.7	40.4	8.5	0.08	ND	60.4
最大値		25.7	19.0	2.5	7.6	33.9	35.4	57.2	10.4	0.16	0.01	94.4
最小値		13.8	13.2	0.7	7.0	17.6	22.7	36.0	6.9	0.04	ND	60.4
平均値		18.6	16.3	1.4	7.4	27.4	29.1	44.6	8.6	0.10	ND	80.9

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所