

## 水質試験結果表(取水分)

2018年3月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	10.1	6.0	8.4	6.9	23.2	33.4	69.6	16.6	0.46	0.04	114.8
2	金	8.5	4.3	42.0	6.8	15.0	21.1	102.4	15.9	0.78	0.13	88.4
3	土	5.3	5.0	20.7	6.9	22.9	27.5	56.8	15.1	0.32	0.02	93.8
4	日	12.6	6.7	6.6	6.9	25.6	30.8	48.8	15.3	0.24	0.02	96.5
5	月	14.0	6.9	17.5	6.9	24.0	26.9	70.4	14.0	0.46	0.03	88.6
6	火	7.2	6.0	108.0	6.9	26.0	31.4	172.8	11.6	1.21	0.21	88.5
7	水	9.2	6.0	40.5	7.0	22.8	27.5	108.0	12.9	1.12	0.07	92.2
8	木	10.0	7.2	18.4	7.0	23.7	33.6	88.0	14.6	0.79	0.06	98.8
9	金	6.6	7.4	79.1	7.0	25.2	29.3	132.4	11.8	1.32	0.22	82.0
10	土	5.8	7.2	28.2	7.1	26.4	30.6	92.0	12.8	0.73	0.09	95.9
11	日	4.6	7.8	17.4	7.1	27.5	35.4	73.2	13.9	0.75	0.05	108.6
12	月	8.1	7.0	17.0	6.9	25.3	33.6	84.4	14.5	0.46	0.04	98.9
13	火	10.2	8.0	11.5	7.0	27.7	31.8	81.6	12.1	0.52	0.02	104.6
14	水	13.4	9.0	11.0	7.0	27.9	32.8	72.8	12.2	0.54	0.03	105.3
15	木	14.5	9.1	16.2	6.9	20.2	24.5	68.8	12.2	0.16	0.03	87.5
16	金	8.3	9.6	33.0	6.9	17.9	23.3	72.0	10.5	0.99	0.07	79.6
17	土	7.8	6.8	29.3	6.8	16.7	22.5	76.0	12.0	0.54	0.08	73.7
18	日	12.2	8.0	13.8	6.9	19.2	24.3	54.8	13.3	0.35	0.04	83.2
19	月	10.7	9.3	12.6	6.9	20.8	25.5	68.0	12.7	0.23	0.03	84.6
20	火	7.5	8.3	32.6	6.8	17.4	23.5	92.0	9.8	0.76	0.09	72.4
21	水	4.9	7.2	15.1	6.9	18.0	22.5	67.2	10.5	0.44	0.03	77.7
22	木	8.8	7.5	27.3	6.9	17.9	24.3	83.2	10.1	0.59	0.06	75.0
23	金	7.3	7.7	34.8	6.8	16.3	27.1	86.8	11.0	0.35	0.09	71.5
24	土	7.0	7.6	12.4	6.9	17.9	22.5	66.4	12.9	0.41	0.04	80.8
25	日	13.0	9.2	9.8	7.0	19.6	23.7	68.0	13.1	0.35	0.02	85.0
26	月	13.4	9.8	11.4	6.9	20.8	25.1	75.2	12.4	0.53	0.03	84.4
27	火	14.8	10.1	11.2	6.9	21.2	30.2	70.4	12.8	0.18	0.02	88.6
28	水	16.6	10.4	10.3	6.9	21.7	26.3	64.8	11.4	0.28	0.03	87.0
29	木	17.1	10.5	8.6	7.0	20.9	26.7	64.8	11.5	0.21	0.04	83.2
30	金	16.2	10.8	11.0	6.8	20.9	28.3	60.4	11.6	0.46	0.05	87.8
31	土	11.7	9.7	5.7	6.9	21.2	26.3	58.0	10.3	0.27	0.01	87.8
最大値		17.1	10.8	108.0	7.1	27.9	35.4	172.8	16.6	1.32	0.22	114.8
最小値		4.6	4.3	5.7	6.8	15.0	21.1	48.8	9.8	0.16	0.01	71.5
平均値		10.2	7.9	23.3	6.9	21.7	27.5	79.0	12.6	0.54	0.06	88.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2018年3月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	木	10.1	6.3	1.2	7.0	22.4	34.4	66.4	18.4	0.08	ND	118.3
2	金	8.5	4.4	4.7	6.9	16.0	21.3	54.8	18.7	0.10	ND	100.7
3	土	5.3	5.4	2.5	7.0	25.6	27.7	46.0	17.9	0.05	0.01	101.7
4	日	12.6	6.6	1.8	7.0	26.9	27.7	40.0	17.9	0.05	ND	103.6
5	月	14.0	7.3	1.4	6.9	22.8	28.1	48.0	15.9	0.04	ND	94.0
6	火	7.2	5.6	2.4	6.7	30.6	36.2	55.2	19.9	0.08	ND	128.7
7	水	9.2	6.2	2.5	7.0	23.1	26.9	57.2	17.0	0.10	ND	103.2
8	木	10.0	7.3	1.6	7.1	26.1	33.2	66.8	17.2	0.05	ND	110.3
9	金	6.6	7.7	3.9	7.1	23.5	27.7	50.0	16.1	0.10	ND	99.9
10	土	5.8	7.2	2.8	7.0	23.9	32.2	60.0	16.1	0.07	ND	102.1
11	日	4.6	8.0	1.3	7.1	27.1	35.4	64.8	15.9	0.04	ND	114.8
12	月	8.1	7.3	1.7	7.1	25.5	36.0	60.8	15.4	0.04	ND	108.2
13	火	10.2	8.1	1.4	7.0	27.5	32.2	69.6	14.6	0.05	ND	108.9
14	水	13.4	9.1	1.8	7.0	26.9	32.0	60.0	13.8	0.08	ND	109.8
15	木	14.5	9.3	1.8	6.9	20.5	26.5	48.0	15.2	0.04	ND	95.9
16	金	8.3	9.9	2.5	6.9	18.4	21.9	42.4	13.8	0.05	ND	88.1
17	土	7.8	7.0	3.9	6.9	17.0	22.5	47.2	14.9	0.08	ND	80.2
18	日	12.2	8.1	1.6	7.0	19.7	24.7	41.2	14.3	0.02	ND	88.8
19	月	10.7	9.1	2.0	7.0	20.9	27.3	46.8	14.2	0.02	ND	90.6
20	火	7.5	8.4	3.0	6.9	19.3	23.7	55.2	13.2	0.06	ND	87.3
21	水	4.9	7.2	3.4	7.0	19.0	23.9	46.4	12.9	0.09	ND	83.6
22	木	8.8	7.7	2.6	6.9	18.6	24.3	48.4	13.8	0.07	ND	84.2
23	金	7.3	7.9	3.1	6.8	17.1	24.3	40.0	13.8	0.08	ND	81.4
24	土	7.0	7.8	2.7	7.0	17.8	23.3	53.6	14.2	0.10	ND	85.4
25	日	13.0	9.4	1.6	7.0	20.2	25.7	48.0	14.5	0.02	ND	89.7
26	月	13.4	9.9	1.9	7.0	21.2	24.9	54.8	13.9	0.03	ND	90.0
27	火	14.8	10.3	2.2	7.0	21.5	29.5	62.8	14.2	0.05	ND	91.7
28	水	16.6	10.6	2.0	6.9	20.3	25.9	51.2	14.2	0.04	ND	90.3
29	木	17.1	10.8	1.8	6.8	21.6	28.5	52.0	13.0	0.04	ND	89.9
30	金	16.2	10.9	1.9	7.0	20.6	28.1	52.4	12.3	0.05	ND	84.0
31	土	11.7	10.0	1.7	7.0	20.7	25.1	57.2	12.7	0.07	ND	92.0
最大値		17.1	10.9	4.7	7.1	30.6	36.2	69.6	19.9	0.10	0.01	128.7
最小値		4.6	4.4	1.2	6.7	16.0	21.3	40.0	12.3	0.02	ND	80.2
平均値		10.2	8.1	2.3	7.0	22.0	27.8	53.1	15.2	0.06	ND	96.7

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所