

水質試験結果表(取水分)

2018年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	31.9	21.2	2.7	7.2	36.9	34.8	50.4	6.4	0.17	ND	97.0
2	月	32.8	21.8	3.6	7.1	34.4	37.2	56.4	6.6	0.27	ND	93.9
3	火	30.7	22.5	4.2	7.1	33.4	32.4	66.8	7.3	0.27	0.01	92.7
4	水	27.2	21.7	4.3	7.1	32.5	33.2	57.2	7.7	0.25	ND	90.0
5	木	23.7	20.2	17.0	7.0	27.1	26.9	67.2	6.7	0.73	0.03	81.9
6	金	23.1	18.1	175.0	6.9	15.2	20.9	259.2	4.8	0.96	0.12	44.9
7	土	22.4	18.2	42.6	7.3	27.3	25.9	103.6	5.5	0.93	0.11	71.6
8	日	26.1	18.1	62.2	7.4	29.2	30.6	109.2	7.8	0.47	0.15	76.1
9	月	32.1	18.4	36.8	7.3	30.8	31.0	80.4	7.1	0.60	0.06	81.1
10	火	32.0	18.9	35.8	7.1	25.4	25.7	77.6	7.3	1.37	0.19	67.0
11	水	32.5	19.3	28.9	7.1	24.5	26.1	78.4	5.7	0.96	0.14	67.6
12	木	26.1	19.6	15.8	7.3	29.2	30.6	56.4	7.2	0.52	0.05	77.6
13	金	31.1	19.7	15.5	7.3	28.2	28.9	64.8	8.2	0.59	0.04	77.0
14	土	31.9	20.0	5.6	7.4	32.5	32.2	58.8	6.7	0.18	0.01	79.8
15	日	34.7	21.6	4.8	7.3	39.4	33.6	64.0	7.4	0.19	0.01	107.1
16	月	31.4	22.3	4.9	7.4	38.2	38.2	64.8	8.2	0.29	0.01	96.3
17	火	32.6	22.5	7.2	7.2	32.3	33.4	55.2	8.4	0.15	0.01	91.2
18	水	34.2	22.0	8.4	7.2	29.6	29.5	57.2	6.7	0.29	0.01	80.5
19	木	32.3	22.1	8.5	7.3	29.1	27.7	58.8	6.4	0.34	0.02	78.2
20	金	33.8	22.1	9.8	7.3	29.5	30.6	60.8	6.2	0.10	0.03	81.8
21	土	33.7	23.0	3.7	7.4	36.0	28.9	43.2	6.5	0.21	ND	83.2
22	日	33.9	24.0	2.3	7.4	40.6	35.0	48.0	8.9	0.16	ND	95.9
23	月	35.8	24.0	6.0	7.2	37.1	35.0	57.2	7.2	0.32	0.01	93.8
24	火	33.2	23.0	6.9	7.3	30.9	28.7	52.0	6.5	0.19	0.02	80.9
25	水	32.1	22.8	7.3	7.1	29.8	32.8	48.4	6.5	0.33	0.03	78.9
26	木	32.7	23.0	7.5	7.2	29.1	28.1	53.6	6.7	0.27	0.02	81.5
27	金	32.0	23.1	6.6	7.3	30.7	29.9	46.8	6.5	0.12	0.02	79.9
28	土	30.2	22.8	3.9	7.4	31.5	32.4	55.6	6.7	0.09	0.01	86.0
29	日	33.6	23.3	2.6	7.4	35.9	36.0	49.6	6.9	0.08	ND	94.9
30	月	34.3	24.0	3.2	7.3	37.7	37.8	59.2	8.3	0.24	ND	98.1
31	火	36.1	25.0	3.2	7.2	35.7	35.6	56.0	8.2	0.20	ND	96.3
最大値		36.1	25.0	175.0	7.4	40.6	38.2	259.2	8.9	1.37	0.19	107.1
最小値		22.4	18.1	2.3	6.9	15.2	20.9	43.2	4.8	0.08	ND	44.9
平均値		31.3	21.6	17.6	7.2	31.6	31.3	68.3	7.0	0.38	0.04	84.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2018年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	31.9	21.3	1.2	7.3	35.4	35.0	42.8	7.9	0.10	ND	93.3
2	月	32.8	22.0	1.2	7.2	37.8	38.0	60.4	8.1	0.12	ND	100.1
3	火	30.7	22.6	1.4	7.1	31.7	31.4	65.2	8.8	0.10	ND	91.3
4	水	27.2	21.6	1.6	7.1	31.5	33.8	56.8	8.3	0.11	ND	90.7
5	木	23.7	20.5	1.6	7.1	27.8	28.9	53.6	9.3	0.03	ND	72.1
6	金	23.1	18.3	4.9	6.5	10.2	18.5	48.4	9.9	0.19	ND	48.5
7	土	22.4	18.1	1.4	7.1	22.2	25.5	41.6	10.6	0.08	ND	80.0
8	日	26.1	17.9	1.1	7.1	28.7	33.4	48.0	11.0	0.03	ND	96.2
9	月	32.1	18.5	1.8	7.1	32.2	36.0	62.8	10.6	0.04	ND	97.7
10	火	32.0	18.8	1.6	6.7	20.7	24.1	44.8	8.9	0.04	ND	67.0
11	水	32.5	19.4	2.2	6.8	22.2	24.9	53.6	8.1	0.05	ND	67.6
12	木	26.1	19.7	1.5	7.1	24.5	30.4	45.6	8.9	0.04	ND	77.6
13	金	31.1	19.7	1.6	7.1	25.3	27.5	48.0	9.7	0.04	ND	77.0
14	土	31.9	20.1	1.3	7.3	35.9	30.4	54.0	8.7	0.04	ND	79.8
15	日	34.7	21.7	0.7	7.3	43.3	32.8	58.0	10.0	0.02	ND	107.1
16	月	31.4	22.5	0.9	7.4	44.7	36.2	68.8	8.8	0.03	ND	96.3
17	火	32.6	22.6	1.2	7.2	38.1	35.8	54.0	8.9	0.03	ND	91.2
18	水	34.2	22.0	1.8	7.1	27.8	31.6	55.6	8.5	0.01	ND	83.3
19	木	32.3	22.2	1.3	7.1	27.2	28.1	52.4	8.3	0.04	ND	80.3
20	金	33.8	22.2	1.3	7.1	27.4	29.1	49.2	8.7	0.04	ND	80.4
21	土	33.7	23.0	0.9	7.3	38.1	30.8	40.0	9.2	0.04	ND	85.3
22	日	33.9	24.1	0.9	7.4	42.3	33.6	48.4	9.3	0.06	ND	96.5
23	月	35.8	24.1	1.5	7.4	39.7	34.8	47.2	8.2	0.08	ND	98.7
24	火	33.2	23.3	1.7	7.2	30.6	31.0	47.2	8.1	0.08	ND	84.5
25	水	32.1	23.0	1.9	7.0	29.6	31.8	48.8	7.2	0.07	ND	80.4
26	木	32.7	23.0	1.8	7.2	27.5	29.1	52.0	8.0	0.06	ND	82.0
27	金	32.0	23.2	1.9	7.2	27.8	30.8	52.8	8.0	0.03	ND	81.6
28	土	30.2	23.0	1.8	7.4	31.1	30.2	40.0	8.2	0.04	ND	85.4
29	日	33.6	23.5	1.7	7.5	36.3	35.8	52.4	8.0	0.10	ND	96.4
30	月	34.3	24.3	1.8	7.4	37.9	38.2	61.6	8.3	0.14	ND	102.2
31	火	36.1	25.1	1.9	7.3	34.9	37.2	50.0	8.3	0.07	ND	98.1
最大値		36.1	25.1	4.9	7.5	44.7	38.2	68.8	11.0	0.19	ND	107.1
最小値		22.4	17.9	0.7	6.5	10.2	18.5	40.0	7.2	0.01	ND	48.5
平均値		31.3	21.7	1.6	7.2	31.3	31.4	51.7	8.8	0.06	ND	86.1

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所