

水質試験結果表(取水分)

2018年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	水	33.5	25.2	3.0	7.2	35.7	35.6	56.4	9.0	0.11	ND	96.4
2	木	34.4	25.4	2.6	7.1	38.1	40.8	62.4	7.7	0.20	0.01	99.2
3	金	34.2	25.3	2.4	7.2	33.6	34.2	49.2	7.4	0.17	ND	93.2
4	土	31.3	24.8	1.4	7.4	34.8	33.0	60.0	8.5	0.13	ND	97.1
5	日	33.2	24.9	1.6	7.5	37.7	35.8	64.8	8.5	0.14	ND	100.6
6	月	30.8	25.1	2.4	7.3	37.3	34.2	60.8	8.0	0.20	0.01	97.7
7	火	30.6	24.4	3.4	7.3	34.8	36.0	60.4	8.8	0.22	0.01	100.1
8	水	29.8	24.0	3.4	7.2	35.4	33.6	58.4	8.2	0.22	0.01	96.5
9	木	28.3	23.0	2.8	7.3	33.0	34.2	60.0	8.4	0.11	ND	92.8
10	金	29.2	22.9	2.5	7.3	35.6	33.4	58.4	8.1	0.17	0.01	93.2
11	土	33.5	23.4	1.3	7.4	36.3	33.0	52.4	7.7	0.10	ND	100.9
12	日	31.9	24.1	1.7	7.4	37.7	37.6	53.2	8.9	0.18	ND	107.4
13	月	31.9	24.1	2.3	7.4	42.7	41.6	72.8	7.9	0.22	ND	108.2
14	火	33.5	24.3	2.9	7.4	43.6	51.7	72.0	10.7	0.19	ND	108.5
15	水	33.7	24.6	3.5	7.4	41.3	38.0	72.0	8.8	0.24	0.01	104.1
16	木	31.2	24.0	2.4	7.4	39.2	40.2	69.2	9.5	0.22	0.01	106.7
17	金	27.8	22.2	5.3	7.3	34.2	34.0	55.2	6.8	0.31	0.02	90.1
18	土	24.4	21.5	1.8	7.5	37.9	36.2	67.2	8.6	0.14	ND	115.9
19	日	27.4	22.0	1.7	7.5	38.7	37.2	62.0	11.2	0.16	ND	103.2
20	月	28.2	22.1	2.6	7.4	40.9	40.2	68.4	8.8	0.24	ND	103.6
21	火	32.0	23.0	2.7	7.3	34.1	36.4	60.8	8.7	0.18	ND	94.4
22	水	33.8	24.0	2.8	7.3	33.3	33.0	66.0	9.0	0.18	ND	91.9
23	木	35.1	24.2	3.1	7.2	33.4	32.4	60.8	8.8	0.19	ND	92.4
24	金	31.1	23.9	5.8	7.3	30.2	29.3	61.6	8.3	0.27	0.01	84.1
25	土	30.9	22.2	15.3	7.4	28.4	32.6	61.2	7.1	0.55	0.03	76.5
26	日	33.0	23.0	5.6	7.5	38.8	37.8	64.8	7.8	0.24	0.01	97.8
27	月	31.5	23.2	6.9	7.3	40.8	40.0	72.0	8.3	0.32	0.01	110.8
28	火	27.3	23.9	7.2	7.3	35.0	36.6	64.8	8.7	0.28	0.01	96.4
29	水	28.0	22.2	11.0	7.3	32.0	32.2	67.2	8.1	0.43	0.04	88.0
30	木	30.4	22.9	6.2	7.3	32.1	33.0	72.8	7.7	0.30	0.02	91.0
31	金	28.7	23.1	4.8	7.3	33.4	35.2	58.0	8.6	0.24	0.02	94.7
最大値		35.1	25.4	15.3	7.5	43.6	51.7	72.8	11.2	0.55	0.04	115.9
最小値		24.4	21.5	1.3	7.1	28.4	29.3	49.2	6.8	0.10	ND	76.5
平均値		31.0	23.6	3.9	7.3	36.1	36.1	62.7	8.5	0.22	0.01	97.9

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2018年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	水	33.5	25.4	1.9	7.3	35.2	35.8	55.2	9.4	0.12	ND	97.6
2	木	34.4	25.7	1.7	7.2	37.1	42.0	58.8	8.4	0.12	ND	96.9
3	金	34.2	25.5	1.7	7.2	34.0	33.6	47.6	8.1	0.12	ND	94.0
4	土	31.3	25.0	1.2	7.5	35.6	35.0	63.2	8.6	0.09	ND	97.3
5	日	33.2	25.2	1.3	7.5	37.5	37.8	60.0	8.6	0.09	ND	103.5
6	月	30.8	25.4	1.2	7.5	39.2	36.2	64.4	8.4	0.11	ND	99.6
7	火	30.6	25.0	1.8	7.4	34.6	36.6	56.8	8.8	0.12	ND	96.0
8	水	29.8	24.3	2.3	7.3	34.3	35.8	56.0	8.7	0.13	ND	94.0
9	木	28.3	23.0	2.4	7.3	33.1	34.2	58.8	9.9	0.11	ND	92.8
10	金	29.2	22.9	1.6	7.3	33.9	33.8	60.8	9.4	0.09	ND	91.4
11	土	33.5	23.5	0.8	7.4	34.9	33.6	52.4	9.3	0.06	ND	103.5
12	日	31.9	24.5	0.8	7.6	39.9	36.8	53.2	10.0	0.12	ND	104.6
13	月	31.9	24.4	0.9	7.5	42.3	41.0	73.6	8.8	0.12	ND	111.0
14	火	33.5	24.2	1.3	7.5	43.1	48.2	74.8	9.5	0.10	ND	108.7
15	水	33.7	24.5	0.9	7.5	40.9	40.2	74.8	9.8	0.08	ND	110.6
16	木	31.2	24.3	1.0	7.5	39.3	39.8	66.0	9.6	0.11	ND	107.6
17	金	27.8	22.5	1.6	7.3	34.3	37.0	53.6	8.3	0.09	ND	90.2
18	土	24.4	21.8	1.8	7.5	35.9	35.0	61.2	9.8	0.12	ND	98.9
19	日	27.4	22.0	1.0	7.6	38.0	38.4	57.2	10.0	0.10	ND	100.8
20	月	28.2	22.4	1.2	7.5	40.0	38.2	66.8	9.8	0.12	ND	105.7
21	火	32.0	23.0	1.5	7.4	34.4	35.6	56.0	10.0	0.08	ND	95.9
22	水	33.8	24.2	1.7	7.3	32.2	32.6	65.2	9.6	0.08	ND	92.7
23	木	35.1	24.4	1.7	7.3	32.4	33.4	66.4	8.4	0.10	ND	92.2
24	金	31.1	24.0	1.8	7.3	31.0	31.4	50.4	9.8	0.08	ND	87.8
25	土	30.9	22.3	2.0	7.3	29.8	30.6	50.8	8.8	0.04	ND	80.1
26	日	33.0	23.2	1.5	7.4	38.5	35.6	58.0	8.5	0.04	ND	95.5
27	月	31.5	23.5	1.3	7.3	42.4	39.6	72.8	9.8	0.04	ND	103.0
28	火	27.3	24.0	1.6	7.2	33.3	36.0	64.4	9.7	0.03	ND	96.0
29	水	28.0	22.2	2.4	7.2	30.9	33.2	55.2	8.7	0.08	ND	88.6
30	木	30.4	22.7	2.8	7.3	30.8	34.2	64.0	8.5	0.11	ND	93.1
31	金	28.7	23.1	2.1	7.3	32.7	35.2	54.0	8.9	0.09	0.01	96.4
最大値		35.1	25.7	2.8	7.6	43.1	48.2	74.8	10.0	0.13	0.01	111.0
最小値		24.4	21.8	0.8	7.2	29.8	30.6	47.6	8.1	0.03	ND	80.1
平均値		31.0	23.8	1.6	7.4	35.9	36.3	60.4	9.2	0.09	ND	97.6

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所