

### 水質試験結果表(取水分)

2018年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	月	24.2	18.8	114.8	7.3	17.3	18.9	106.8	5.7	0.95	0.01	45.6
2	火	21.8	17.1	15.2	7.3	19.7	20.7	56.0	8.4	0.72	0.06	53.2
3	水	20.7	17.0	8.8	7.2	22.3	24.5	42.4	8.3	0.37	0.02	57.7
4	木	17.4	17.0	4.5	7.3	23.8	25.9	47.2	8.8	0.26	ND	65.7
5	金	23.1	16.9	6.2	7.3	25.5	25.7	54.4	6.3	0.29	0.01	68.3
6	土	28.0	18.4	2.8	7.4	28.7	26.9	49.6	7.1	0.16	ND	70.6
7	日	23.7	19.5	3.0	7.4	30.0	28.5	44.0	8.7	0.16	ND	77.0
8	月	23.5	18.9	4.7	7.4	30.7	29.7	51.2	10.3	0.24	ND	79.6
9	火	22.9	18.1	6.2	7.3	31.9	31.6	58.8	9.8	0.35	0.02	79.1
10	水	20.8	18.0	4.7	7.4	26.0	26.5	42.4	7.4	0.22	ND	71.8
11	木	17.6	17.2	4.9	7.4	25.7	26.3	49.6	6.8	0.25	0.01	69.8
12	金	15.6	16.9	4.9	7.3	25.1	28.5	40.0	8.4	0.26	0.01	68.3
13	土	18.8	16.3	2.3	7.3	27.7	27.3	48.4	7.7	0.16	ND	72.7
14	日	22.2	17.0	2.4	7.4	30.5	29.7	44.8	8.4	0.15	ND	79.5
15	月	16.3	17.1	3.1	7.4	30.4	31.0	52.0	8.2	0.21	ND	80.1
16	火	17.6	16.5	3.0	7.4	28.7	30.2	46.8	9.2	0.17	0.01	79.5
17	水	23.6	16.7	2.8	7.4	29.7	30.2	46.8	8.4	0.16	ND	80.8
18	木	19.0	16.2	2.1	7.4	31.8	32.8	56.0	10.7	0.16	ND	87.7
19	金	20.6	16.1	1.9	7.4	31.8	33.0	59.2	10.6	0.15	ND	88.8
20	土	16.3	15.9	1.3	7.6	33.5	33.2	52.0	8.1	0.11	ND	91.6
21	日	17.6	15.3	1.2	7.5	35.0	34.0	47.2	9.0	0.12	ND	90.6
22	月	17.5	15.1	1.6	7.4	34.8	36.2	52.0	8.9	0.18	ND	91.1
23	火	19.2	15.2	1.3	7.4	33.2	34.6	53.2	9.4	0.13	ND	91.3
24	水	18.9	15.6	4.5	7.5	30.3	39.6	50.8	8.9	0.26	0.02	86.7
25	木	21.5	15.2	1.3	7.5	31.7	33.6	52.0	8.9	0.13	ND	93.1
26	金	19.4	15.0	1.4	7.4	32.3	33.4	54.0	11.7	0.10	ND	88.6
27	土	16.9	16.0	1.1	7.4	31.5	32.2	47.2	8.8	0.10	ND	88.5
28	日	13.1	15.0	1.6	7.5	28.8	31.4	42.4	9.7	0.12	ND	88.2
29	月	12.8	14.2	1.6	7.5	26.9	29.7	46.8	8.6	0.12	ND	73.7
30	火	13.9	14.5	2.6	7.4	25.0	27.1	43.2	8.5	0.14	ND	71.2
31	水	12.5	14.0	2.1	7.4	24.5	27.9	43.2	10.4	0.13	ND	73.1
最大値		28.0	19.5	114.8	7.6	35.0	39.6	106.8	11.7	0.95	0.06	93.1
最小値		12.5	14.0	1.1	7.2	17.3	18.9	40.0	5.7	0.10	ND	45.6
平均値		19.3	16.5	7.1	7.4	28.5	29.7	51.0	8.7	0.23	0.01	77.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2018年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	24.2	18.3	2.3	7.1	17.1	20.5	38.0	7.9	0.04	ND	55.6
2	火	21.8	17.1	3.1	7.2	18.5	20.1	39.2	9.0	0.05	ND	57.5
3	水	20.7	17.0	2.5	7.0	18.8	23.9	30.0	8.5	0.08	ND	58.1
4	木	17.4	17.0	3.2	6.6	21.9	24.9	36.0	9.0	0.07	ND	67.2
5	金	23.1	16.8	2.7	7.2	24.0	25.7	49.6	8.0	0.09	ND	69.4
6	土	28.0	18.3	1.5	7.3	30.9	27.5	43.2	8.6	0.03	ND	71.5
7	日	23.7	19.8	0.9	7.4	30.6	28.3	42.8	9.2	0.04	ND	78.2
8	月	23.5	19.2	1.4	7.4	31.4	27.9	48.0	9.2	0.06	ND	79.9
9	火	22.9	18.3	2.3	7.3	33.9	30.8	48.4	10.2	0.09	ND	80.3
10	水	20.8	18.0	2.8	7.3	25.6	28.5	40.0	8.6	0.08	ND	74.2
11	木	17.6	17.2	2.6	7.3	25.2	26.3	49.2	8.3	0.10	ND	72.0
12	金	15.6	16.8	2.5	7.2	23.9	28.9	42.0	9.0	0.09	ND	69.6
13	土	18.8	16.5	2.6	7.4	28.6	28.1	48.0	8.7	0.12	ND	74.2
14	日	22.2	17.0	1.6	7.4	29.0	29.9	42.8	8.8	0.08	ND	80.7
15	月	16.3	17.1	1.6	7.4	29.7	29.3	48.8	9.2	0.09	ND	80.4
16	火	17.6	16.3	2.7	7.4	28.2	30.4	42.8	9.5	0.11	ND	81.1
17	水	23.6	16.6	3.0	7.4	28.0	31.0	48.8	8.6	0.14	ND	80.5
18	木	19.0	16.4	2.8	7.4	30.8	33.2	50.4	11.8	0.15	ND	87.5
19	金	20.6	16.2	2.7	7.5	32.7	33.6	52.8	11.5	0.15	ND	89.7
20	土	16.3	16.0	2.1	7.7	35.0	32.8	54.8	9.4	0.12	ND	91.4
21	日	17.6	15.5	2.0	7.7	36.5	34.0	53.2	9.6	0.16	ND	91.1
22	月	17.5	15.4	2.7	7.6	36.4	35.6	47.6	9.2	0.18	ND	90.7
23	火	19.2	15.4	2.0	7.6	32.6	35.6	53.2	9.2	0.13	ND	90.7
24	水	18.9	15.5	1.9	7.6	31.8	41.8	51.6	9.5	0.11	ND	91.8
25	木	21.5	15.6	1.5	7.5	31.1	32.8	53.6	9.7	0.11	ND	92.8
26	金	19.4	15.1	1.3	7.6	33.0	34.0	48.8	11.5	0.09	ND	90.0
27	土	16.9	16.0	0.9	7.6	31.9	34.6	43.2	9.8	0.08	ND	88.8
28	日	13.1	15.1	1.0	7.6	30.5	32.0	44.0	9.4	0.08	ND	84.0
29	月	12.8	14.6	1.2	7.6	27.4	29.7	43.2	9.6	0.09	ND	77.6
30	火	13.9	14.4	2.2	7.4	24.7	26.3	42.0	8.9	0.10	ND	70.8
31	水	12.5	14.0	1.9	7.4	24.7	26.9	41.2	10.0	0.10	ND	74.9
最大値		28.0	19.8	3.2	7.7	36.5	41.8	54.8	11.8	0.18	ND	92.8
最小値		12.5	14.0	0.9	6.6	17.1	20.1	30.0	7.9	0.03	ND	55.6
平均値		19.3	16.5	2.1	7.4	28.5	29.8	45.7	9.3	0.10	ND	78.8

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所