

水質試験結果表(取水分)

2019年6月

| 項目 | | 気温 [°C] | 水温 [°C] | 濁度 [度] | pH [-logH] | 酸消費量 [mg/L] | 全硬度 [mg/L] | 全蒸発残留物 [mg/L] | 塩化物イオン [mg/L] | 鉄 [mg/L] | マンガン [mg/L] | 電気伝導度 [μ S/cm] |
|-----|----|------------|------------|-----------|---------------|----------------|---------------|------------------|------------------|-------------|----------------|-------------------|
| 日付 | 曜日 | | | | | | | | | | | |
| 1 | 土 | 23.5 | 17.0 | 1.2 | 6.9 | 28.3 | 31.6 | 49.2 | 6.7 | 0.12 | ND | 85.3 |
| 2 | 日 | 22.0 | 18.6 | 1.5 | 6.9 | 29.8 | 31.8 | 45.6 | 6.9 | 0.17 | ND | 88.8 |
| 3 | 月 | 25.9 | 18.3 | 2.9 | 6.9 | 29.6 | 31.4 | 59.6 | 6.6 | 0.28 | ND | 85.6 |
| 4 | 火 | 26.7 | 19.0 | 2.7 | 6.8 | 27.6 | 28.1 | 48.0 | 6.1 | 0.22 | 0.01 | 78.7 |
| 5 | 水 | 26.5 | 19.5 | 2.4 | 6.8 | 26.2 | 26.9 | 53.2 | 7.1 | 0.21 | ND | 75.7 |
| 6 | 木 | 28.0 | 19.3 | 2.9 | 6.9 | 25.9 | 27.1 | 50.0 | 5.7 | 0.31 | 0.01 | 73.5 |
| 7 | 金 | 20.3 | 19.0 | 2.9 | 6.8 | 25.9 | 27.1 | 44.0 | 5.3 | 0.22 | 0.01 | 73.5 |
| 8 | 土 | 19.9 | 18.0 | 1.8 | 6.8 | 24.7 | 26.7 | 43.2 | 6.4 | 0.16 | ND | 75.0 |
| 9 | 日 | 21.2 | 18.1 | 1.8 | 6.9 | 26.6 | 28.7 | 42.0 | 6.7 | 0.18 | ND | 80.0 |
| 10 | 月 | 21.3 | 18.0 | 2.1 | 6.8 | 28.4 | 31.2 | 52.4 | 6.3 | 0.22 | ND | 83.3 |
| 11 | 火 | 24.9 | 17.7 | 3.3 | 6.9 | 26.7 | 28.3 | 50.0 | 5.5 | 0.24 | ND | 77.8 |
| 12 | 水 | 20.5 | 18.2 | 3.0 | 6.8 | 26.7 | 29.1 | 56.8 | 5.9 | 0.26 | 0.01 | 76.5 |
| 13 | 木 | 23.0 | 17.8 | 3.3 | 6.9 | 26.6 | 28.7 | 54.4 | 5.7 | 0.26 | 0.01 | 75.5 |
| 14 | 金 | 27.3 | 18.7 | 2.7 | 6.9 | 26.0 | 28.5 | 50.4 | 5.6 | 0.23 | 0.01 | 74.8 |
| 15 | 土 | 22.6 | 18.7 | 1.5 | 6.9 | 27.6 | 28.3 | 52.4 | 6.0 | 0.14 | ND | 81.0 |
| 16 | 日 | 19.7 | 18.3 | 2.5 | 7.0 | 26.3 | 27.1 | 48.8 | 5.2 | 0.19 | ND | 75.9 |
| 17 | 月 | 21.8 | 16.0 | 8.2 | 6.7 | 17.3 | 21.9 | 46.8 | 3.9 | 0.39 | 0.02 | 55.0 |
| 18 | 火 | 24.2 | 16.2 | 4.4 | 6.9 | 21.3 | 22.7 | 45.2 | 5.6 | 0.24 | 0.01 | 63.6 |
| 19 | 水 | 23.7 | 16.3 | 4.0 | 6.9 | 24.6 | 26.7 | 47.2 | 5.7 | 0.24 | ND | 70.7 |
| 20 | 木 | 27.9 | 18.0 | 3.2 | 6.9 | 26.5 | 27.5 | 54.0 | 5.3 | 0.25 | 0.01 | 74.3 |
| 21 | 金 | 24.6 | 19.1 | 3.3 | 6.9 | 27.4 | 28.3 | 55.6 | 5.6 | 0.25 | 0.01 | 78.0 |
| 22 | 土 | 22.3 | 19.5 | 1.7 | 6.9 | 27.0 | 29.3 | 49.2 | 5.4 | 0.15 | ND | 81.4 |
| 23 | 日 | 23.7 | 19.1 | 1.8 | 6.9 | 27.8 | 30.4 | 44.8 | 5.7 | 0.18 | ND | 82.7 |
| 24 | 月 | 25.3 | 19.0 | 2.8 | 6.8 | 27.3 | 30.8 | 50.4 | 5.1 | 0.26 | ND | 79.5 |
| 25 | 火 | 27.9 | 19.0 | 2.8 | 6.9 | 27.5 | 29.3 | 51.2 | 6.1 | 0.26 | 0.01 | 79.9 |
| 26 | 水 | 28.5 | 20.0 | 2.5 | 6.8 | 29.1 | 30.4 | 52.8 | 6.0 | 0.25 | ND | 82.8 |
| 27 | 木 | 27.2 | 20.9 | 2.6 | 6.8 | 29.8 | 32.6 | 60.0 | 6.4 | 0.24 | ND | 86.1 |
| 28 | 金 | 23.5 | 20.2 | 3.7 | 6.9 | 26.0 | 29.7 | 57.2 | 6.5 | 0.26 | 0.01 | 77.2 |
| 29 | 土 | 26.6 | 19.0 | 2.5 | 6.8 | 23.5 | 27.1 | 52.4 | 4.8 | 0.24 | ND | 68.2 |
| 30 | 日 | 27.2 | 19.0 | 2.2 | 6.9 | 23.5 | 24.5 | 40.8 | 4.8 | 0.16 | ND | 68.2 |
| 最大値 | | 28.5 | 20.9 | 8.2 | 7.0 | 29.8 | 32.6 | 60.0 | 7.1 | 0.39 | 0.02 | 88.8 |
| 最小値 | | 19.7 | 16.0 | 1.2 | 6.7 | 17.3 | 21.9 | 40.8 | 3.9 | 0.12 | ND | 55.0 |
| 平均値 | | 24.3 | 18.5 | 2.8 | 6.9 | 26.4 | 28.4 | 50.3 | 5.8 | 0.23 | ND | 77.0 |

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

