

水質試験結果表(取水分)

2019年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	月	25.0	18.0	18.3	6.7	19.2	20.3	62.8	4.0	0.84	0.05	54.4
2	火	26.0	18.7	5.0	6.8	22.5	24.7	44.4	5.3	0.31	0.02	64.8
3	水	27.4	19.0	3.6	6.8	25.4	28.1	45.2	5.5	0.27	0.01	71.7
4	木	26.7	19.0	3.6	6.8	25.3	27.1	54.4	5.2	0.28	0.01	76.1
5	金	24.9	19.3	3.7	6.8	25.5	26.7	51.2	6.0	0.28	0.01	72.1
6	土	26.6	19.9	1.9	6.8	26.3	27.9	52.8	5.2	0.15	ND	75.9
7	日	25.1	20.4	2.9	6.8	26.9	27.7	49.6	4.9	0.20	ND	77.2
8	月	26.5	19.9	4.0	6.8	26.7	27.9	49.6	5.2	0.38	0.01	76.8
9	火	23.6	20.0	2.6	6.7	25.7	28.9	46.4	6.5	0.23	ND	74.6
10	水	28.8	19.7	3.0	7.0	28.1	31.6	53.6	9.7	0.26	0.01	81.5
11	木	22.1	20.7	2.4	7.0	28.1	28.7	58.0	8.7	0.22	ND	79.2
12	金	24.2	19.6	4.4	7.1	24.5	26.1	51.6	7.3	0.28	ND	71.5
13	土	27.2	19.8	1.3	7.1	27.9	27.7	57.2	6.9	0.17	ND	76.8
14	日	25.1	19.4	0.8	7.1	28.4	28.9	48.4	8.5	0.12	ND	82.3
15	月	25.9	20.2	1.0	7.1	29.4	29.9	49.6	7.8	0.15	ND	82.9
16	火	24.7	20.0	5.1	7.0	30.9	30.8	64.0	8.2	0.48	0.01	84.5
17	水	28.2	20.9	2.6	7.0	29.9	31.6	55.6	7.6	0.23	ND	81.8
18	木	26.4	22.0	2.4	6.9	28.7	31.6	55.2	7.8	0.27	ND	80.2
19	金	24.9	20.6	10.5	6.9	23.2	26.3	55.6	6.7	0.53	0.04	65.6
20	土	25.0	20.0	1.8	7.1	24.9	27.1	49.2	6.4	0.14	ND	70.9
21	日	28.6	20.0	1.4	7.1	26.5	26.9	45.2	6.7	0.18	ND	75.5
22	月	26.1	21.0	3.3	6.9	28.2	28.7	50.0	6.6	0.25	ND	79.0
23	火	27.4	21.0	4.8	7.0	26.6	27.7	52.0	6.4	0.23	0.02	72.4
24	水	29.4	21.0	4.9	6.9	25.6	26.7	52.8	6.3	0.32	0.01	73.8
25	木	30.8	22.0	3.7	7.0	27.8	29.7	45.6	6.4	0.27	0.01	76.3
26	金	32.2	22.3	2.9	6.9	28.0	28.7	55.6	7.0	0.19	0.01	77.1
27	土	33.0	23.5	1.6	7.1	29.3	29.9	55.6	6.7	0.17	ND	85.7
28	日	26.2	22.4	6.2	6.9	20.4	23.1	52.0	6.3	0.35	0.01	61.6
29	月	31.3	22.2	4.3	6.9	23.9	27.3	54.4	6.3	0.28	ND	68.9
30	火	31.5	23.5	4.1	7.0	26.5	26.9	52.0	6.4	0.31	0.01	74.1
31	水	31.4	22.4	3.8	6.9	26.6	27.7	57.2	7.0	0.29	0.01	74.7
最大値		33.0	23.5	18.3	7.1	30.9	31.6	64.0	9.7	0.84	0.05	85.7
最小値		22.1	18.0	0.8	6.7	19.2	20.3	44.4	4.0	0.12	ND	54.4
平均値		27.2	20.6	3.9	6.9	26.4	27.8	52.5	6.6	0.28	0.01	74.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2019年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	25.0	18.1	1.2	6.6	15.9	20.1	38.4	6.3	0.04	ND	58.7
2	火	26.0	18.8	0.8	6.6	20.1	27.3	37.2	5.3	0.03	ND	65.5
3	水	27.4	19.2	0.7	6.8	24.9	27.5	44.4	6.1	0.04	ND	74.9
4	木	26.7	19.2	0.9	6.7	24.8	27.3	52.0	6.1	0.05	ND	73.2
5	金	24.9	19.5	0.8	6.8	24.2	26.7	54.4	6.2	0.04	ND	74.6
6	土	26.6	19.9	0.7	6.8	25.8	26.7	50.8	5.4	0.04	ND	76.4
7	日	25.1	20.6	0.8	7.0	26.8	29.5	46.4	5.4	0.08	ND	77.5
8	月	26.5	20.0	1.0	6.9	26.7	29.5	55.6	5.7	0.10	ND	76.7
9	火	23.6	20.1	0.8	6.7	26.0	27.7	48.0	6.0	0.05	ND	75.7
10	水	28.8	19.7	0.9	7.0	27.1	30.2	44.8	8.2	0.07	ND	82.1
11	木	22.1	20.9	0.8	7.0	27.1	28.9	52.0	8.7	0.07	ND	80.3
12	金	24.2	19.7	0.9	7.0	23.3	25.7	40.8	8.4	0.04	ND	73.2
13	土	27.2	19.7	0.8	7.1	26.9	28.5	49.6	6.4	0.06	ND	76.2
14	日	25.1	19.2	0.5	7.2	30.0	31.0	39.2	8.2	0.11	ND	82.9
15	月	25.9	20.4	0.5	7.2	30.8	31.4	50.8	7.7	0.12	ND	82.5
16	火	24.7	20.2	1.0	7.1	29.3	32.2	60.8	8.5	0.12	ND	84.2
17	水	28.2	21.2	0.8	7.1	28.3	30.6	56.0	7.8	0.06	ND	83.8
18	木	26.4	22.0	1.0	7.1	28.1	31.4	51.6	8.1	0.08	ND	80.9
19	金	24.9	20.9	0.9	6.7	20.1	22.7	42.0	8.7	0.04	ND	70.5
20	土	25.0	20.0	0.5	7.0	23.0	26.5	44.0	7.9	0.04	ND	72.9
21	日	28.6	20.3	0.6	7.1	27.0	26.9	38.4	7.2	0.06	ND	75.4
22	月	26.1	20.9	1.1	7.1	28.0	30.2	48.4	6.5	0.09	ND	79.0
23	火	27.4	21.0	0.7	6.9	26.0	27.7	47.2	7.6	0.05	ND	76.2
24	水	29.4	21.2	0.7	6.8	23.8	26.5	44.8	7.3	0.04	ND	75.5
25	木	30.8	22.0	0.7	6.9	26.7	28.7	44.0	7.1	0.04	ND	77.6
26	金	32.2	22.4	0.7	6.9	27.0	27.7	54.8	7.3	0.05	ND	79.0
27	土	33.0	23.5	0.6	7.1	29.1	30.8	45.6	7.6	0.05	ND	85.6
28	日	26.2	22.6	0.8	7.1	27.4	26.9	47.2	7.2	0.05	ND	77.3
29	月	31.3	22.4	0.8	6.9	21.0	24.1	48.0	7.0	0.04	ND	66.6
30	火	31.5	23.8	0.5	6.8	25.4	27.5	44.8	6.8	0.03	ND	75.2
31	水	31.4	22.7	0.5	7.0	25.5	28.7	48.0	7.3	0.03	ND	76.9
最大値		33.0	23.8	1.2	7.2	30.8	32.2	60.8	8.7	0.12	ND	85.6
最小値		22.1	18.1	0.5	6.6	15.9	20.1	37.2	5.3	0.03	ND	58.7
平均値		27.2	20.7	0.8	6.9	25.7	28.0	47.4	7.1	0.06	ND	76.4

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所