

水質試験結果表(取水分)

2019年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	火	26.2	20.1	2.1	6.9	27.8	27.7	50.0	6.6	0.17	ND	77.7
2	水	24.6	21.0	1.5	7.0	28.8	29.7	48.8	6.7	0.18	ND	82.4
3	木	26.6	20.8	1.3	7.1	31.7	31.8	56.0	8.0	0.15	ND	88.4
4	金	21.7	20.4	7.4	7.0	26.6	27.3	60.4	8.5	0.26	0.02	78.1
5	土	27.5	18.9	3.4	7.0	20.6	26.7	45.2	6.5	0.24	0.01	65.9
6	日	21.6	18.8	1.6	7.0	23.2	28.9	41.2	8.4	0.14	ND	69.0
7	月	21.5	18.4	4.1	6.9	26.6	28.1	51.2	7.3	0.41	0.01	75.7
8	火	20.6	19.0	2.3	7.0	29.4	31.6	49.2	8.6	0.23	ND	84.1
9	水	24.3	17.8	3.3	7.0	25.9	28.5	46.4	6.1	0.26	0.01	76.9
10	木	21.4	17.2	2.0	7.0	29.2	31.4	54.8	7.7	0.16	ND	84.1
11	金	25.4	18.4	2.0	7.1	31.4	32.6	60.0	8.6	0.18	ND	88.2
12	土	22.1	18.9	1.2	7.2	31.8	33.8	52.8	7.6	0.11	ND	89.0
13	日	18.5	18.4	4.3	7.0	24.5	32.0	44.8	8.2	0.30	0.01	77.7
14	月	18.7	17.6	2.0	7.1	25.8	28.3	45.2	7.3	0.15	ND	75.1
15	火	22.2	17.0	4.2	7.0	27.8	30.6	64.8	7.3	0.35	0.01	78.8
16	水	18.4	16.3	2.5	7.1	28.9	31.4	57.2	8.3	0.19	ND	81.7
17	木	20.1	16.3	2.0	6.9	29.5	32.0	54.4	8.3	0.17	ND	84.3
18	金	18.4	16.5	1.6	7.0	29.7	31.6	56.0	7.4	0.13	ND	84.8
19	土	20.4	16.8	2.4	7.2	28.4	30.2	48.4	5.9	0.12	ND	81.4
20	日	23.7	17.5	13.8	7.1	22.1	25.7	44.4	5.1	0.40	0.03	69.4
21	月	16.4	16.8	9.5	7.0	24.3	25.7	52.4	6.0	0.34	0.01	72.5
22	火	26.4	16.3	1.3	7.1	27.3	28.9	41.2	6.9	0.17	ND	78.9
23	水	20.2	17.7	2.1	7.0	27.9	27.7	49.6	6.3	0.11	ND	78.7
24	木	18.3	17.0	2.2	7.0	28.3	30.2	49.6	5.5	0.20	ND	82.7
25	金	17.4	17.0	2.7	7.3	27.8	28.7	49.2	6.8	0.21	ND	81.4
26	土	17.3	16.0	3.8	7.0	24.2	27.1	55.2	5.7	0.24	0.01	70.8
27	日	17.5	16.1	1.4	7.0	24.3	25.1	43.2	6.0	0.12	ND	70.1
28	月	17.7	15.7	3.0	7.0	25.4	25.9	50.8	6.8	0.26	ND	73.1
29	火	15.8	15.3	2.4	7.0	26.3	27.9	48.0	6.8	0.20	ND	74.3
30	水	16.2	15.1	2.4	7.0	26.3	28.3	52.0	8.0	0.19	ND	76.1
31	木	18.4	15.1	2.2	7.0	27.6	28.1	44.0	6.2	0.16	ND	75.7
最大値		27.5	21.0	13.8	7.3	31.8	33.8	64.8	8.6	0.41	0.03	89.0
最小値		15.8	15.1	1.2	6.9	20.6	25.1	41.2	5.1	0.11	ND	65.9
平均値		20.8	17.6	3.2	7.0	27.1	29.1	50.5	7.1	0.21	ND	78.3

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2019年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	火	26.2	20.5	0.9	6.9	27.5	31.8	45.6	8.0	0.08	ND	78.9
2	水	24.6	21.1	0.8	7.0	28.7	31.2	45.6	6.5	0.09	ND	82.8
3	木	26.6	21.0	0.7	7.0	31.4	33.2	52.0	8.6	0.08	ND	89.5
4	金	21.7	20.8	1.0	6.9	22.6	28.7	42.4	9.6	0.05	ND	82.2
5	土	27.5	19.0	2.3	6.8	18.6	26.1	45.2	8.9	0.11	ND	71.2
6	日	21.6	18.9	1.3	6.9	22.6	27.5	40.0	8.4	0.08	ND	68.8
7	月	21.5	19.0	1.5	7.0	26.3	28.7	43.6	6.4	0.11	ND	73.8
8	火	20.6	19.2	0.9	6.9	28.4	31.4	45.6	8.3	0.07	ND	84.0
9	水	24.3	18.0	2.0	6.9	25.3	28.9	41.6	6.8	0.03	ND	78.3
10	木	21.4	17.4	1.2	6.9	28.4	31.6	58.0	8.5	0.08	ND	84.9
11	金	25.4	18.3	1.1	7.0	30.3	32.0	44.0	9.0	0.08	ND	88.7
12	土	22.1	19.0	1.1	7.2	31.1	35.6	50.4	8.4	0.07	ND	90.0
13	日	18.5	18.4	0.7	7.0	25.5	31.6	38.4	9.3	0.03	ND	82.5
14	月	18.7	17.8	1.3	7.0	22.3	26.3	41.6	8.7	0.07	ND	73.8
15	火	22.2	17.0	1.6	7.0	28.0	31.6	44.0	7.6	0.10	ND	79.6
16	水	18.4	16.7	1.3	7.0	28.7	31.6	48.0	8.2	0.07	ND	82.8
17	木	20.1	16.5	1.3	6.9	29.4	31.0	56.4	8.6	0.08	ND	86.0
18	金	18.4	16.7	1.3	7.1	29.3	33.0	58.4	8.3	0.09	ND	85.6
19	土	20.4	16.8	1.8	7.2	27.7	28.7	44.0	6.1	0.07	ND	82.8
20	日	23.7	17.5	1.6	6.9	20.2	27.9	35.2	6.2	0.04	ND	72.4
21	月	16.4	17.0	3.5	6.9	23.8	27.1	37.6	5.9	0.11	ND	73.3
22	火	26.4	16.3	0.9	7.1	26.9	26.3	43.2	7.9	0.11	ND	80.9
23	水	20.2	17.9	1.6	6.9	26.9	28.7	44.8	7.9	0.07	ND	79.0
24	木	18.3	17.0	1.3	7.0	28.2	29.7	46.0	5.7	0.09	ND	83.5
25	金	17.4	17.0	1.4	7.1	28.2	30.2	48.0	7.3	0.10	ND	82.8
26	土	17.3	16.2	0.9	6.8	22.7	26.1	43.2	7.2	0.04	ND	74.6
27	日	17.5	16.2	1.3	7.0	24.0	25.1	36.0	6.4	0.09	ND	69.0
28	月	17.7	16.0	1.7	6.9	24.5	26.5	44.4	6.7	0.13	ND	72.8
29	火	15.8	15.5	1.2	6.9	25.7	27.9	43.2	7.9	0.09	ND	75.2
30	水	16.2	15.1	1.2	7.0	26.0	27.5	49.2	7.3	0.11	ND	76.8
31	木	18.4	15.3	1.2	7.0	26.5	27.7	37.6	7.0	0.09	ND	77.5
最大値		27.5	21.1	3.5	7.2	31.4	35.6	58.4	9.6	0.13	ND	90.0
最小値		15.8	15.1	0.7	6.8	18.6	25.1	35.2	5.7	0.03	ND	68.8
平均値		20.8	17.7	1.4	7.0	26.3	29.4	44.9	7.7	0.08	ND	79.5

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所