

水質試験結果表(取水分)

2020年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	金	21.0	13.6	4.5	7.1	26.3	28.7	51.6	10.6	0.30	0.01	76.5
2	土	24.9	14.1	1.8	7.2	26.7	28.9	45.2	7.6	0.16	ND	78.0
3	日	23.5	15.6	2.5	7.1	27.4	30.4	45.6	10.1	0.24	ND	80.3
4	月	24.6	16.0	2.9	7.1	27.3	30.6	48.0	9.9	0.28	ND	79.9
5	火	17.6	16.2	2.8	7.2	27.0	29.9	51.2	10.3	0.27	ND	80.0
6	水	17.6	15.6	3.4	7.2	27.5	29.5	52.0	10.5	0.30	ND	80.1
7	木	21.7	14.5	6.7	7.2	26.1	29.1	45.2	9.9	0.38	0.01	77.3
8	金	20.8	14.9	4.4	7.0	27.4	31.0	52.0	9.2	0.29	0.01	80.6
9	土	19.2	15.7	2.3	7.2	28.1	30.6	56.4	8.4	0.18	ND	88.1
10	日	20.0	14.8	4.1	7.2	27.7	28.9	51.6	8.9	0.27	0.01	80.4
11	月	19.4	14.5	8.8	7.1	23.3	28.1	48.4	7.4	0.40	0.03	69.7
12	火	24.0	15.3	5.8	7.2	24.1	27.7	42.8	6.8	0.32	0.01	70.6
13	水	23.2	15.6	5.8	7.1	27.2	29.5	50.4	8.8	0.38	0.01	77.5
14	木	20.7	15.0	5.0	7.2	27.7	30.6	58.0	8.9	0.34	0.01	80.6
15	金	23.6	15.6	3.7	7.1	29.1	31.2	52.0	10.3	0.26	0.01	82.1
16	土	17.4	15.4	2.9	7.2	28.7	28.9	56.0	8.4	0.20	ND	81.9
17	日	19.2	15.2	5.2	7.1	25.2	30.2	41.2	9.4	0.29	0.01	73.9
18	月	20.1	15.5	5.2	7.0	27.6	29.7	52.4	8.7	0.36	0.01	78.8
19	火	20.1	16.7	6.8	7.2	26.1	28.3	47.2	8.5	0.36	0.02	78.3
20	水	19.1	16.0	7.5	7.1	25.4	30.6	52.4	7.4	0.38	0.02	73.8
21	木	15.5	15.0	5.5	7.0	27.7	29.1	51.6	8.2	0.36	0.01	78.0
22	金	23.2	14.4	4.7	7.0	26.7	29.3	56.4	8.3	0.12	0.01	78.2
23	土	19.2	16.2	2.3	7.1	27.8	29.1	50.8	8.2	0.20	ND	78.9
24	日	26.0	17.4	2.2	7.1	28.9	30.6	48.4	8.4	0.21	ND	80.2
25	月	23.7	18.2	7.1	7.1	28.3	31.2	61.2	8.8	0.58	0.02	79.8
26	火	22.3	18.0	3.3	7.0	27.7	30.4	48.8	8.9	0.14	0.01	78.4
27	水	22.6	17.0	8.3	6.9	26.0	28.5	43.6	9.2	0.43	0.02	74.6
28	木	21.2	17.0	4.5	7.0	27.5	31.2	48.8	9.5	0.33	0.01	77.6
29	金	22.1	17.0	3.8	7.0	27.5	30.2	42.0	6.9	0.33	0.01	78.4
30	土	23.4	17.3	1.9	7.1	29.4	29.7	56.0	8.4	0.20	ND	84.4
31	日	22.9	18.3	1.8	7.1	30.9	30.6	55.2	8.9	0.23	ND	86.1
最大値		26.0	18.3	8.8	7.2	30.9	31.2	61.2	10.6	0.58	0.03	88.1
最小値		15.5	13.6	1.8	6.9	23.3	27.7	41.2	6.8	0.12	ND	69.7
平均値		21.3	15.9	4.4	7.1	27.2	29.8	50.4	8.8	0.29	0.01	78.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2020年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	金	21.0	13.8	0.5	7.0	25.3	27.5	47.6	11.3	0.03	ND	78.3
2	土	24.9	14.3	0.8	7.2	24.5	29.9	42.4	9.7	0.01	ND	79.1
3	日	23.5	15.8	0.5	7.2	25.2	30.4	40.0	9.6	0.01	ND	81.0
4	月	24.6	16.2	0.3	7.2	25.6	30.4	40.4	11.2	0.02	ND	81.4
5	火	17.6	15.8	0.3	7.1	25.2	29.5	45.6	11.4	0.02	ND	81.2
6	水	17.6	16.0	0.3	7.0	24.6	29.3	42.0	10.0	0.02	ND	80.6
7	木	21.7	15.0	0.4	7.0	23.9	32.2	37.2	10.5	0.02	ND	79.9
8	金	20.8	15.3	0.7	7.1	26.0	29.3	44.4	9.2	0.04	ND	80.6
9	土	19.2	16.0	0.6	7.3	27.8	31.0	46.4	9.5	0.03	ND	85.5
10	日	20.0	15.0	0.7	7.2	27.9	29.5	41.6	9.3	0.03	ND	84.0
11	月	19.4	14.9	0.8	7.0	23.2	28.5	42.8	8.2	0.03	ND	75.4
12	火	24.0	15.5	0.9	6.9	21.7	27.7	42.8	8.6	0.04	ND	71.3
13	水	23.2	15.9	0.8	7.0	25.2	27.1	42.0	9.2	0.04	ND	79.0
14	木	20.7	15.7	1.0	7.0	26.5	29.1	42.4	11.5	0.05	ND	82.5
15	金	23.6	16.0	0.8	7.0	27.1	29.5	43.2	11.1	0.04	ND	83.8
16	土	17.4	15.5	0.7	7.1	28.2	31.2	46.0	10.6	0.03	ND	84.6
17	日	19.2	15.3	0.6	7.1	26.0	28.3	41.6	9.6	0.03	ND	79.1
18	月	20.1	15.4	0.8	7.1	25.8	31.6	42.4	10.2	0.04	ND	79.9
19	火	20.1	16.9	0.9	7.1	25.7	31.6	40.8	9.5	0.04	ND	79.6
20	水	19.1	16.3	1.0	7.0	24.5	29.9	39.2	8.6	0.05	ND	76.2
21	木	15.5	15.0	1.0	7.0	25.5	29.1	48.4	9.6	0.05	ND	79.9
22	金	23.2	14.6	1.0	7.0	25.9	30.8	39.6	9.8	0.03	ND	79.7
23	土	19.2	16.5	0.6	7.1	27.7	28.3	43.2	9.3	0.03	ND	80.2
24	日	26.0	17.6	0.7	7.2	29.1	28.7	38.4	9.0	0.07	ND	80.8
25	月	23.7	18.7	0.8	7.1	27.8	30.8	50.0	9.3	0.08	ND	81.0
26	火	22.3	18.1	0.8	7.0	27.3	29.7	41.2	10.6	0.05	ND	80.4
27	水	22.6	17.2	1.4	7.0	25.3	28.5	40.8	9.4	0.05	ND	78.1
28	木	21.2	17.2	1.0	7.0	26.5	29.3	43.2	11.1	0.06	ND	78.9
29	金	22.1	17.4	1.0	6.9	26.9	30.6	34.8	7.7	0.06	ND	80.5
30	土	23.4	17.8	0.8	7.2	29.3	30.6	49.2	8.3	0.06	ND	84.6
31	日	22.9	18.0	1.0	7.2	33.6	31.2	52.8	8.3	0.13	ND	86.0
最大値		26.0	18.7	1.4	7.3	33.6	32.2	52.8	11.5	0.13	ND	86.0
最小値		15.5	13.8	0.3	6.9	21.7	27.1	34.8	7.7	0.01	ND	71.3
平均値		21.3	16.1	0.7	7.1	26.3	29.7	43.0	9.7	0.04	ND	80.4

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所