

水質試験結果表(取水分)

2020年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	水	28.4	19.9	6.2	6.9	25.5	26.3	57.6	9.8	0.38	0.02	71.5
2	木	21.0	19.0	8.7	6.8	22.2	24.9	48.0	9.3	0.48	0.03	64.4
3	金	23.2	18.4	8.3	7.0	24.3	25.5	50.8	7.8	0.29	0.01	67.5
4	土	22.0	18.7	2.7	7.0	25.2	28.3	46.4	8.3	0.16	0.01	70.8
5	日	23.2	18.5	10.1	7.0	20.3	25.3	54.4	7.6	0.21	0.04	59.2
6	月	23.7	18.3	5.7	6.9	23.4	23.9	52.8	9.6	0.19	0.02	66.2
7	火	25.9	18.0	36.8	7.0	26.4	27.1	88.0	7.4	1.51	0.20	69.9
8	水	23.1	19.4	20.0	6.7	23.5	27.7	78.0	12.2	0.89	0.07	86.7
9	木	26.6	19.3	36.5	6.8	22.3	25.5	108.8	15.6	0.84	0.14	89.6
10	金	24.2	19.0	16.6	6.8	22.8	25.5	96.0	13.8	0.56	0.06	86.1
11	土	25.8	19.3	9.7	7.0	22.1	25.9	54.4	13.5	0.25	0.05	83.8
12	日	22.2	19.8	15.0	6.9	22.2	23.9	71.6	13.0	0.51	0.07	80.9
13	月	22.2	18.7	13.7	6.7	23.4	24.7	74.8	14.4	0.76	0.05	84.4
14	火	25.0	19.2	31.1	6.8	20.5	22.3	74.8	9.7	0.88	0.12	73.1
15	水	22.5	18.7	22.9	6.7	22.7	24.9	85.2	13.1	0.58	0.09	84.9
16	木	26.5	18.3	57.6	6.8	19.7	21.7	142.0	12.3	0.84	0.26	74.7
17	金	25.3	18.7	32.1	6.7	22.4	25.5	98.8	15.4	1.52	0.16	95.3
18	土	25.8	18.8	9.0	6.9	23.4	25.1	76.0	14.9	0.53	0.02	93.0
19	日	28.9	19.4	7.9	6.8	23.6	26.9	64.4	13.7	0.56	0.03	91.5
20	月	30.0	21.0	8.9	6.7	26.0	30.4	64.4	16.0	0.55	0.04	96.6
21	火	29.1	21.4	8.2	6.9	26.7	32.2	68.4	16.1	0.47	0.02	101.2
22	水	29.9	21.3	7.0	6.8	28.6	32.0	78.8	16.6	0.32	0.02	109.1
23	木	23.6	20.0	2.1	7.3	23.1	26.9	50.4	7.4	0.09	ND	68.8
24	金	23.5	19.0	1.6	7.1	24.5	27.3	43.2	8.5	0.02	ND	70.8
25	土	24.9	19.5	2.0	7.0	25.4	26.3	44.8	7.1	0.04	ND	71.8
26	日	27.1	19.8	3.7	7.1	24.5	27.1	49.2	8.5	0.07	ND	69.9
27	月	27.9	19.3	9.8	6.9	19.2	20.1	44.0	7.4	0.32	0.02	54.0
28	火	28.6	19.6	6.4	6.8	19.8	20.1	44.4	7.8	0.19	0.02	54.7
29	水	25.7	20.8	23.2	6.9	23.0	24.1	80.0	11.1	0.94	0.09	75.4
30	木	27.3	20.7	9.0	6.7	26.6	28.9	72.4	12.6	0.27	0.03	90.4
31	金	30.1	21.4	6.1	6.9	27.8	30.6	69.2	14.8	0.40	0.02	97.3
最大値		30.1	21.4	57.6	7.3	28.6	32.2	142.0	16.6	1.52	0.26	109.1
最小値		21.0	18.0	1.6	6.7	19.2	20.1	43.2	7.1	0.02	ND	54.0
平均値		25.6	19.5	14.1	6.9	23.6	26.0	68.8	11.5	0.50	0.06	79.1

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2020年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	水	28.4	20.2	1.0	6.9	23.9	27.3	42.0	10.9	0.04	ND	75.2
2	木	21.0	19.8	1.1	6.7	20.1	24.7	41.2	10.9	0.02	ND	65.5
3	金	23.2	19.0	1.0	6.8	21.5	24.9	40.4	9.2	0.05	ND	68.7
4	土	22.0	19.0	0.6	7.0	24.4	26.1	41.2	9.0	0.01	ND	71.9
5	日	23.2	18.7	0.8	6.9	21.1	27.5	36.8	10.7	0.03	ND	64.7
6	月	23.7	19.0	0.5	6.8	21.1	21.1	40.8	11.1	0.01	ND	66.8
7	火	25.9	18.5	1.2	6.7	20.0	24.9	40.4	9.2	0.04	ND	67.0
8	水	23.1	19.3	0.9	6.6	22.5	26.1	52.0	15.4	0.04	ND	94.6
9	木	26.6	19.6	1.4	6.6	20.1	24.6	57.6	18.2	0.05	ND	95.1
10	金	24.2	19.0	1.1	6.8	23.1	26.3	67.2	17.3	0.03	ND	98.6
11	土	25.8	19.5	0.6	6.9	22.6	27.1	64.0	15.7	0.01	ND	96.6
12	日	22.2	20.0	0.9	6.9	20.9	24.1	54.8	15.4	0.02	ND	87.8
13	月	22.2	19.1	0.8	6.7	23.2	27.7	66.0	17.2	0.02	ND	97.2
14	火	25.0	19.0	1.0	6.7	21.2	23.9	50.8	14.5	0.05	ND	87.1
15	水	22.5	18.6	1.7	6.6	20.7	23.9	57.6	14.9	0.01	ND	87.2
16	木	26.5	18.5	1.7	6.6	18.0	20.9	47.2	15.2	0.03	ND	81.9
17	金	25.3	19.0	0.9	6.6	21.0	23.7	54.0	19.0	0.04	ND	101.7
18	土	25.8	19.0	0.8	6.8	22.1	26.1	60.4	16.7	0.02	ND	102.5
19	日	28.9	19.6	0.5	6.8	22.5	26.5	48.0	18.0	0.01	ND	100.2
20	月	30.0	21.0	0.6	6.7	23.7	30.4	60.8	18.1	0.02	ND	102.3
21	火	29.1	21.5	0.7	6.7	26.2	29.3	57.2	17.4	0.03	ND	103.4
22	水	29.9	21.4	0.6	6.7	27.3	31.0	68.8	18.4	0.03	ND	109.1
23	木	23.6	20.3	0.6	7.0	22.5	24.7	45.6	8.6	0.01	ND	70.4
24	金	23.5	19.0	0.6	7.1	22.4	26.3	42.0	9.2	0.02	ND	71.5
25	土	24.9	19.5	0.6	6.9	23.6	27.3	48.4	8.3	0.02	ND	72.7
26	日	27.1	20.0	0.6	7.1	23.4	25.9	40.0	8.9	0.01	ND	72.1
27	月	27.9	19.7	0.8	6.9	20.2	22.9	34.0	8.9	0.01	ND	63.3
28	火	28.6	19.5	1.0	6.7	18.5	20.9	36.0	9.0	0.03	ND	56.4
29	水	25.7	20.9	0.8	6.7	22.3	24.1	52.0	14.2	0.03	ND	85.6
30	木	27.3	20.9	1.0	6.8	25.2	26.9	56.8	13.1	0.04	ND	91.4
31	金	30.1	21.6	0.6	6.8	27.6	30.2	62.0	15.2	0.02	ND	100.5
最大値		30.1	21.6	1.7	7.1	27.6	31.0	68.8	19.0	0.05	ND	109.1
最小値		21.0	18.5	0.5	6.6	18.0	20.9	34.0	8.3	0.01	ND	56.4
平均値		25.6	19.7	0.9	6.8	22.4	25.7	50.5	13.5	0.03	ND	84.2

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所