

水質試験結果表(取水分)

2020年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	29.0	21.8	2.9	7.1	32.5	32.2	57.2	13.8	0.14	0.01	106.0
2	日	28.8	22.5	3.3	6.9	31.1	32.8	63.2	14.9	0.13	0.01	107.9
3	月	30.1	22.6	5.3	6.9	30.9	31.2	56.0	14.6	0.39	0.02	106.7
4	火	31.0	21.2	4.3	6.9	26.5	27.1	44.8	7.0	0.31	0.01	69.7
5	水	31.0	21.2	3.2	6.9	24.7	25.9	48.4	9.0	0.27	0.02	67.8
6	木	31.4	21.9	2.2	6.8	25.6	25.5	51.2	7.8	0.20	ND	68.7
7	金	28.2	22.4	2.1	7.0	25.6	24.7	45.6	8.2	0.20	ND	68.0
8	土	28.2	21.6	1.6	7.0	23.2	28.7	33.2	6.8	0.13	ND	69.0
9	日	32.2	21.8	0.8	6.9	27.6	30.8	43.6	8.3	0.14	ND	79.9
10	月	34.0	23.0	0.8	6.9	28.8	31.0	45.6	6.9	0.16	ND	82.8
11	火	32.7	24.3	1.1	6.9	30.2	32.8	32.0	6.8	0.18	ND	83.2
12	水	29.9	24.6	8.3	6.9	25.7	28.1	51.2	8.1	0.37	0.02	73.5
13	木	26.1	23.3	4.1	6.9	22.8	25.1	47.2	8.5	0.23	0.01	67.9
14	金	31.6	21.9	10.4	7.0	33.0	34.6	77.6	10.0	0.38	0.03	104.3
15	土	28.3	23.0	1.3	7.0	25.9	28.1	49.2	7.3	0.31	ND	74.9
16	日	30.2	22.5	1.2	7.0	27.4	28.3	36.0	6.7	0.13	ND	77.4
17	月	32.5	23.3	3.7	6.9	28.9	29.1	60.0	9.2	0.06	ND	79.7
18	火	30.8	23.2	3.0	6.9	27.5	29.9	57.6	7.3	0.27	0.01	76.1
19	水	30.4	23.0	3.2	6.8	27.4	27.7	52.8	8.7	0.29	0.01	74.9
20	木	33.0	23.4	3.3	6.9	26.4	29.1	53.2	8.6	0.27	0.01	73.3
21	金	34.5	23.4	3.5	7.0	26.6	27.1	45.6	8.0	0.33	0.01	73.0
22	土	32.8	24.0	0.8	7.1	27.9	26.5	45.6	7.7	0.24	ND	76.2
23	日	30.1	24.5	1.0	7.2	30.6	29.5	52.8	7.4	0.15	ND	84.7
24	月	31.1	24.3	2.0	6.9	30.7	30.6	62.8	7.9	0.24	ND	83.4
25	火	32.5	24.0	2.0	7.0	28.8	29.7	52.4	6.8	0.21	0.01	78.9
26	水	33.5	24.0	2.1	7.0	29.6	30.6	57.2	8.7	0.20	ND	78.2
27	木	32.2	24.0	2.1	6.9	27.8	29.5	49.6	6.6	0.22	0.01	77.5
28	金	28.8	23.9	2.2	6.8	27.1	27.9	50.4	8.2	0.22	ND	74.0
29	土	32.6	23.7	0.9	7.0	26.9	28.1	58.0	8.0	0.11	ND	77.2
30	日	35.2	25.0	0.9	7.1	28.8	28.9	50.0	5.9	0.15	ND	81.6
31	月	34.2	25.0	2.8	6.8	29.9	30.4	58.4	6.9	0.32	ND	81.0
最大値		35.2	25.0	10.4	7.2	33.0	34.6	77.6	14.9	0.39	0.03	107.9
最小値		26.1	21.2	0.8	6.8	22.8	24.7	32.0	5.9	0.06	ND	67.8
平均値		31.2	23.2	2.8	6.9	27.9	29.1	51.2	8.4	0.22	0.01	79.9

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2020年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	29.0	21.8	0.5	7.0	30.2	31.4	52.0	16.0	0.01	ND	107.5
2	日	28.8	22.5	0.5	6.9	36.0	32.0	54.8	16.7	0.03	ND	111.0
3	月	30.1	22.8	0.6	6.9	29.4	32.8	58.8	17.8	0.02	ND	113.1
4	火	31.0	21.4	0.7	6.9	25.5	25.7	38.0	9.3	0.04	ND	70.7
5	水	31.0	21.6	0.9	7.0	23.7	25.7	47.2	9.4	0.05	ND	68.9
6	木	31.4	22.1	0.9	7.0	24.5	25.5	44.8	8.7	0.07	ND	69.5
7	金	28.2	22.5	1.0	7.0	25.1	24.3	42.4	8.5	0.08	ND	68.5
8	土	28.2	21.4	0.9	7.2	22.9	30.6	30.0	8.4	0.04	ND	70.1
9	日	32.2	21.7	0.6	7.3	27.5	29.5	34.0	7.4	0.12	ND	78.6
10	月	34.0	23.0	0.6	7.1	28.6	29.1	37.6	7.7	0.14	ND	81.0
11	火	32.7	24.5	0.7	6.9	29.5	31.0	30.8	7.6	0.14	ND	81.9
12	水	29.9	25.3	1.0	7.0	27.5	29.1	52.8	9.4	0.12	ND	79.7
13	木	26.1	23.5	1.5	6.7	22.8	23.9	51.6	9.6	0.08	ND	70.1
14	金	31.6	22.1	1.1	6.8	30.1	32.4	62.8	10.3	0.05	ND	94.3
15	土	28.3	22.7	0.7	7.0	24.7	25.9	45.6	8.0	0.07	ND	76.2
16	日	30.2	22.3	0.8	7.0	27.2	28.5	46.0	8.4	0.08	ND	78.0
17	月	32.5	23.1	0.9	7.0	27.5	31.8	56.0	8.9	0.04	ND	79.9
18	火	30.8	23.4	0.5	6.7	26.2	28.9	45.2	7.7	0.03	ND	76.9
19	水	30.4	23.3	0.5	6.8	26.2	28.9	44.0	10.3	0.05	ND	76.1
20	木	33.0	23.7	0.7	6.9	25.5	28.5	50.8	10.6	0.05	ND	74.1
21	金	34.5	23.7	1.0	7.0	25.7	26.5	45.6	8.6	0.07	ND	74.0
22	土	32.8	24.3	0.6	7.2	27.2	27.1	43.6	6.9	0.07	ND	76.4
23	日	30.1	24.8	0.6	7.2	30.2	30.4	40.0	8.4	0.09	ND	83.3
24	月	31.1	24.7	0.7	7.1	30.9	31.6	42.4	8.0	0.11	ND	83.1
25	火	32.5	24.2	0.7	7.0	29.0	30.4	59.2	8.5	0.06	ND	80.7
26	水	33.5	24.4	0.8	6.9	28.6	29.3	52.0	9.2	0.05	ND	80.8
27	木	32.2	24.1	1.0	7.0	26.5	27.1	52.0	7.7	0.07	ND	77.0
28	金	28.8	24.1	1.0	6.9	25.9	25.7	48.0	8.1	0.07	ND	74.5
29	土	32.6	23.9	0.6	7.1	25.9	29.3	50.0	7.7	0.05	ND	76.2
30	日	35.2	25.3	0.4	7.1	28.0	27.3	44.0	7.4	0.08	ND	81.6
31	月	34.2	25.5	0.6	7.0	29.7	30.4	52.8	7.3	0.11	ND	80.6
最大値		35.2	25.5	1.5	7.3	36.0	32.8	62.8	17.8	0.14	ND	113.1
最小値		26.1	21.4	0.4	6.7	22.8	23.9	30.0	6.9	0.01	ND	68.5
平均値		31.2	23.3	0.8	7.0	27.4	28.7	46.9	9.3	0.07	ND	80.5

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所