

水質試験結果表(取水分)

2020年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	23.0	19.0	2.2	7.0	28.9	30.2	52.0	8.2	0.21	ND	79.3
2	金	22.4	18.7	2.1	6.8	28.1	28.7	54.8	8.4	0.18	ND	78.3
3	土	21.2	18.8	0.9	7.0	27.8	28.5	47.6	8.9	0.12	ND	80.0
4	日	21.2	18.5	0.9	7.0	30.5	29.9	48.4	10.1	0.12	ND	85.9
5	月	19.1	18.8	2.8	6.9	30.2	30.8	50.4	9.7	0.29	0.01	84.0
6	火	16.7	17.3	2.1	6.9	29.4	30.8	52.8	8.8	0.18	ND	81.6
7	水	22.2	17.2	1.8	6.9	29.1	29.7	54.0	8.6	0.18	ND	81.8
8	木	16.9	17.8	1.8	6.9	29.0	30.6	50.4	9.4	0.17	ND	82.4
9	金	16.3	16.8	1.7	6.9	27.1	27.7	48.4	8.3	0.16	ND	78.4
10	土	20.1	16.9	1.3	7.1	27.3	28.9	48.4	9.0	0.14	ND	79.0
11	日	23.5	18.0	1.2	6.9	28.3	28.5	47.2	9.3	0.14	ND	81.6
12	月	25.1	18.4	2.9	6.9	30.4	31.0	56.4	8.5	0.15	ND	84.5
13	火	24.1	18.7	2.0	7.0	28.6	28.9	54.4	8.7	0.19	ND	80.6
14	水	21.7	18.1	1.3	6.9	30.1	28.3	50.4	9.2	0.14	ND	81.1
15	木	24.1	18.0	1.3	7.0	29.7	28.3	44.0	9.6	0.16	ND	83.7
16	金	21.5	17.1	1.0	7.0	29.7	30.4	45.2	9.2	0.10	ND	83.7
17	土	15.2	17.0	0.7	7.0	30.7	30.2	42.8	9.4	0.09	ND	85.7
18	日	14.0	16.0	0.7	7.1	31.1	31.2	46.8	9.6	0.10	ND	86.1
19	月	13.5	16.0	1.3	7.0	29.7	30.6	43.2	9.3	0.13	ND	82.0
20	火	18.3	15.4	1.3	7.1	30.6	31.2	54.8	10.1	0.10	ND	84.8
21	水	18.5	15.6	1.4	6.9	31.3	31.0	53.2	8.8	0.13	ND	81.2
22	木	19.7	16.2	1.2	7.0	30.3	29.1	46.4	10.1	0.11	ND	85.2
23	金	15.9	16.7	1.9	7.0	29.2	28.5	41.6	8.8	0.12	ND	80.8
24	土	16.6	15.5	2.8	7.1	25.4	28.3	56.8	7.6	0.22	ND	79.7
25	日	12.5	14.5	3.3	7.1	24.3	25.7	47.6	7.4	0.21	0.01	79.5
26	月	17.2	14.2	2.9	6.9	26.0	26.7	49.2	6.5	0.21	ND	75.2
27	火	16.0	14.0	2.1	6.8	27.0	26.9	44.4	6.4	0.19	ND	73.4
28	水	13.6	14.3	1.9	6.9	29.0	29.3	51.2	8.0	0.17	ND	80.0
29	木	21.4	14.1	1.3	7.0	29.6	29.9	55.6	8.1	0.11	ND	82.5
30	金	15.2	14.2	1.2	7.0	30.4	30.4	46.4	6.7	0.11	ND	85.9
31	土	13.8	13.8	0.7	7.0	30.3	29.3	48.8	7.4	0.08	ND	86.4
最大値		25.1	19.0	3.3	7.1	31.3	31.2	56.8	10.1	0.29	0.01	86.4
最小値		12.5	13.8	0.7	6.8	24.3	25.7	41.6	6.4	0.08	ND	73.4
平均値		18.7	16.6	1.7	7.0	29.0	29.3	49.5	8.6	0.15	ND	81.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2020年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	木	23.0	19.5	0.7	7.0	28.4	29.3	44.0	8.7	0.05	ND	81.5
2	金	22.4	19.6	0.8	6.8	28.7	28.5	48.4	9.3	0.06	ND	81.4
3	土	21.2	19.3	0.6	7.1	27.1	29.1	43.2	9.8	0.07	ND	80.9
4	日	21.2	19.0	0.5	7.1	30.7	29.3	40.0	10.9	0.08	ND	84.5
5	月	19.1	19.2	0.8	7.0	30.0	29.9	47.2	10.1	0.09	ND	84.5
6	火	16.7	18.1	1.0	7.0	28.5	31.2	45.2	9.7	0.08	ND	84.3
7	水	22.2	18.0	0.9	6.9	28.6	30.6	48.8	9.3	0.08	ND	83.5
8	木	16.9	18.2	1.0	7.0	29.1	29.9	45.6	10.5	0.08	ND	83.4
9	金	16.3	17.3	1.0	6.9	27.0	28.5	48.0	8.5	0.08	ND	79.6
10	土	20.1	17.2	0.9	7.1	26.0	27.3	47.6	8.5	0.09	ND	80.0
11	日	23.5	18.2	0.9	7.2	28.1	28.5	42.0	8.5	0.09	ND	80.3
12	月	25.1	19.0	0.6	7.0	29.5	30.6	52.4	9.7	0.08	ND	84.4
13	火	24.1	19.3	0.8	7.1	29.6	30.4	48.0	9.9	0.07	ND	81.8
14	水	21.7	19.0	0.7	7.0	29.4	29.9	40.0	9.7	0.08	ND	82.6
15	木	24.1	18.9	0.7	7.0	30.2	29.3	36.0	10.9	0.09	ND	84.9
16	金	21.5	18.0	0.6	7.1	30.0	30.6	48.0	10.3	0.07	ND	84.7
17	土	15.2	17.7	0.5	7.2	30.8	29.5	36.8	9.9	0.08	ND	86.2
18	日	14.0	16.9	0.5	7.2	32.0	29.9	43.6	10.4	0.08	ND	86.2
19	月	13.5	16.6	0.4	7.1	30.8	29.9	46.4	10.3	0.07	ND	84.3
20	火	18.3	16.1	0.7	7.1	30.2	29.9	50.0	10.6	0.07	ND	85.8
21	水	18.5	16.3	0.6	7.1	31.0	30.4	47.2	9.0	0.06	ND	84.4
22	木	19.7	17.0	0.6	7.0	30.0	29.9	41.2	10.5	0.07	ND	85.8
23	金	15.9	17.0	0.8	7.0	29.8	29.3	46.8	9.8	0.06	ND	83.2
24	土	16.6	16.2	1.7	6.9	25.4	29.5	54.0	8.8	0.10	ND	80.9
25	日	12.5	15.2	1.4	7.0	28.0	28.7	42.4	8.4	0.10	ND	83.0
26	月	17.2	15.0	1.4	6.8	25.0	27.1	48.0	7.6	0.08	ND	77.5
27	火	16.0	14.7	1.0	6.9	26.5	26.1	38.8	6.9	0.07	ND	74.2
28	水	13.6	15.0	0.8	7.0	28.1	26.7	45.2	7.4	0.07	ND	79.3
29	木	21.4	14.8	0.8	6.9	29.6	28.1	48.0	8.1	0.07	ND	82.7
30	金	15.2	15.0	0.8	7.0	29.6	28.7	44.0	8.0	0.07	ND	85.8
31	土	13.8	14.0	0.5	7.1	31.0	30.4	45.2	8.4	0.06	ND	76.7
最大値		25.1	19.6	1.7	7.2	32.0	31.2	54.0	10.9	0.10	ND	86.2
最小値		12.5	14.0	0.4	6.8	25.0	26.1	36.0	6.9	0.05	ND	74.2
平均値		18.7	17.3	0.8	7.0	29.0	29.3	45.2	9.3	0.08	ND	82.5

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所