

水質試験結果表(取水分)

2020年11月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	16.7	13.7	0.9	7.0	31.9	30.6	49.6	8.0	0.11	ND	89.4
2	月	15.8	14.0	2.1	6.9	31.1	29.3	50.0	6.7	0.17	ND	86.2
3	火	17.1	14.1	2.3	7.1	28.6	29.7	46.0	5.5	0.11	ND	80.9
4	水	10.2	13.6	2.2	6.8	30.1	31.6	48.8	6.5	0.10	ND	86.4
5	木	12.6	12.6	2.1	6.9	28.1	29.5	58.4	6.3	0.16	ND	84.7
6	金	12.9	13.0	1.7	7.0	31.2	29.9	56.4	6.7	0.12	ND	86.0
7	土	15.7	13.2	1.0	7.1	29.8	32.6	44.0	6.7	0.07	ND	83.7
8	日	14.8	13.9	1.1	7.1	29.8	30.8	43.6	6.7	0.10	ND	83.5
9	月	14.3	13.8	2.1	7.0	30.5	31.6	50.0	6.8	0.17	ND	84.7
10	火	10.8	13.0	1.5	7.0	30.9	32.2	44.4	6.9	0.14	ND	91.4
11	水	14.4	12.5	1.4	7.0	32.0	35.2	64.4	8.3	0.12	ND	97.9
12	木	11.3	11.9	1.3	7.0	33.6	35.0	52.4	7.8	0.11	ND	98.9
13	金	15.7	12.2	1.3	6.9	32.7	35.0	52.0	7.7	0.13	ND	93.7
14	土	19.4	13.1	0.7	7.2	33.8	35.2	63.2	8.7	0.10	ND	99.9
15	日	17.4	12.7	0.7	7.0	33.8	33.8	54.8	7.8	0.11	ND	95.2
16	月	17.7	13.1	2.7	6.9	34.7	35.6	58.8	8.2	0.22	ND	100.1
17	火	15.1	13.3	1.3	7.0	36.4	37.6	55.6	8.6	0.07	ND	102.7
18	水	22.9	13.5	1.1	7.0	35.8	37.8	61.2	8.8	0.10	ND	104.7
19	木	23.4	14.7	1.3	7.1	36.4	38.4	63.2	7.4	0.11	ND	105.1
20	金	23.2	16.1	1.7	7.2	41.2	42.0	72.4	7.9	0.15	ND	112.6
21	土	13.8	15.5	1.2	7.0	34.7	38.2	62.0	7.6	0.10	ND	103.9
22	日	19.6	13.2	1.0	7.2	33.8	36.0	54.8	7.9	0.02	ND	97.7
23	月	12.7	13.5	1.3	7.0	33.8	35.6	55.2	7.1	0.04	ND	98.1
24	火	12.4	13.6	2.5	7.0	30.2	34.4	57.2	7.2	0.20	ND	90.0
25	水	15.0	11.9	1.6	6.9	32.9	35.4	55.2	7.8	0.15	ND	96.4
26	木	10.6	12.0	1.4	6.9	33.4	35.6	60.4	8.2	0.13	ND	99.3
27	金	12.2	11.4	1.2	6.9	33.8	36.0	51.6	7.3	0.12	ND	96.2
28	土	10.5	13.1	1.2	7.0	31.5	33.0	54.0	7.0	0.04	ND	93.8
29	日	7.9	11.1	2.1	7.1	28.8	32.8	49.2	6.7	0.06	ND	84.9
30	月	14.4	11.3	1.1	6.9	30.3	32.2	51.6	6.0	0.13	ND	87.0
最大値		23.4	16.1	2.7	7.2	41.2	42.0	72.4	8.8	0.22	ND	112.6
最小値		7.9	11.1	0.7	6.8	28.1	29.3	43.6	5.5	0.02	ND	80.9
平均値		15.0	13.2	1.5	7.0	32.5	34.1	54.7	7.4	0.12	ND	93.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

