

水質試験結果表(取水分)

2021年3月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	月	15.0	7.8	2.9	7.1	23.5	30.4	46.8	6.0	0.21	ND	73.8
2	火	10.9	8.9	4.0	7.1	22.0	26.9	45.6	7.1	0.24	0.01	74.8
3	水	8.0	6.9	39.7	6.6	16.0	22.3	89.2	8.9	0.76	0.18	72.9
4	木	11.9	7.6	4.2	6.9	18.7	21.9	40.0	6.0	0.28	0.02	61.6
5	金	12.4	8.5	3.0	6.8	21.0	24.1	42.8	6.5	0.19	0.01	64.4
6	土	11.0	8.0	2.8	7.1	19.7	23.9	43.6	6.4	0.12	ND	65.7
7	日	7.9	8.1	3.1	7.1	18.1	24.3	40.4	6.3	0.16	ND	60.6
8	月	7.5	8.3	2.6	6.9	19.1	24.1	38.4	6.5	0.16	ND	63.3
9	火	5.6	7.7	2.5	7.0	21.2	24.7	34.8	6.1	0.16	ND	67.0
10	水	11.4	8.5	2.6	6.8	22.1	25.7	38.4	5.5	0.14	ND	68.2
11	木	8.5	8.7	2.2	6.9	22.5	25.1	44.0	5.7	0.16	ND	69.0
12	金	11.8	9.0	2.1	7.0	22.6	25.9	43.6	5.6	0.15	ND	66.2
13	土	9.9	8.8	1.7	7.0	22.5	24.3	44.0	6.7	0.07	ND	74.5
14	日	10.7	8.7	8.2	7.0	18.0	20.1	50.0	4.9	0.42	0.03	53.1
15	月	10.5	8.8	4.6	6.8	18.2	20.9	44.4	6.4	0.19	0.01	61.8
16	火	12.0	9.1	3.1	7.0	20.1	23.5	46.8	6.3	0.20	0.01	65.9
17	水	14.2	8.4	3.4	7.0	20.3	24.1	46.0	6.5	0.23	0.01	73.6
18	木	11.5	8.8	2.5	6.9	19.5	22.5	41.2	4.7	0.18	ND	60.3
19	金	10.5	9.0	2.7	6.9	20.1	23.9	42.0	4.8	0.17	ND	61.1
20	土	15.8	9.2	2.3	7.2	20.8	22.1	39.2	4.9	0.04	ND	61.8
21	日	17.6	10.0	2.0	7.1	20.7	21.9	38.4	4.7	0.04	ND	62.1
22	月	8.5	10.3	22.6	6.8	18.2	24.9	71.6	7.2	0.37	ND	73.9
23	火	9.5	9.3	8.0	6.7	21.6	25.7	63.2	9.9	0.32	0.01	90.0
24	水	14.9	9.6	4.5	6.8	22.0	28.9	54.8	8.9	0.32	0.01	88.0
25	木	14.3	10.0	4.5	6.9	20.4	22.7	43.2	5.6	0.16	ND	61.3
26	金	11.1	9.1	3.5	7.1	19.8	22.9	38.0	4.6	0.23	0.01	61.8
27	土	11.9	9.2	1.2	7.2	20.9	24.1	36.0	4.6	0.11	ND	61.3
28	日	14.6	10.8	2.9	7.0	23.7	26.5	48.0	8.4	0.20	ND	89.4
29	月	17.8	11.0	19.8	6.8	20.7	24.1	57.6	7.9	0.55	0.09	77.5
30	火	17.0	11.4	12.6	6.7	19.0	22.1	56.0	7.6	0.29	0.04	70.5
31	水	19.4	11.0	5.1	6.9	21.0	25.3	49.6	8.2	0.27	0.02	77.7
最大値		19.4	11.4	39.7	7.2	23.7	30.4	89.2	9.9	0.76	0.18	90.0
最小値		5.6	6.9	1.2	6.6	16.0	20.1	34.8	4.6	0.04	ND	53.1
平均値		12.1	9.0	6.0	6.9	20.5	24.2	47.0	6.4	0.23	0.01	68.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2021年3月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	15.0	7.7	1.0	6.9	23.8	28.9	39.2	7.0	0.05	ND	74.8
2	火	10.9	9.0	1.1	7.0	21.4	26.5	35.6	7.6	0.05	ND	77.1
3	水	8.0	7.4	3.0	6.6	12.9	20.5	44.0	11.6	0.05	ND	79.2
4	木	11.9	7.8	0.9	6.7	16.5	21.7	36.0	6.9	0.03	ND	62.5
5	金	12.4	8.7	0.8	6.7	19.9	23.1	41.2	7.6	0.03	ND	65.6
6	土	11.0	8.2	0.8	6.9	18.6	24.7	36.0	7.2	0.02	ND	68.4
7	日	7.9	8.5	1.0	6.9	16.4	22.1	34.4	7.4	0.02	ND	63.0
8	月	7.5	8.5	0.7	6.8	17.9	23.1	32.0	6.8	0.03	ND	64.8
9	火	5.6	8.0	1.3	6.8	20.4	24.3	32.4	6.1	0.05	ND	67.0
10	水	11.4	8.9	1.1	6.9	20.6	25.3	32.0	6.2	0.04	ND	68.9
11	木	8.5	9.0	0.9	6.8	22.1	26.3	38.4	5.9	0.04	ND	69.7
12	金	11.8	9.0	0.8	6.9	20.8	23.9	42.8	5.4	0.04	ND	67.9
13	土	9.9	8.6	0.7	7.0	22.1	24.1	39.2	7.4	0.01	ND	73.1
14	日	10.7	8.9	1.1	6.8	17.0	19.9	46.4	8.1	0.02	ND	65.1
15	月	10.5	8.8	1.0	6.7	15.8	20.3	33.2	6.9	0.03	ND	61.8
16	火	12.0	9.5	0.8	6.7	18.7	22.9	42.0	6.7	0.04	ND	66.7
17	水	14.2	8.6	1.0	6.8	19.3	24.7	38.0	7.9	0.04	ND	74.1
18	木	11.5	9.2	0.9	6.8	18.3	21.7	35.2	5.7	0.04	ND	61.3
19	金	10.5	9.3	0.9	6.9	18.8	21.7	34.8	6.0	0.04	ND	62.2
20	土	15.8	9.8	0.9	6.9	20.0	21.9	33.6	5.5	0.01	ND	62.7
21	日	17.6	10.0	0.6	7.0	20.6	21.9	33.2	4.9	ND	ND	62.8
22	月	8.5	10.8	1.0	6.8	17.9	26.3	41.6	9.4	0.01	ND	81.5
23	火	9.5	9.8	1.1	6.8	20.3	26.1	51.2	11.7	0.06	ND	93.0
24	水	14.9	10.2	0.9	6.9	21.3	26.9	56.0	11.3	0.05	ND	95.4
25	木	14.3	10.2	0.7	6.8	18.7	22.7	35.6	4.9	0.01	ND	63.9
26	金	11.1	9.3	1.0	7.0	18.4	22.5	34.4	6.5	0.04	ND	60.1
27	土	11.9	9.3	0.3	7.0	19.8	22.7	30.8	5.9	0.01	ND	62.5
28	日	14.6	11.0	0.2	7.1	23.0	27.3	40.4	9.7	0.01	ND	90.5
29	月	17.8	11.6	0.3	6.9	20.8	25.5	33.2	10.1	0.02	ND	89.6
30	火	17.0	11.9	1.1	6.9	17.5	22.9	39.6	8.4	0.02	ND	73.8
31	水	19.4	11.6	1.0	6.8	19.0	24.7	41.6	8.9	0.04	ND	78.8
最大値		19.4	11.9	3.0	7.1	23.8	28.9	56.0	11.7	0.06	ND	95.4
最小値		5.6	7.4	0.2	6.6	12.9	19.9	30.8	4.9	ND	ND	60.1
平均値		12.1	9.3	0.9	6.9	19.3	23.8	38.2	7.5	0.03	ND	71.2

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 濁度およびpH以外の基準については参考値とする。
 本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所