

## 水質試験結果表(取水分)

2021年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	18.1	10.7	4.1	6.9	20.9	25.1	48.8	8.3	0.22	ND	77.1
2	金	17.1	10.6	4.6	6.9	19.2	20.7	41.6	3.9	0.25	0.01	56.6
3	土	20.4	11.1	2.3	7.1	20.3	20.3	34.0	6.8	0.07	ND	57.1
4	日	17.7	11.7	2.5	7.1	19.6	19.9	32.0	6.7	0.06	ND	55.8
5	月	10.9	10.8	6.6	6.9	17.4	18.7	36.4	6.3	0.24	ND	52.6
6	火	10.9	10.0	4.9	6.8	16.7	19.5	40.4	4.4	0.30	0.01	51.8
7	水	16.3	10.1	2.9	6.9	18.6	20.7	41.2	3.9	0.14	0.01	55.7
8	木	12.9	10.5	3.0	6.9	20.0	21.9	37.6	4.6	0.14	0.01	57.6
9	金	16.7	10.3	2.6	6.8	20.0	22.1	35.2	5.1	0.13	ND	59.0
10	土	15.9	9.6	1.9	7.1	20.7	21.3	39.6	5.2	0.05	ND	60.9
11	日	12.9	10.1	2.0	7.0	21.5	23.5	38.0	4.6	0.06	ND	62.3
12	月	17.6	10.9	2.4	6.9	21.3	22.9	43.6	4.7	0.04	ND	61.8
13	火	17.2	11.7	2.8	6.8	20.7	22.7	45.2	5.1	0.12	ND	61.8
14	水	14.5	11.0	4.1	6.8	20.4	22.7	46.0	6.3	0.07	ND	65.3
15	木	16.6	10.1	4.2	6.9	18.7	20.3	41.6	6.0	0.16	ND	54.5
16	金	17.9	10.7	3.8	6.7	20.5	22.3	37.6	4.0	0.24	ND	60.2
17	土	13.8	11.2	2.7	6.9	22.1	21.7	38.4	4.4	0.08	ND	62.2
18	日	11.9	10.6	7.5	6.9	19.1	20.1	35.6	3.5	0.12	ND	52.5
19	月	14.7	9.5	6.2	6.8	18.1	20.9	39.6	3.5	0.32	0.01	54.7
20	火	17.5	10.4	4.8	6.8	20.5	22.3	44.8	4.1	0.28	ND	60.1
21	水	17.5	11.6	4.4	6.8	20.9	21.9	42.4	4.6	0.17	ND	61.1
22	木	19.9	12.0	5.0	6.8	21.4	23.1	45.2	4.7	0.29	0.01	62.4
23	金	18.4	11.9	4.6	6.8	21.8	23.9	42.0	4.8	0.25	0.01	64.0
24	土	19.6	12.5	3.0	6.9	22.8	24.1	43.2	5.2	0.22	ND	65.1
25	日	21.3	14.0	4.2	6.9	21.9	24.1	39.2	4.1	0.28	ND	64.9
26	月	16.8	12.3	6.2	6.8	22.0	23.7	44.4	4.5	0.43	0.01	64.7
27	火	16.3	11.8	6.7	6.8	23.2	25.9	41.6	4.8	0.39	0.02	67.1
28	水	15.7	13.0	6.3	7.0	22.9	27.1	47.2	5.6	0.34	0.02	68.0
29	木	16.0	12.9	6.7	6.9	21.3	23.1	42.8	5.0	0.35	0.02	64.2
30	金	18.6	11.4	22.0	6.6	13.4	15.3	48.0	3.1	0.86	0.08	42.2
最大値		21.3	14.0	22.0	7.1	23.2	27.1	48.8	8.3	0.86	0.08	77.1
最小値		10.9	9.5	1.9	6.6	13.4	15.3	32.0	3.1	0.04	ND	42.2
平均値		16.4	11.2	4.8	6.9	20.3	22.1	41.1	4.9	0.22	0.01	60.1

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2021年4月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	木	18.1	11.5	0.9	6.7	20.0	26.3	46.0	8.9	0.03	ND	81.8
2	金	17.1	11.2	0.8	6.7	17.7	20.5	36.8	6.4	0.01	ND	58.3
3	土	20.4	12.0	0.6	6.9	19.1	20.1	27.6	6.5	ND	ND	58.9
4	日	17.7	12.0	0.4	6.9	19.0	20.3	27.2	6.4	ND	ND	57.5
5	月	10.9	11.2	0.6	6.9	17.4	20.3	30.4	6.0	0.01	ND	60.5
6	火	10.9	10.8	0.9	6.6	14.7	19.1	32.8	6.0	0.02	ND	52.2
7	水	16.3	10.7	0.9	6.9	17.0	19.9	36.0	4.9	0.03	ND	56.4
8	木	12.9	11.2	0.8	6.9	18.2	20.7	36.0	5.0	0.02	ND	58.2
9	金	16.7	10.9	0.8	6.7	18.5	21.5	31.2	5.5	0.02	ND	59.6
10	土	15.9	10.1	0.8	7.0	19.6	21.5	34.4	5.5	0.02	ND	61.6
11	日	12.9	10.5	0.5	7.0	20.9	22.7	31.2	4.8	ND	ND	62.9
12	月	17.6	11.1	0.7	7.0	20.1	22.5	36.8	4.7	0.01	ND	62.5
13	火	17.2	12.0	0.7	6.8	20.3	23.3	37.2	5.3	ND	ND	62.3
14	水	14.5	11.4	0.9	6.7	19.4	22.9	39.6	8.1	0.02	ND	73.3
15	木	16.6	11.0	0.9	6.7	17.0	19.9	34.8	6.2	0.01	ND	56.2
16	金	17.9	11.3	0.9	6.7	18.7	22.1	28.0	4.9	0.03	ND	61.1
17	土	13.8	11.9	0.7	6.8	22.4	22.5	29.6	6.0	0.02	ND	63.3
18	日	11.9	11.2	0.8	6.8	18.2	20.3	27.2	6.6	0.01	ND	59.0
19	月	14.7	10.5	1.0	6.6	15.7	19.1	31.6	5.7	0.02	ND	54.7
20	火	17.5	11.2	0.8	6.9	18.2	21.3	34.8	5.9	0.03	ND	61.5
21	水	17.5	12.4	0.8	6.8	19.3	23.5	39.2	5.7	0.03	ND	62.9
22	木	19.9	12.7	0.7	6.7	19.3	23.1	38.0	6.1	0.03	ND	64.0
23	金	18.4	12.7	0.9	6.7	19.3	23.3	36.0	5.9	0.03	ND	65.2
24	土	19.6	13.1	0.6	6.7	20.8	23.9	34.0	5.9	0.03	ND	66.7
25	日	21.3	13.2	0.5	6.8	20.4	23.5	34.4	6.3	0.02	ND	66.5
26	月	16.8	13.3	0.6	6.7	20.4	24.3	36.4	6.0	0.03	ND	66.5
27	火	16.3	12.5	0.9	6.6	20.0	24.3	34.8	6.0	0.03	ND	69.4
28	水	15.7	13.2	0.7	6.7	20.5	25.1	38.4	6.3	0.02	ND	70.1
29	木	16.0	13.1	1.2	6.7	20.7	23.5	36.8	5.9	0.02	ND	69.6
30	金	18.6	12.0	1.4	6.5	12.3	16.9	39.2	6.0	0.03	ND	50.0
最大値		21.3	13.3	1.4	7.0	22.4	26.3	46.0	8.9	0.03	ND	81.8
最小値		10.9	10.1	0.4	6.5	12.3	16.9	27.2	4.7	ND	ND	50.0
平均値		16.4	11.7	0.8	6.8	18.8	21.9	34.5	6.0	0.02	ND	62.4

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所