

水質試験結果表(取水分)

2021年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	15.5	12.2	5.4	6.6	17.8	19.7	35.2	4.3	0.05	ND	55.2
2	日	11.5	12.5	12.6	6.7	16.6	19.5	54.0	3.7	0.20	0.04	56.0
3	月	15.1	11.2	11.5	6.7	14.9	17.9	38.4	5.1	0.15	0.02	51.2
4	火	20.0	12.1	6.1	6.7	18.9	21.9	49.2	4.6	0.05	0.01	59.4
5	水	15.0	13.5	5.5	6.8	21.0	22.9	46.0	4.5	0.05	ND	65.0
6	木	17.6	12.4	25.5	6.8	16.3	19.3	49.2	3.3	0.14	0.04	50.1
7	金	18.0	12.7	9.2	6.8	19.5	20.9	40.8	4.5	0.42	0.01	55.7
8	土	22.0	12.8	4.1	6.8	19.7	23.1	42.8	6.7	0.25	ND	63.6
9	日	19.0	13.9	4.5	6.8	20.3	24.1	41.6	6.1	0.26	ND	66.0
10	月	19.3	13.4	10.9	6.8	18.6	22.9	47.2	6.5	0.60	0.01	65.6
11	火	20.5	13.1	8.7	6.8	22.6	24.5	48.8	4.7	0.21	0.01	66.3
12	水	19.1	14.0	6.9	6.8	22.8	25.7	45.6	4.4	0.36	0.02	69.0
13	木	25.7	14.4	6.5	6.9	24.7	26.7	50.4	4.6	0.36	0.01	70.0
14	金	26.1	15.0	6.8	6.9	23.9	24.5	46.8	4.4	0.34	0.02	69.3
15	土	27.0	16.0	3.3	6.9	23.7	25.3	48.0	4.5	0.04	0.01	69.6
16	日	19.9	17.2	3.7	7.0	24.3	26.7	47.2	4.7	0.05	0.01	74.1
17	月	21.3	16.4	12.8	6.8	22.9	25.9	63.6	4.1	0.19	0.02	69.2
18	火	18.2	14.9	19.1	6.7	14.6	16.5	57.6	3.1	0.81	0.16	44.3
19	水	19.6	15.1	8.9	6.9	18.7	20.7	43.6	3.4	0.32	0.03	56.6
20	木	17.0	14.3	6.3	6.9	21.8	23.5	49.2	3.9	0.30	0.01	64.0
21	金	21.7	15.3	8.7	6.9	19.5	21.9	44.4	3.8	0.42	0.05	57.4
22	土	17.8	15.9	11.2	6.8	19.6	22.7	59.6	8.0	0.82	0.04	79.6
23	日	21.4	15.1	6.5	6.9	20.4	23.1	51.2	8.7	0.45	0.01	80.6
24	月	24.5	16.0	7.7	6.8	22.3	26.3	57.2	8.6	0.46	0.02	86.0
25	火	26.7	16.0	5.8	6.9	23.6	28.9	60.0	9.0	0.23	0.01	93.7
26	水	18.8	16.9	5.7	6.9	24.6	28.3	62.4	10.0	0.37	0.02	97.3
27	木	15.2	15.0	5.0	6.8	22.0	22.3	48.0	4.3	0.30	0.01	63.1
28	金	21.8	14.5	6.7	6.9	20.0	21.1	44.4	4.1	0.33	0.01	58.4
29	土	22.7	15.9	2.2	6.9	21.5	22.9	38.0	4.5	0.06	ND	62.5
30	日	25.9	15.5	2.2	6.9	22.4	24.5	38.4	3.7	0.02	ND	63.6
31	月	21.9	16.0	3.0	6.8	22.0	22.5	44.0	3.3	0.05	ND	63.2
最大値		27.0	17.2	25.5	7.0	24.7	28.9	63.6	10.0	0.82	0.16	97.3
最小値		11.5	11.2	2.2	6.6	14.6	16.5	35.2	3.1	0.02	ND	44.3
平均値		20.2	14.5	7.8	6.8	20.7	23.1	48.2	5.1	0.28	0.02	66.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2021年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	15.5	12.8	0.5	6.8	15.6	18.5	31.2	6.2	ND	ND	58.2
2	日	11.5	12.8	0.7	6.7	17.3	20.7	30.0	6.4	ND	ND	64.7
3	月	15.1	11.9	0.8	6.7	15.4	18.3	26.8	5.6	ND	ND	60.3
4	火	20.0	12.5	0.7	6.7	17.1	20.3	30.0	5.9	ND	ND	63.4
5	水	15.0	13.7	0.5	6.7	18.2	22.3	32.4	5.6	ND	ND	66.2
6	木	17.6	13.3	0.9	6.7	17.6	21.3	32.0	6.2	0.01	ND	64.1
7	金	18.0	13.4	0.8	6.7	17.8	20.3	37.2	5.9	0.03	ND	60.4
8	土	22.0	13.0	1.0	6.8	22.2	23.5	36.4	3.5	0.02	ND	64.4
9	日	19.0	14.2	0.6	6.8	22.9	24.1	36.0	3.7	0.02	ND	67.8
10	月	19.3	14.4	0.5	6.6	21.5	22.5	35.2	4.0	0.02	ND	67.4
11	火	20.5	13.8	0.9	6.6	20.2	25.1	27.6	5.3	0.02	ND	69.0
12	水	19.1	14.6	0.8	6.7	21.1	24.5	28.4	6.3	0.03	ND	70.8
13	木	25.7	15.0	0.8	6.6	21.6	26.1	42.0	6.3	0.03	ND	72.2
14	金	26.1	15.5	0.8	6.6	21.7	25.1	32.0	5.2	0.03	ND	71.8
15	土	27.0	16.5	0.3	6.8	21.4	24.9	34.8	6.0	ND	ND	71.9
16	日	19.9	18.0	0.1	6.7	23.0	26.9	36.0	6.3	ND	ND	75.6
17	月	21.3	17.0	0.4	6.8	21.6	26.7	37.2	6.0	ND	ND	73.1
18	火	18.2	15.8	1.7	6.6	12.7	16.3	31.2	5.7	0.06	ND	53.1
19	水	19.6	15.5	1.5	6.6	14.1	20.9	32.8	5.6	0.04	ND	59.1
20	木	17.0	15.0	1.2	6.8	19.3	23.9	40.0	6.2	0.05	ND	66.0
21	金	21.7	15.7	0.8	6.8	18.8	21.9	34.0	5.6	0.03	ND	62.9
22	土	17.8	16.5	1.4	6.8	17.7	21.9	41.6	10.3	0.06	ND	84.4
23	日	21.4	15.9	1.1	6.8	19.6	24.1	48.8	9.8	0.05	ND	86.2
24	月	24.5	16.7	0.6	6.8	20.8	25.3	57.2	10.4	0.03	ND	89.0
25	火	26.7	16.4	0.7	6.7	21.8	27.7	59.2	10.1	0.04	ND	93.7
26	水	18.8	17.2	0.7	6.8	22.4	27.9	48.4	11.5	0.04	ND	99.4
27	木	15.2	16.0	1.0	6.7	20.2	23.3	40.0	5.3	0.06	ND	65.0
28	金	21.8	15.1	1.1	6.8	18.1	22.1	34.0	5.7	0.04	ND	62.0
29	土	22.7	16.5	0.6	7.0	20.5	22.5	39.2	4.9	0.02	ND	63.4
30	日	25.9	16.1	0.6	7.0	22.0	25.3	36.0	5.0	ND	ND	64.6
31	月	21.9	17.0	0.4	6.9	20.9	23.7	38.4	4.7	0.03	ND	64.3
最大値		27.0	18.0	1.7	7.0	23.0	27.9	59.2	11.5	0.06	ND	99.4
最小値		11.5	11.9	0.1	6.6	12.7	16.3	26.8	3.5	ND	ND	53.1
平均値		20.2	15.1	0.8	6.7	19.5	23.2	37.0	6.3	0.02	ND	69.5

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所