

## 水質試験結果表(取水分)

2021年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	28.4	20.8	5.7	6.8	30.4	31.2	64.4	4.8	0.36	0.01	81.8
2	金	31.9	20.2	5.2	6.9	30.2	32.2	63.2	5.0	0.44	0.01	82.3
3	土	29.7	21.2	42.7	6.8	21.3	23.7	81.6	3.2	0.43	0.03	59.8
4	日	25.8	20.9	7.7	6.9	25.3	24.3	58.8	3.8	0.06	0.01	67.2
5	月	24.1	20.8	6.8	6.8	25.4	25.7	59.6	3.6	0.46	0.03	68.4
6	火	23.7	19.0	19.3	6.8	19.8	20.3	64.4	2.7	0.94	0.09	47.7
7	水	24.5	19.8	15.4	6.6	22.3	26.9	84.4	9.7	0.71	0.02	91.8
8	木	25.9	19.8	25.2	6.5	21.7	26.7	94.8	11.0	1.21	0.09	96.6
9	金	25.8	20.2	21.2	6.6	22.9	26.3	92.4	12.3	1.13	0.08	97.3
10	土	26.3	20.6	5.3	6.8	28.0	28.5	69.6	10.1	0.51	ND	101.3
11	日	27.8	20.5	10.7	6.8	24.9	26.7	72.0	8.4	0.68	0.02	91.0
12	月	23.3	20.7	7.8	6.9	25.6	28.3	72.4	9.6	0.40	ND	97.8
13	火	27.6	20.3	8.4	6.8	26.0	29.1	68.8	9.6	0.43	0.03	98.6
14	水	28.5	21.5	6.8	6.8	26.2	28.9	80.0	11.5	0.45	0.03	107.8
15	木	30.5	21.9	6.9	6.9	27.5	29.3	72.4	10.7	0.38	0.01	104.9
16	金	28.6	20.3	7.0	7.0	24.0	26.7	49.6	3.4	0.48	0.03	63.6
17	土	31.2	21.0	1.6	6.9	25.7	25.9	55.2	3.7	0.17	ND	70.0
18	日	31.7	22.2	1.7	7.0	28.0	27.3	48.8	2.6	0.20	ND	76.8
19	月	32.8	22.8	4.4	6.8	28.2	30.2	61.6	2.1	0.44	0.02	77.9
20	火	34.1	23.1	2.8	6.8	27.7	28.9	57.2	4.6	0.24	0.01	76.5
21	水	32.5	23.0	5.3	6.9	26.0	27.3	54.8	4.6	0.29	ND	71.4
22	木	33.8	23.0	1.5	6.9	29.4	30.8	52.4	3.7	0.11	ND	78.5
23	金	34.7	23.2	1.0	7.0	31.5	31.6	50.0	4.5	0.08	ND	81.0
24	土	30.9	24.0	0.7	6.9	30.6	36.2	43.2	4.7	0.05	ND	84.1
25	日	27.9	24.2	1.0	7.0	30.3	36.2	46.4	3.9	0.12	ND	81.6
26	月	32.6	24.0	3.9	6.8	30.8	33.6	50.0	3.7	0.27	ND	80.7
27	火	31.8	23.0	3.9	6.9	27.0	28.5	52.0	4.1	0.28	0.02	72.8
28	水	28.3	22.2	2.9	6.9	26.6	27.7	50.8	4.3	0.20	0.01	72.7
29	木	24.2	22.1	2.8	6.8	26.2	28.3	51.2	4.0	0.22	0.01	71.6
30	金	32.1	22.0	2.3	6.9	26.9	33.6	51.2	4.6	0.17	ND	75.2
31	土	30.8	23.1	1.0	7.1	29.9	32.0	54.0	4.6	0.11	ND	81.1
最大値		34.7	24.2	42.7	7.1	31.5	36.2	94.8	12.3	1.21	0.09	107.8
最小値		23.3	19.0	0.7	6.5	19.8	20.3	43.2	2.1	0.05	ND	47.7
平均値		29.1	21.7	7.7	6.9	26.7	28.8	62.2	5.8	0.39	0.02	81.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2021年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	木	28.4	21.1	0.4	6.8	29.0	31.0	49.6	6.1	0.02	ND	83.5
2	金	31.9	21.6	0.5	6.8	28.2	28.9	58.8	5.3	0.03	ND	85.0
3	土	29.7	22.0	0.4	6.9	25.1	27.1	46.0	7.1	ND	ND	79.8
4	日	25.8	21.7	1.0	6.9	22.2	24.1	38.8	6.6	0.04	ND	70.4
5	月	24.1	21.2	0.6	6.7	22.8	25.1	47.2	5.5	0.03	ND	70.0
6	火	23.7	19.6	1.4	6.6	17.3	18.3	38.0	5.0	0.06	ND	52.9
7	水	24.5	20.3	1.4	6.5	21.0	24.9	40.0	12.8	0.06	ND	101.0
8	木	25.9	20.5	1.5	6.6	18.2	25.3	58.0	14.6	0.06	ND	108.1
9	金	25.8	20.9	1.0	6.5	19.9	24.3	60.8	12.2	0.06	ND	91.3
10	土	26.3	20.6	0.6	6.8	27.5	27.3	58.4	12.2	0.03	ND	111.2
11	日	27.8	21.0	0.6	7.0	25.7	28.1	66.0	11.7	0.03	ND	104.6
12	月	23.3	21.2	0.5	6.7	23.8	28.1	64.0	12.9	0.03	ND	108.3
13	火	27.6	21.0	0.8	6.7	24.2	28.3	59.6	12.3	0.05	ND	106.0
14	水	28.5	22.0	0.5	6.8	25.2	29.3	70.0	13.4	0.04	ND	113.3
15	木	30.5	22.5	0.7	6.8	25.5	29.7	67.6	12.8	0.03	ND	110.9
16	金	28.6	21.1	1.1	6.7	22.1	25.5	45.6	5.9	0.05	0.03	66.7
17	土	31.2	21.8	0.8	7.0	26.0	25.1	40.0	4.0	0.02	ND	70.3
18	日	31.7	22.8	0.4	6.9	29.0	26.7	53.2	4.7	0.04	ND	77.2
19	月	32.8	23.4	0.5	6.8	27.7	28.3	53.6	4.7	0.05	ND	79.4
20	火	34.1	24.0	0.5	6.8	26.7	27.3	58.4	5.2	0.04	ND	78.6
21	水	32.5	23.9	0.7	6.8	24.4	25.5	48.4	5.9	0.03	ND	73.7
22	木	33.8	23.9	0.6	7.0	29.0	30.2	43.2	4.5	0.04	ND	79.6
23	金	34.7	24.0	0.4	6.9	30.5	30.6	54.8	4.8	0.03	ND	81.7
24	土	30.9	24.7	0.5	7.0	30.9	31.4	43.6	4.8	0.02	ND	84.1
25	日	27.9	25.2	0.6	7.0	32.2	37.2	38.0	4.9	0.08	ND	85.4
26	月	32.6	24.7	0.9	6.9	31.8	35.4	50.0	5.1	0.10	ND	81.8
27	火	31.8	24.0	1.1	6.9	25.6	27.5	54.4	4.9	0.06	ND	76.3
28	水	28.3	22.7	1.0	6.8	26.8	27.9	44.8	3.9	0.05	ND	74.0
29	木	24.2	23.0	1.0	6.8	26.6	28.3	40.4	4.3	0.06	ND	75.3
30	金	32.1	22.6	0.8	6.9	26.2	28.1	51.6	4.5	0.04	ND	76.0
31	土	30.8	24.0	0.4	7.0	29.4	28.9	43.2	5.0	0.04	ND	82.5
最大値		34.7	25.2	1.5	7.0	32.2	37.2	70.0	14.6	0.10	0.03	113.3
最小値		23.3	19.6	0.4	6.5	17.3	18.3	38.0	3.9	ND	ND	52.9
平均値		29.1	22.4	0.8	6.8	25.8	27.9	51.2	7.3	0.04	ND	85.1

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所