

水質試験結果表(取水分)

2022年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	日	13.1	13.0	4.8	6.6	22.2	21.9	39.6	4.5	0.07	ND	58.5
2	月	12.0	12.2	10.0	6.5	20.6	22.5	42.4	4.0	0.43	0.01	59.1
3	火	14.4	11.5	4.0	6.8	22.5	22.9	43.2	5.3	0.24	ND	63.6
4	水	19.4	13.0	4.5	6.7	24.5	24.9	52.4	5.6	0.25	ND	67.3
5	木	21.8	14.0	5.2	6.7	23.8	22.5	40.0	4.3	0.29	ND	69.3
6	金	23.7	15.0	5.3	6.6	24.8	25.9	48.0	5.4	0.35	0.01	69.5
7	土	24.2	15.2	3.3	6.6	25.0	26.5	42.8	4.0	0.21	0.01	71.5
8	日	21.4	15.5	4.9	6.7	25.0	28.1	40.8	4.3	0.33	0.01	72.9
9	月	13.9	15.1	10.4	6.5	24.0	32.2	52.0	3.8	0.63	0.02	71.8
10	火	16.8	12.8	10.9	6.6	25.7	26.5	48.4	3.9	0.33	0.03	72.2
11	水	18.1	14.8	6.3	6.7	25.3	25.7	51.6	4.7	0.39	0.02	72.0
12	木	25.0	15.0	6.0	6.7	25.0	26.9	58.4	4.6	0.25	ND	72.4
13	金	24.5	15.6	7.8	6.8	24.4	27.1	54.0	4.7	0.40	0.02	71.5
14	土	16.6	16.0	5.1	6.6	23.6	24.9	42.4	4.4	0.30	0.01	68.3
15	日	16.2	15.0	6.7	6.6	22.1	24.1	42.4	4.3	0.37	0.01	62.6
16	月	17.1	14.3	7.1	6.8	23.6	24.9	46.4	5.2	0.48	0.02	66.5
17	火	16.6	14.8	5.2	6.6	25.5	27.3	46.4	5.6	0.32	ND	71.9
18	水	20.0	14.8	5.7	6.6	25.7	34.6	33.6	4.9	0.30	0.01	74.4
19	木	24.4	15.7	4.8	6.5	26.0	30.4	51.2	4.4	0.36	ND	76.5
20	金	19.0	16.0	4.7	6.6	27.4	30.6	54.4	5.0	0.31	0.01	78.5
21	土	21.6	16.0	4.4	6.7	26.3	32.0	47.6	6.4	0.29	0.01	80.0
22	日	25.0	16.0	4.7	6.8	26.9	30.2	54.4	5.3	0.30	0.01	80.3
23	月	25.6	19.0	5.5	6.6	25.1	29.9	55.2	5.2	0.37	0.03	80.2
24	火	24.2	17.8	5.3	6.6	28.2	31.6	52.4	5.1	0.36	ND	81.5
25	水	25.9	18.5	5.2	6.5	28.7	30.2	54.4	4.8	0.37	0.01	82.0
26	木	25.8	18.6	4.1	6.7	29.0	29.3	52.4	5.1	0.34	0.01	81.5
27	金	21.8	18.8	4.6	6.7	26.6	27.7	49.6	4.8	0.37	0.01	77.2
28	土	25.6	18.0	3.2	6.8	24.9	26.3	48.0	4.5	0.19	0.01	73.1
29	日	25.3	18.5	2.1	6.6	27.6	29.5	42.4	5.1	0.17	ND	82.0
30	月	27.4	18.8	3.6	6.8	28.8	29.3	44.0	4.9	0.31	0.01	80.4
31	火	20.4	18.6	5.9	6.8	28.4	30.6	47.6	4.6	0.43	0.01	79.5
最大値		27.4	19.0	10.9	6.8	29.0	34.6	58.4	6.4	0.63	0.03	82.0
最小値		12.0	11.5	2.1	6.5	20.6	21.9	33.6	3.8	0.07	ND	58.5
平均値		20.9	15.7	5.5	6.7	25.4	27.6	47.7	4.8	0.33	0.01	73.2

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2022年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	日	13.1	13.4	0.4	6.4	21.9	20.9	35.2	7.1	0.01	ND	62.2
2	月	12.0	12.7	0.4	6.4	18.5	23.7	25.6	6.6	0.01	ND	63.5
3	火	14.4	13.0	0.3	6.6	21.6	23.3	43.6	6.0	0.01	ND	68.2
4	水	19.4	13.6	0.4	6.6	23.2	24.5	28.0	7.6	0.01	ND	71.1
5	木	21.8	14.4	0.5	6.6	22.5	24.7	34.8	6.2	0.01	ND	73.4
6	金	23.7	15.4	0.2	6.7	23.7	27.1	40.8	6.1	0.01	ND	73.6
7	土	24.2	16.0	0.6	6.7	23.1	27.5	38.0	6.7	0.01	ND	76.2
8	日	21.4	16.1	0.6	6.6	24.0	28.1	39.6	6.9	0.02	ND	77.8
9	月	13.9	15.7	0.6	6.6	23.7	31.2	44.4	6.9	0.02	ND	76.4
10	火	16.8	13.5	1.0	6.6	23.2	28.1	31.2	7.0	0.04	ND	77.5
11	水	18.1	15.2	0.7	6.7	23.3	26.9	46.4	6.2	0.03	ND	77.1
12	木	25.0	15.4	0.7	6.7	23.6	27.1	33.6	6.5	0.03	ND	76.9
13	金	24.5	16.0	0.6	6.5	23.6	27.9	41.2	6.6	0.03	ND	76.3
14	土	16.6	16.5	0.4	6.7	22.5	25.5	34.8	5.5	0.02	ND	72.9
15	日	16.2	15.5	0.8	6.5	20.1	22.1	37.6	5.4	ND	ND	67.4
16	月	17.1	15.0	0.7	6.5	22.4	26.5	40.0	5.5	0.03	ND	71.4
17	火	16.6	15.3	0.8	6.5	22.2	26.3	42.4	6.0	0.03	ND	74.4
18	水	20.0	15.0	0.9	6.5	22.0	30.8	36.0	5.0	0.04	ND	75.9
19	木	24.4	16.3	0.4	6.5	23.9	28.3	42.4	6.7	0.03	ND	78.7
20	金	19.0	16.7	0.8	6.5	24.5	30.8	34.8	6.5	0.03	ND	81.4
21	土	21.6	16.5	0.3	6.8	24.1	30.4	30.4	6.0	0.02	ND	82.5
22	日	25.0	16.5	0.4	6.7	24.1	30.6	43.2	5.5	0.03	0.01	83.0
23	月	25.6	18.3	0.4	6.7	24.5	30.2	47.6	5.1	0.02	0.01	82.6
24	火	24.2	18.6	0.7	6.5	25.9	31.2	42.0	6.7	ND	ND	83.8
25	水	25.9	19.3	1.0	6.5	27.0	30.4	48.0	6.4	0.02	ND	85.2
26	木	25.8	19.5	0.7	6.5	27.1	29.3	38.8	5.5	0.02	ND	84.0
27	金	21.8	19.6	0.8	6.6	26.4	29.7	45.2	6.7	0.02	ND	83.0
28	土	25.6	18.9	0.4	6.8	24.0	26.3	40.4	5.6	0.02	ND	77.9
29	日	25.3	19.3	0.3	6.7	25.8	29.3	30.4	5.5	0.02	ND	82.6
30	月	27.4	19.9	0.5	6.8	26.7	31.0	36.0	5.7	0.01	ND	82.0
31	火	20.4	19.4	0.7	6.8	27.0	28.7	36.4	5.5	0.02	ND	82.5
最大値		27.4	19.9	1.0	6.8	27.1	31.2	48.0	7.6	0.04	0.01	85.2
最小値		12.0	12.7	0.2	6.4	18.5	20.9	25.6	5.0	ND	ND	62.2
平均値		20.9	16.3	0.6	6.6	23.7	27.7	38.3	6.2	0.02	ND	76.8

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 濁度およびpH以外の基準については参考値とする。
 本試験結果はJIS.K.0101(工業用水試験法)による。