

水質試験結果表(取水分)

2022年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日											
1	金	34.4	24.2	2.3	6.6	29.5	32.4	62.4	5.0	0.21	0.01	84.2
2	土	32.1	24.0	0.9	6.7	29.2	29.1	49.6	4.6	0.13	ND	83.9
3	日	27.2	24.8	1.2	6.8	28.7	31.2	46.4	4.4	0.15	ND	83.5
4	月	28.8	22.8	37.3	6.6	16.8	29.7	78.4	3.2	0.78	0.10	52.4
5	火	28.6	22.3	12.9	6.7	23.8	25.9	56.0	4.3	0.27	0.10	70.1
6	水	29.1	22.6	7.0	6.8	26.3	29.3	61.2	5.5	0.20	0.01	76.0
7	木	31.5	23.0	6.1	6.8	27.6	28.3	69.2	4.4	0.35	0.03	78.9
8	金	29.7	23.5	4.7	6.6	28.2	29.5	58.8	4.4	0.32	0.01	82.4
9	土	29.4	23.8	1.3	6.9	30.0	31.2	62.4	5.0	0.15	ND	88.0
10	日	26.2	23.5	6.2	6.8	22.5	24.3	44.0	4.0	0.34	0.01	67.3
11	月	30.2	22.7	8.6	6.8	26.7	27.9	65.6	5.2	0.60	ND	73.8
12	火	27.8	23.9	7.8	6.8	25.9	29.7	55.2	4.7	0.18	0.02	74.1
13	水	25.7	21.7	20.8	6.7	19.2	22.1	69.6	4.0	0.48	0.04	58.0
14	木	27.1	21.2	8.2	6.8	25.0	28.9	54.8	4.6	0.43	0.04	72.0
15	金	26.3	21.2	11.2	6.7	22.5	25.9	58.4	4.1	0.51	0.03	65.2
16	土	29.0	20.9	1.9	6.8	24.4	31.6	56.8	6.0	0.17	0.01	72.5
17	日	29.8	21.6	1.5	6.9	26.4	31.4	54.4	5.2	0.14	ND	77.4
18	月	26.7	21.7	2.8	6.8	27.7	29.7	58.4	4.9	0.27	ND	79.6
19	火	25.7	21.6	5.1	6.8	27.3	29.9	62.4	4.9	0.32	ND	77.8
20	水	30.9	20.6	10.8	6.7	21.9	29.5	58.0	3.3	0.34	0.04	62.0
21	木	26.7	20.4	5.5	6.7	23.7	27.9	56.8	4.7	0.33	0.01	68.9
22	金	24.2	20.6	10.2	6.7	23.2	28.3	60.4	5.3	0.49	0.07	64.4
23	土	24.5	20.1	2.1	6.9	23.3	24.1	64.0	5.0	0.16	ND	67.3
24	日	27.5	20.1	2.2	6.8	23.4	27.5	55.2	4.5	0.16	ND	66.8
25	月	30.3	21.4	3.6	6.8	24.2	26.3	57.6	4.4	0.26	ND	65.8
26	火	32.1	21.6	3.5	6.7	25.4	27.3	47.2	4.4	0.22	ND	71.1
27	水	30.3	22.4	3.3	6.9	25.7	27.1	51.2	4.5	0.13	0.01	70.2
28	木	32.1	22.5	4.8	6.8	24.7	25.7	40.4	4.4	0.27	0.03	68.1
29	金	33.8	23.2	3.4	6.8	25.7	26.1	48.4	4.4	0.14	0.01	71.0
30	土	33.7	23.9	2.3	6.9	24.6	28.7	53.2	4.3	0.25	0.01	72.5
31	日	34.3	24.2	1.5	6.6	24.7	26.3	54.0	3.0	0.18	ND	71.6
最大値		34.4	24.8	37.3	6.9	30.0	32.4	78.4	6.0	0.78	0.10	88.0
最小値		24.2	20.1	0.9	6.6	16.8	22.1	40.4	3.0	0.13	ND	52.4
平均値		29.2	22.3	6.5	6.8	25.1	28.2	57.1	4.5	0.29	0.02	72.2

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2022年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μS/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	金	34.4	24.4	0.3	6.6	28.4	31.6	55.2	6.5	0.04	ND	87.0
2	土	32.1	24.1	0.2	6.8	28.2	29.9	54.4	6.1	0.02	ND	85.3
3	日	27.2	25.0	0.1	6.8	27.6	30.6	52.8	5.4	0.02	ND	85.4
4	月	28.8	23.1	0.7	6.5	18.7	25.5	51.2	7.4	0.03	ND	69.9
5	火	28.6	22.2	1.1	6.5	21.4	25.3	44.8	7.3	0.02	ND	75.4
6	水	29.1	22.4	0.5	6.8	24.8	31.4	60.0	6.6	0.01	ND	81.3
7	木	31.5	23.0	0.5	6.7	26.4	29.5	52.0	7.0	0.02	ND	83.8
8	金	29.7	23.6	0.2	6.5	25.7	29.9	51.2	7.3	0.03	ND	83.7
9	土	29.4	23.9	0.3	6.8	27.7	32.4	49.2	7.3	0.04	ND	89.7
10	日	26.2	23.5	0.2	6.7	23.0	28.3	45.6	7.4	0.01	ND	80.2
11	月	30.2	22.7	0.8	6.7	23.2	28.5	63.6	6.3	0.01	ND	76.5
12	火	27.8	23.8	0.2	6.6	23.2	31.0	48.8	5.5	0.01	ND	78.6
13	水	25.7	21.8	1.9	6.4	17.2	21.5	41.6	6.6	0.03	ND	64.9
14	木	27.1	20.8	0.9	6.7	23.3	27.3	50.8	7.0	0.04	ND	78.2
15	金	26.3	21.3	1.1	6.6	22.4	24.5	40.0	6.9	0.04	ND	74.7
16	土	29.0	20.8	0.3	6.7	23.3	29.9	46.0	6.4	0.02	ND	77.0
17	日	29.8	21.3	0.3	6.7	24.6	31.0	41.6	6.4	0.01	ND	79.7
18	月	26.7	21.5	0.2	6.7	25.4	30.2	45.2	6.5	0.01	ND	82.0
19	火	25.7	21.3	0.6	6.6	26.1	31.2	54.8	6.8	0.03	ND	81.2
20	水	30.9	20.7	0.9	6.7	20.9	27.3	49.2	6.7	0.03	ND	70.1
21	木	26.7	20.5	1.0	6.7	22.7	27.7	51.2	5.4	0.05	ND	72.7
22	金	24.2	20.3	0.7	6.5	23.0	26.1	49.6	6.0	0.02	ND	72.6
23	土	24.5	20.0	0.8	6.9	23.1	24.9	61.2	6.1	0.01	ND	74.0
24	日	27.5	20.2	0.5	6.8	21.0	27.5	51.6	5.7	0.01	ND	68.7
25	月	30.3	21.4	0.2	6.6	22.1	26.3	58.0	5.5	0.03	ND	70.1
26	火	32.1	21.6	0.2	6.6	23.2	27.7	41.2	4.9	0.01	ND	73.7
27	水	30.3	22.6	0.3	6.7	23.2	25.1	46.0	4.9	0.02	ND	72.2
28	木	32.1	22.7	0.5	6.6	22.1	25.7	33.6	5.4	0.01	ND	71.6
29	金	33.8	23.4	0.3	6.6	24.1	25.9	48.0	5.1	0.03	ND	73.0
30	土	33.7	23.9	0.1	6.7	22.5	25.7	53.2	5.7	0.01	ND	74.2
31	日	34.3	24.3	0.0	6.6	22.8	25.5	48.0	5.3	0.02	ND	73.1
最大値		34.4	25.0	1.9	6.9	28.4	32.4	63.6	7.4	0.05	ND	89.7
最小値		24.2	20.0	0.0	6.4	17.2	21.5	33.6	4.9	0.01	ND	64.9
平均値		29.2	22.3	0.5	6.7	23.6	27.9	49.7	6.2	0.02	ND	76.8

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所