

### 水質試験結果表(取水分)

2022年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	月	34.0	24.0	2.2	6.5	24.0	26.7	52.4	3.9	0.25	0.01	71.7
2	火	35.5	24.7	3.3	6.6	26.0	26.5	40.4	4.5	0.18	ND	76.1
3	水	31.3	24.4	2.6	6.6	25.5	27.7	52.4	3.7	0.26	0.02	72.1
4	木	28.9	23.6	3.2	6.6	25.3	27.9	48.4	4.7	0.19	ND	71.5
5	金	28.6	19.7	98.4	6.8	33.6	37.0	230.8	4.9	0.90	0.47	89.1
6	土	31.3	21.1	15.3	6.9	22.7	23.3	72.8	4.4	0.73	0.11	66.2
7	日	30.6	22.7	8.0	6.8	23.7	24.3	52.0	4.7	0.17	0.01	69.3
8	月	31.4	23.0	13.2	6.7	25.2	28.3	60.8	4.9	0.68	0.01	69.2
9	火	33.6	23.0	12.3	6.8	25.4	28.3	60.8	4.4	0.36	0.04	70.1
10	水	30.6	23.0	8.4	6.9	24.3	28.3	52.8	4.8	0.45	0.03	69.9
11	木	33.8	23.0	4.2	7.0	25.8	30.6	42.8	4.4	0.28	0.01	72.6
12	金	33.2	23.9	4.6	6.9	25.8	26.9	50.8	4.4	0.29	ND	72.1
13	土	33.4	24.1	1.5	6.9	26.9	27.1	54.0	4.1	0.11	ND	76.1
14	日	27.1	24.0	2.0	6.9	28.2	29.7	175.2	5.1	0.16	ND	81.0
15	月	27.0	23.4	11.9	6.8	25.8	29.9	62.8	4.1	0.44	0.03	75.0
16	火	33.7	23.8	6.5	6.8	27.6	30.4	65.6	3.8	0.33	0.01	77.9
17	水	25.1	23.0	5.5	6.9	28.2	32.0	70.8	3.9	0.11	0.01	79.4
18	木	23.6	22.2	4.9	7.0	26.3	28.1	52.4	4.1	0.29	ND	74.0
19	金	26.5	21.7	14.9	6.9	22.6	24.1	49.2	4.1	0.38	0.04	63.6
20	土	27.9	22.0	1.8	7.0	26.0	25.7	53.2	4.5	0.14	ND	72.2
21	日	27.3	22.0	25.5	7.0	21.1	22.7	73.2	3.8	0.85	0.10	60.6
22	月	31.3	21.7	20.7	6.9	23.4	25.9	74.4	3.7	0.96	0.12	64.9
23	火	32.3	22.4	7.2	6.9	25.2	27.1	53.2	4.5	0.46	0.04	69.3
24	水	27.6	22.2	6.6	6.9	26.0	27.1	57.6	4.8	0.42	0.01	70.9
25	木	26.3	22.0	4.9	7.0	26.6	26.3	46.4	4.6	0.35	0.02	70.9
26	金	26.5	21.4	5.9	6.9	24.7	26.7	50.4	4.3	0.34	0.02	68.3
27	土	25.8	21.7	1.9	7.1	25.4	26.1	60.0	4.6	0.14	ND	72.2
28	日	25.4	21.6	2.1	7.1	25.7	26.1	49.2	3.8	0.16	ND	72.9
29	月	26.6	21.4	2.7	6.9	26.0	28.5	49.2	3.9	0.20	0.01	71.1
30	火	27.6	21.7	4.1	7.0	26.2	28.1	50.4	3.4	0.20	ND	70.3
31	水	31.3	22.0	10.7	6.9	24.9	25.7	52.8	4.0	0.31	0.04	66.8
最大値		35.5	24.7	98.4	7.1	33.6	37.0	230.8	5.1	0.96	0.47	89.1
最小値		23.6	19.7	1.5	6.5	21.1	22.7	40.4	3.4	0.11	ND	60.6
平均値		29.5	22.6	10.2	6.9	25.6	27.5	65.1	4.3	0.36	0.04	71.8

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2022年8月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	34.0	25.0	0.1	6.6	23.4	25.7	46.0	5.6	0.02	ND	73.1
2	火	35.5	24.8	0.2	6.6	24.2	27.3	43.2	6.5	0.08	ND	74.1
3	水	31.3	24.4	0.3	6.6	24.8	26.9	49.2	5.9	0.03	ND	74.1
4	木	28.9	23.5	0.3	6.5	24.3	26.7	41.2	6.1	0.01	ND	73.3
5	金	28.6	19.6	1.7	6.5	32.7	42.4	72.8	12.4	0.05	ND	116.5
6	土	31.3	21.0	0.1	6.6	19.7	23.3	43.6	8.2	0.02	ND	77.3
7	日	30.6	22.1	0.0	6.8	21.3	26.7	62.8	7.3	ND	ND	69.2
8	月	31.4	22.7	0.3	6.6	22.6	26.9	50.0	6.9	0.01	ND	76.6
9	火	33.6	22.8	0.3	6.6	22.8	27.5	54.0	6.4	0.01	ND	77.1
10	水	30.6	22.9	0.6	6.8	22.9	27.1	35.6	7.8	0.01	ND	75.9
11	木	33.8	23.0	0.4	6.8	23.3	27.5	39.6	7.2	0.01	ND	78.5
12	金	33.2	23.7	0.3	6.9	24.0	27.1	39.2	6.6	0.01	ND	77.1
13	土	33.4	24.0	0.1	6.8	24.9	29.7	48.8	5.5	ND	ND	79.6
14	日	27.1	24.0	0.1	6.7	25.5	29.9	37.2	6.8	ND	ND	82.0
15	月	27.0	23.3	0.4	6.6	25.5	31.0	62.8	6.8	0.01	ND	83.8
16	火	33.7	23.4	0.3	6.8	25.3	28.3	47.6	6.5	0.01	ND	82.3
17	水	25.1	23.0	1.1	6.7	26.3	30.4	43.6	7.1	0.01	ND	83.3
18	木	23.6	22.0	1.2	6.8	26.5	28.7	52.4	6.5	0.01	ND	81.0
19	金	26.5	22.0	1.6	6.7	19.5	26.7	33.6	6.9	0.02	ND	70.7
20	土	27.9	22.0	0.1	6.9	23.1	25.5	40.4	7.0	0.01	ND	76.4
21	日	27.3	21.8	0.2	6.7	19.8	24.3	40.4	7.7	ND	ND	71.9
22	月	31.3	22.1	0.5	6.7	19.5	23.5	48.8	6.7	0.01	ND	69.4
23	火	32.3	22.3	0.6	6.7	22.9	27.3	48.0	6.3	0.03	ND	74.3
24	水	27.6	22.2	1.0	6.9	24.0	27.3	39.6	6.6	0.05	ND	75.7
25	木	26.3	22.1	0.7	6.9	23.6	27.5	44.4	6.7	0.02	ND	75.6
26	金	26.5	21.3	0.6	6.7	22.8	26.9	41.6	6.2	0.03	ND	72.9
27	土	25.8	21.9	0.5	7.0	23.6	27.3	55.2	5.1	0.01	ND	75.4
28	日	25.4	21.6	0.2	6.9	24.4	27.1	46.4	5.5	0.01	ND	75.4
29	月	26.6	21.7	0.5	6.8	24.5	27.9	45.6	5.7	0.02	ND	72.7
30	火	27.6	21.9	0.6	6.7	23.4	30.2	46.4	5.9	0.01	ND	72.9
31	水	31.3	22.0	0.6	6.8	22.0	26.1	42.8	6.3	0.02	ND	70.7
最大値		35.5	25.0	1.7	7.0	32.7	42.4	72.8	12.4	0.08	ND	116.5
最小値		23.6	19.6	0.0	6.5	19.5	23.3	33.6	5.1	ND	ND	69.2
平均値		29.5	22.6	0.5	6.7	23.6	27.8	46.5	6.7	0.02	ND	77.1

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 濁度およびpH以外の基準については参考値とする。  
 本試験結果はJIS.K.0101(工業用水試験法)による。