

水質試験結果表(取水分)

2022年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	25.1	19.6	1.8	7.0	26.7	28.3	52.8	6.2	0.17	ND	75.7
2	日	24.3	20.1	1.5	6.9	28.5	30.4	56.0	6.5	0.18	ND	82.6
3	月	24.5	20.4	6.8	6.9	30.2	32.4	67.6	6.2	0.41	0.01	82.6
4	火	28.6	19.8	3.9	7.1	28.8	29.9	52.8	5.7	0.28	0.01	83.7
5	水	19.5	20.0	3.3	7.0	29.9	33.0	46.4	6.4	0.28	0.01	85.2
6	木	17.5	18.4	3.1	7.0	32.0	35.4	59.2	6.0	0.28	0.01	91.0
7	金	14.8	17.3	3.2	7.0	35.1	37.0	68.4	7.6	0.09	ND	97.6
8	土	20.2	16.9	3.0	7.1	27.1	28.1	45.2	4.9	0.20	ND	79.0
9	日	16.7	17.0	1.2	7.1	27.4	28.1	43.2	5.7	0.13	ND	80.8
10	月	18.4	17.0	1.2	7.1	28.4	29.1	42.8	6.0	0.15	ND	82.8
11	火	14.9	16.8	7.6	7.0	23.7	24.3	45.2	5.0	0.21	0.01	72.0
12	水	18.5	16.3	4.2	6.9	26.5	28.5	41.6	4.9	0.22	0.02	76.2
13	木	19.2	16.1	2.6	7.0	28.3	29.5	45.6	5.6	0.16	ND	80.9
14	金	18.1	17.0	2.7	6.9	28.8	32.2	46.0	5.0	0.21	ND	82.4
15	土	20.7	17.0	0.8	7.2	29.9	32.6	53.2	6.4	0.10	ND	87.4
16	日	21.2	18.0	0.7	7.2	28.8	29.7	46.0	6.0	0.12	ND	86.1
17	月	20.2	18.7	2.9	7.0	30.1	30.4	55.6	6.2	0.23	ND	83.9
18	火	22.4	17.6	2.1	7.0	31.3	32.4	42.8	5.6	0.16	ND	88.8
19	水	18.2	16.3	1.6	7.1	33.4	36.0	62.8	5.9	0.14	ND	95.2
20	木	16.2	15.4	1.2	7.1	34.8	35.0	60.4	6.8	0.10	ND	99.1
21	金	17.6	15.0	1.5	7.2	34.3	36.2	58.4	8.0	0.15	ND	98.1
22	土	20.7	15.7	0.7	7.1	36.1	36.2	52.4	7.0	0.10	ND	99.1
23	日	18.1	16.5	1.1	7.1	36.0	39.6	56.0	7.0	0.11	ND	101.1
24	月	17.7	16.3	1.9	7.1	35.6	37.2	54.8	5.7	0.19	ND	97.3
25	火	21.2	16.0	1.1	7.2	37.0	38.6	49.2	6.0	0.14	ND	101.3
26	水	15.1	15.9	1.1	6.8	36.7	39.2	63.2	7.1	0.17	ND	103.7
27	木	14.5	14.3	0.9	6.9	37.6	40.0	66.4	6.7	0.12	ND	104.7
28	金	16.2	14.2	0.9	7.1	37.0	38.8	66.4	6.7	0.10	ND	102.7
29	土	21.4	14.7	0.3	7.0	37.5	41.8	58.4	6.0	0.08	ND	105.7
30	日	14.2	14.9	0.2	7.0	38.3	41.2	59.6	6.8	0.09	ND	107.5
31	月	14.6	14.1	0.7	7.0	37.7	42.2	63.6	6.2	0.11	ND	105.5
最大値		28.6	20.4	7.6	7.2	38.3	42.2	68.4	8.0	0.41	0.02	107.5
最小値		14.2	14.1	0.2	6.8	23.7	24.3	41.6	4.9	0.08	ND	72.0
平均値		19.0	16.9	2.1	7.0	32.0	34.0	54.3	6.2	0.17	ND	91.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2022年10月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	25.1	19.8	0.0	6.8	24.7	27.3	47.2	6.7	0.01	ND	77.7
2	日	24.3	20.0	0.0	6.8	26.7	29.5	44.4	7.8	0.02	ND	82.0
3	月	24.5	20.6	0.8	6.8	29.1	32.0	56.0	8.2	0.02	ND	86.9
4	火	28.6	19.9	0.9	7.0	27.6	31.6	49.6	7.8	0.04	ND	86.3
5	水	19.5	20.2	0.7	6.9	27.1	31.2	37.2	8.6	0.04	ND	84.4
6	木	17.5	18.6	1.0	6.9	30.4	33.4	48.4	7.7	0.05	ND	92.3
7	金	14.8	17.2	1.1	6.9	32.9	36.4	40.0	8.2	0.04	ND	99.9
8	土	20.2	17.0	0.5	6.9	25.9	31.2	44.0	7.2	0.04	ND	84.9
9	日	16.7	17.0	0.4	6.9	24.8	28.7	36.0	5.9	0.03	ND	82.0
10	月	18.4	17.0	0.4	7.1	27.3	30.6	41.2	6.3	0.04	ND	84.2
11	火	14.9	16.9	1.4	6.8	21.9	25.9	44.8	6.1	0.06	ND	77.5
12	水	18.5	16.3	0.9	6.7	24.6	27.5	34.8	6.8	0.04	ND	77.7
13	木	19.2	16.2	0.9	6.8	26.2	29.7	41.6	6.5	0.06	ND	82.3
14	金	18.1	17.0	0.8	6.9	27.8	30.8	39.6	6.9	0.04	ND	83.9
15	土	20.7	17.0	0.2	7.0	28.5	30.4	34.8	8.1	0.03	ND	89.3
16	日	21.2	18.1	0.3	7.1	28.8	29.7	38.8	7.3	0.03	ND	87.7
17	月	20.2	18.8	0.3	6.9	29.0	31.2	52.8	7.4	0.04	ND	86.1
18	火	22.4	17.8	0.9	6.9	28.7	32.2	48.0	6.9	0.05	ND	88.1
19	水	18.2	16.4	1.0	7.0	32.6	33.8	51.2	7.0	0.08	ND	95.5
20	木	16.2	15.5	0.9	7.1	34.5	35.8	56.8	7.6	0.04	ND	100.2
21	金	17.6	15.1	1.0	7.1	34.0	36.0	56.4	8.9	0.07	ND	98.6
22	土	20.7	15.8	0.5	7.1	35.0	37.2	42.8	8.4	0.07	ND	99.4
23	日	18.1	16.7	0.6	7.2	35.5	37.0	37.2	8.2	0.05	ND	101.9
24	月	17.7	16.6	0.5	7.2	36.2	37.6	56.8	8.0	0.07	ND	99.8
25	火	21.2	16.0	0.7	7.2	35.4	38.4	48.0	6.9	0.08	ND	101.7
26	水	15.1	16.2	0.7	6.9	36.5	39.8	65.6	7.6	0.08	ND	104.5
27	木	14.5	14.5	0.8	7.0	36.9	42.0	52.8	7.0	0.09	ND	105.4
28	金	16.2	14.4	0.7	7.1	36.8	38.8	58.8	6.0	0.07	ND	104.5
29	土	21.4	14.8	0.1	7.2	37.8	42.6	55.6	6.4	0.07	ND	107.1
30	日	14.2	15.1	0.1	7.2	38.4	43.2	58.4	6.9	0.04	ND	106.7
31	月	14.6	15.0	0.4	7.4	37.0	41.6	46.4	6.7	0.09	ND	105.5
最大値		28.6	20.6	1.4	7.4	38.4	43.2	65.6	8.9	0.09	ND	107.1
最小値		14.2	14.4	0.0	6.7	21.9	25.9	34.8	5.9	0.01	ND	77.5
平均値		19.0	17.0	0.6	7.0	30.9	34.0	47.3	7.3	0.05	ND	92.4

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所