

### 水質試験結果表(取水分)

2024年2月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	7.9	7.9	1.8	7.1	25.2	26.3	32.4	8.3	0.08	ND	75.9
2	金	2.8	7.6	2.4	6.9	23.2	26.9	40.8	7.8	0.08	ND	72.1
3	土	5.0	7.8	1.3	7.1	26.4	26.3	35.2	6.8	0.07	ND	72.0
4	日	10.0	8.3	1.3	7.2	26.6	26.5	34.0	7.4	0.09	ND	71.5
5	月	3.9	8.4	1.7	7.0	25.8	25.5	36.8	6.7	0.11	ND	72.3
6	火	6.0	7.3	3.3	7.0	23.2	26.7	43.2	7.6	0.12	ND	76.8
7	水	6.5	8.0	2.1	7.1	24.0	28.5	50.4	6.4	0.13	ND	73.6
8	木	4.2	8.4	1.7	7.0	24.7	26.5	35.6	6.1	0.11	ND	73.0
9	金	7.3	8.3	1.8	7.2	24.1	26.1	37.2	6.3	0.07	ND	71.1
10	土	4.9	8.6	0.7	7.3	26.3	27.9	40.4	6.5	0.06	ND	70.6
11	日	9.5	7.8	1.5	7.2	26.1	29.1	41.6	10.0	0.13	ND	92.5
12	月	6.0	8.5	2.2	7.0	24.0	34.6	44.0	13.6	0.24	ND	104.5
13	火	8.1	8.7	1.8	7.0	26.1	26.1	48.4	6.7	0.06	ND	71.0
14	水	10.0	9.1	2.0	7.2	23.7	26.7	44.4	6.3	0.04	ND	70.8
15	木	13.2	9.5	1.5	7.1	24.0	26.1	40.0	6.2	0.07	ND	71.0
16	金	6.5	10.4	11.8	7.0	23.5	25.3	54.0	8.2	0.23	0.08	74.0
17	土	4.2	9.3	2.2	7.2	23.6	24.3	41.6	7.1	0.12	ND	65.7
18	日	14.2	10.0	1.9	7.2	30.7	33.6	52.0	7.3	0.10	ND	86.0
19	月	17.3	11.0	2.4	7.2	23.7	26.3	40.0	6.9	0.14	ND	70.8
20	火	11.1	11.9	17.3	6.9	20.3	24.1	58.0	10.7	0.11	ND	82.7
21	水	7.4	11.6	17.8	6.9	27.9	31.2	84.4	11.2	0.35	0.03	95.7
22	木	6.6	10.8	31.6	6.9	19.8	29.1	84.4	8.6	0.61	0.06	75.1
23	金	6.1	10.4	5.4	7.1	29.5	33.2	41.6	10.6	0.32	0.02	97.7
24	土	9.7	10.5	2.9	7.1	32.3	39.6	70.0	11.2	0.18	ND	114.6
25	日	4.2	10.7	3.1	7.1	33.0	36.6	52.8	12.0	0.23	ND	112.2
26	月	8.8	10.4	4.9	7.0	31.8	36.8	60.0	12.1	0.29	ND	111.8
27	火	3.0	9.6	3.7	7.0	23.3	25.9	39.2	5.9	0.14	ND	68.0
28	水	11.9	9.7	3.8	7.0	24.9	27.3	41.2	8.0	0.25	0.01	73.5
29	木	5.6	9.9	3.3	7.0	23.2	25.3	48.0	6.2	0.15	0.01	67.9
最大値		17.3	11.9	31.6	7.3	33.0	39.6	84.4	13.6	0.61	0.08	114.6
最小値		2.8	7.3	0.7	6.9	19.8	24.1	32.4	5.9	0.04	ND	65.7
平均値		7.7	9.3	4.8	7.1	25.5	28.6	47.3	8.2	0.16	0.01	80.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

