

水質試験結果表(取水分)

2024年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	水	17.6	16.0	3.3	7.0	27.5	28.3	40.0	7.0	0.08	ND	74.8
2	木	20.1	14.4	3.9	7.0	27.4	28.3	41.6	7.2	0.08	ND	73.9
3	金	21.8	15.5	1.4	6.8	28.6	28.9	51.2	7.3	0.03	ND	77.0
4	土	22.1	16.2	1.7	6.9	32.1	29.1	48.4	7.3	0.14	ND	78.4
5	日	25.0	17.0	16.0	7.0	32.1	30.2	45.2	8.1	0.16	ND	79.7
6	月	23.1	17.5	1.6	7.0	31.5	30.4	43.6	8.0	0.15	ND	81.1
7	火	16.8	16.6	4.0	6.8	29.9	28.3	42.8	7.9	0.20	0.01	75.8
8	水	14.7	15.6	6.1	6.9	26.6	27.7	48.0	7.7	0.26	0.02	73.0
9	木	12.8	14.8	4.8	6.9	28.2	29.3	38.0	6.4	0.26	0.01	77.0
10	金	18.7	14.5	4.4	6.9	27.5	30.8	48.8	7.4	0.14	0.02	77.9
11	土	23.1	16.0	2.3	7.0	28.9	28.9	52.8	8.0	0.15	ND	77.7
12	日	23.1	17.1	3.1	6.9	29.2	28.7	48.8	7.6	0.20	0.01	78.6
13	月	15.2	16.5	7.1	7.0	28.3	26.5	47.2	8.1	0.30	0.01	71.3
14	火	17.0	14.5	8.7	6.9	21.1	22.9	46.0	5.5	0.30	0.04	59.6
15	水	22.5	16.2	5.7	6.9	23.7	26.3	46.0	6.0	0.27	0.02	67.8
16	木	24.9	16.5	4.7	7.0	25.7	27.3	49.6	6.8	0.24	0.02	71.8
17	金	20.8	15.7	5.2	7.0	25.8	26.7	43.2	5.5	0.24	0.03	72.0
18	土	23.4	16.6	2.3	6.8	28.9	27.5	42.8	6.5	0.14	ND	74.6
19	日	19.7	17.5	2.3	6.9	30.0	29.3	50.8	8.3	0.17	ND	75.9
20	月	17.8	17.0	4.7	6.9	28.2	28.5	44.8	6.7	0.25	0.01	71.1
21	火	18.8	17.4	4.6	7.0	26.3	28.3	47.2	6.5	0.26	ND	73.4
22	水	23.9	16.5	4.3	6.9	27.0	28.3	49.2	7.1	0.13	ND	74.6
23	木	24.4	17.8	3.6	6.9	27.8	30.2	46.0	6.7	0.23	ND	77.0
24	金	23.1	18.5	3.0	6.8	30.0	31.8	54.0	8.2	0.08	ND	81.6
25	土	23.9	18.6	1.4	7.0	33.0	31.8	58.8	7.6	0.13	ND	84.5
26	日	25.1	18.9	1.5	7.0	34.7	32.0	53.6	6.6	0.16	ND	85.0
27	月	23.7	19.5	2.4	6.9	32.8	30.6	53.6	7.6	0.19	ND	82.7
28	火	17.2	19.3	3.2	7.0	29.1	31.8	52.0	6.9	0.18	ND	81.1
29	水	22.1	17.2	55.0	6.8	14.6	17.1	99.2	3.4	1.03	ND	44.8
30	木	22.6	17.2	7.4	7.0	20.9	22.7	46.0	6.0	0.12	0.01	60.3
31	金	20.9	17.5	3.6	6.8	24.4	25.9	46.4	6.2	0.11	0.01	70.4
最大値		25.1	19.5	55.0	7.0	34.7	32.0	99.2	8.3	1.03	0.04	85.0
最小値		12.8	14.4	1.4	6.8	14.6	17.1	38.0	3.4	0.03	ND	44.8
平均値		20.8	16.8	5.9	6.9	27.8	28.2	49.2	7.0	0.21	0.01	74.3

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2024年5月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	水	17.6	15.6	0.7	6.9	24.6	28.3	49.6	8.4	0.02	ND	73.0
2	木	20.1	14.3	1.0	6.9	25.1	29.3	39.6	8.3	0.02	ND	76.3
3	金	21.8	15.0	0.4	7.0	26.9	31.0	38.8	8.7	0.02	ND	78.6
4	土	22.1	16.5	0.6	7.1	30.2	29.3	44.4	10.1	0.04	ND	79.3
5	日	25.0	17.5	0.6	7.0	32.1	30.8	43.6	10.3	0.06	ND	81.2
6	月	23.1	17.6	0.9	7.0	30.1	31.8	34.0	9.5	0.10	ND	82.5
7	火	16.8	16.5	1.0	6.9	29.9	30.6	52.8	9.5	0.09	ND	81.0
8	水	14.7	15.5	1.5	6.7	23.9	27.3	44.4	9.4	0.01	ND	76.2
9	木	12.8	14.7	1.4	6.8	26.5	28.3	36.0	8.6	0.07	ND	80.1
10	金	18.7	14.2	1.5	6.8	26.8	30.6	52.0	8.4	0.03	ND	80.9
11	土	23.1	16.0	0.8	6.9	27.7	29.5	46.8	9.0	0.04	ND	79.3
12	日	23.1	17.1	0.5	6.9	28.6	30.4	48.4	8.8	0.01	ND	81.2
13	月	15.2	16.4	1.0	6.9	27.6	28.5	49.6	9.3	0.05	ND	78.8
14	火	17.0	14.0	1.9	6.7	19.5	22.1	34.0	7.3	0.05	ND	64.5
15	水	22.5	16.0	1.3	6.7	22.5	26.3	42.0	7.2	0.04	ND	69.9
16	木	24.9	16.0	1.4	6.8	24.1	28.5	43.2	7.9	0.03	ND	74.3
17	金	20.8	15.2	1.6	6.8	24.9	27.5	40.8	7.2	0.04	ND	74.8
18	土	23.4	16.1	0.8	6.8	27.8	28.1	48.4	7.8	0.04	ND	76.3
19	日	19.7	17.0	0.6	6.9	30.3	30.4	31.2	8.8	0.04	ND	78.5
20	月	17.8	16.5	1.0	6.9	27.2	28.5	50.0	8.2	0.05	ND	76.0
21	火	18.8	16.8	1.3	6.8	25.5	28.5	44.0	7.7	0.04	ND	75.4
22	水	23.9	16.0	1.3	6.9	25.4	29.1	38.0	7.8	0.03	ND	76.6
23	木	24.4	17.3	1.1	6.9	26.3	28.5	47.6	7.4	0.06	ND	78.8
24	金	23.1	17.8	1.1	6.8	29.0	31.0	44.0	9.0	0.06	ND	83.0
25	土	23.9	18.0	0.7	7.1	33.5	31.0	62.8	8.9	0.04	ND	86.4
26	日	25.1	18.5	0.7	7.1	35.3	33.0	58.4	7.2	0.09	ND	86.8
27	月	23.7	19.0	1.1	7.0	31.3	32.6	49.2	7.4	0.07	ND	84.6
28	火	17.2	18.2	1.6	7.0	28.7	32.2	53.6	7.8	0.05	ND	83.3
29	水	22.1	15.5	2.9	6.5	11.8	17.1	38.4	8.2	0.08	ND	55.7
30	木	22.6	15.5	2.0	6.8	18.0	21.9	34.0	7.7	0.07	ND	61.7
31	金	20.9	17.0	1.3	6.7	23.0	25.3	48.0	8.8	0.02	ND	70.8
最大値		25.1	19.0	2.9	7.1	35.3	33.0	62.8	10.3	0.10	ND	86.8
最小値		12.8	14.0	0.4	6.5	11.8	17.1	31.2	7.2	0.01	ND	55.7
平均値		20.8	16.4	1.1	6.9	26.6	28.6	44.8	8.4	0.05	ND	77.0

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
 濁度およびpH以外の基準については参考値とする。
 本試験結果はJIS.K.0101(工業用水試験法)による。