

### 水質試験結果表(取水分)

2024年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	月	23.7	21.3	8.7	6.7	23.2	24.3	46.0	7.3	0.27	ND	63.2
2	火	25.6	18.1	20.3	7.1	39.1	41.0	100.0	8.3	0.94	0.06	97.4
3	水	29.6	19.3	19.4	6.7	19.8	22.3	64.4	6.0	0.72	0.04	55.3
4	木	29.2	19.5	7.3	6.9	21.0	22.9	53.6	6.6	0.40	0.02	60.3
5	金	32.2	20.0	5.4	6.9	23.2	25.1	38.0	7.1	0.37	0.03	61.7
6	土	30.1	21.2	3.1	6.9	24.4	21.7	47.2	6.4	0.22	0.01	64.1
7	日	33.9	20.5	13.0	7.0	21.9	20.7	48.8	6.0	0.51	0.01	57.7
8	月	30.0	21.2	8.9	6.9	24.0	23.9	72.0	6.8	0.68	0.02	63.5
9	火	29.4	20.5	4.0	7.0	24.7	23.7	47.6	6.7	0.23	0.05	64.0
10	水	26.1	20.2	3.7	6.9	25.2	25.7	48.0	7.2	0.19	0.05	65.6
11	木	23.5	20.5	7.5	6.8	22.9	23.1	48.0	7.3	0.39	0.02	62.1
12	金	24.2	19.7	5.1	6.9	23.6	23.7	58.4	6.3	0.33	0.02	64.2
13	土	26.6	20.1	1.2	7.2	25.6	23.9	56.8	6.3	0.12	ND	67.4
14	日	25.3	21.5	1.3	6.9	26.8	26.3	58.4	6.9	0.13	ND	70.3
15	月	27.1	21.0	2.1	7.2	26.3	26.1	50.8	7.3	0.20	ND	67.5
16	火	32.0	21.3	12.9	6.9	22.4	21.5	58.0	7.3	0.24	0.05	59.6
17	水	24.6	20.3	6.9	6.9	23.0	23.3	60.0	6.5	0.35	0.07	60.3
18	木	30.8	20.2	5.4	6.9	23.7	25.5	54.0	8.0	0.36	0.02	63.2
19	金	31.1	21.0	3.8	7.0	25.5	26.1	58.4	6.9	0.27	ND	65.4
20	土	30.8	21.7	2.0	6.9	24.8	24.9	56.4	6.5	0.12	ND	65.4
21	日	32.1	22.0	2.0	6.9	26.4	25.3	53.6	6.6	0.15	ND	69.1
22	月	29.8	22.6	4.8	6.8	27.3	25.3	57.2	5.4	0.16	0.01	66.6
23	火	33.1	22.4	2.9	6.8	25.4	26.7	44.4	7.1	0.17	0.01	70.5
24	水	24.3	23.0	6.0	7.0	24.2	23.5	45.6	5.9	0.35	0.01	63.7
25	木	30.4	22.3	4.7	6.9	24.9	25.9	51.2	8.0	0.31	ND	66.7
26	金	33.0	22.5	5.8	6.9	25.2	24.7	56.0	7.3	0.09	ND	67.0
27	土	32.7	23.2	1.5	6.9	26.8	25.5	56.8	7.2	0.10	0.01	69.3
28	日	34.0	24.0	1.6	6.9	27.0	26.7	50.0	7.9	0.14	0.02	70.9
29	月	32.0	23.5	3.2	6.7	27.6	29.3	53.6	7.3	0.28	0.02	71.1
30	火	28.9	23.3	2.7	6.8	27.1	28.1	54.0	7.1	0.17	0.02	71.2
31	水	30.9	22.0	8.1	6.8	23.5	23.5	56.0	5.9	0.34	0.02	63.0
最大値		34.0	24.0	20.3	7.2	39.1	41.0	100.0	8.3	0.94	0.07	97.4
最小値		23.5	18.1	1.2	6.7	19.8	20.7	38.0	5.4	0.09	ND	55.3
平均値		29.3	21.3	6.0	6.9	25.0	25.2	54.9	6.9	0.30	0.02	66.0

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

## 水質試験結果表(送水分)

2024年7月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8~8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	月	23.7	20.5	1.5	6.8	24.3	28.1	35.6	7.8	0.04	ND	70.0
2	火	25.6	18.2	2.2	7.0	37.3	39.6	79.2	12.1	0.05	ND	106.4
3	水	29.6	19.2	1.7	6.6	18.8	22.9	46.0	8.7	0.06	ND	65.3
4	木	29.2	19.5	1.8	6.6	19.6	22.3	42.4	9.7	0.06	ND	63.7
5	金	32.2	20.4	1.7	6.6	21.9	25.5	40.0	9.3	0.07	ND	65.2
6	土	30.1	21.5	0.6	6.9	23.3	24.9	37.2	8.1	0.02	ND	67.1
7	日	33.9	21.0	1.2	6.7	19.0	21.5	40.4	10.4	0.04	ND	63.7
8	月	30.0	21.7	1.1	6.7	21.2	23.7	46.4	9.9	0.04	ND	65.0
9	火	29.4	20.8	1.4	6.8	22.4	24.1	36.8	8.5	0.06	ND	66.8
10	水	26.1	20.5	1.6	6.7	23.2	25.9	50.8	12.6	0.08	ND	67.8
11	木	23.5	20.5	1.7	6.6	22.8	24.7	42.0	8.9	0.07	ND	68.0
12	金	24.2	20.1	1.7	6.7	21.5	24.9	59.2	9.0	0.02	ND	66.3
13	土	26.6	20.5	0.7	6.9	23.3	25.1	49.2	8.2	0.04	ND	68.2
14	日	25.3	21.5	0.5	7.0	24.8	25.5	56.4	8.9	0.01	ND	71.1
15	月	27.1	21.0	0.9	7.0	25.6	26.9	44.0	10.0	0.05	ND	71.9
16	火	32.0	21.5	1.2	6.8	21.5	22.1	44.4	9.5	0.05	ND	64.9
17	水	24.6	20.5	1.7	6.6	21.8	24.3	56.0	8.7	0.06	ND	63.9
18	木	30.8	20.5	1.8	6.7	22.1	23.9	52.8	9.2	0.03	ND	65.2
19	金	31.1	21.3	1.8	6.8	23.4	25.1	48.0	9.3	0.08	ND	67.6
20	土	30.8	22.0	1.1	6.8	23.7	24.3	56.0	7.1	0.05	ND	66.3
21	日	32.1	22.6	0.6	6.9	27.1	24.3	51.6	9.6	0.03	ND	70.3
22	月	29.8	23.3	1.0	7.0	26.1	25.9	54.0	8.7	0.03	ND	69.2
23	火	33.1	22.8	1.5	6.7	25.6	26.1	41.6	8.4	0.08	ND	69.9
24	水	24.3	23.5	2.4	6.8	26.6	26.5	44.0	8.1	0.09	ND	73.6
25	木	30.4	22.5	1.2	6.8	24.6	25.5	43.2	9.3	0.06	ND	69.9
26	金	33.0	23.1	1.3	6.7	23.0	24.3	51.6	8.6	0.06	ND	69.0
27	土	32.7	23.8	0.7	6.9	24.9	26.7	51.6	7.8	0.04	ND	70.2
28	日	34.0	24.6	0.6	7.0	26.5	28.1	56.0	8.7	0.06	ND	71.6
29	月	32.0	24.4	0.8	6.9	26.6	27.5	48.0	7.2	0.08	ND	71.9
30	火	28.9	23.5	0.8	6.9	27.4	27.9	53.2	7.8	0.06	ND	72.7
31	水	30.9	22.2	1.5	6.7	20.7	22.1	46.8	8.5	0.05	ND	64.3
最大値		34.0	24.6	2.4	7.0	37.3	39.6	79.2	12.6	0.09	ND	106.4
最小値		23.5	18.2	0.5	6.6	18.8	21.5	35.6	7.1	0.01	ND	63.7
平均値		29.3	21.6	1.3	6.8	23.9	25.5	48.5	9.0	0.05	ND	69.3

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。  
 濁度およびpH以外の基準については参考値とする。  
 本試験結果はJIS.K.0101(工業用水試験法)による。