

水質試験結果表(取水分)

2024年11月

項目		気温 [°C]	水温 [°C]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	金	22.1	16.5	1.6	7.1	34.1	36.8	60.8	7.0	0.13	ND	87.5
2	土	18.4	17.4	0.6	7.1	33.6	34.8	50.4	7.7	0.07	ND	88.1
3	日	22.8	17.0	8.6	7.0	22.1	23.3	59.6	6.8	0.53	0.04	62.2
4	月	21.9	16.3	2.5	6.8	27.0	28.9	52.8	6.3	0.14	ND	73.7
5	火	17.4	16.7	3.5	7.0	31.0	33.6	54.0	7.4	0.22	ND	82.4
6	水	19.0	16.3	2.1	7.1	32.6	34.6	56.4	7.0	0.12	ND	86.1
7	木	15.4	15.6	1.7	7.1	33.5	34.8	53.2	7.3	0.10	ND	87.8
8	金	16.1	14.2	1.3	7.0	35.5	37.6	55.6	7.7	0.13	ND	91.4
9	土	13.0	13.5	0.7	7.1	37.1	39.0	61.2	7.9	0.08	ND	97.0
10	日	12.9	13.5	0.6	7.2	38.4	39.8	62.4	7.7	0.09	ND	99.1
11	月	19.1	14.7	1.3	7.1	38.8	40.2	67.2	7.4	0.13	ND	100.1
12	火	16.7	15.6	1.4	7.1	39.2	42.8	65.6	7.8	0.16	ND	99.5
13	水	22.0	15.7	1.3	7.1	39.7	44.0	66.0	7.9	0.14	ND	103.3
14	木	15.1	15.0	1.3	7.0	38.0	41.0	60.0	6.2	0.12	ND	96.2
15	金	16.0	15.4	1.4	6.9	38.4	38.0	60.8	8.3	0.16	ND	98.5
16	土	18.1	15.7	0.5	7.1	40.9	42.6	63.2	7.0	0.07	ND	103.1
17	日	21.3	16.5	0.6	7.1	40.9	42.2	61.6	7.3	0.08	ND	103.9
18	月	18.3	15.7	1.6	7.1	39.8	40.6	55.2	8.1	0.14	ND	100.0
19	火	8.0	13.6	1.0	7.1	39.0	39.8	61.6	7.8	0.11	ND	98.2
20	水	11.1	12.5	0.9	7.0	39.8	42.4	61.2	8.0	0.11	ND	102.5
21	木	7.7	12.4	0.7	6.9	39.6	40.2	64.4	7.6	0.09	ND	101.8
22	金	10.9	12.7	0.9	6.8	38.9	39.8	58.4	8.1	0.09	ND	100.9
23	土	11.0	12.6	0.7	7.2	38.3	39.8	61.6	7.7	0.07	ND	99.5
24	日	13.9	12.5	0.5	7.2	37.2	37.2	62.0	7.8	0.07	ND	95.6
25	月	13.3	12.2	0.8	7.2	38.9	38.0	60.8	7.6	0.09	ND	97.7
26	火	17.1	11.8	0.6	7.1	39.4	40.2	53.2	7.8	0.08	ND	101.0
27	水	13.1	12.9	3.0	7.2	35.0	37.2	62.0	7.3	0.14	ND	93.3
28	木	7.6	12.7	2.7	7.0	30.7	34.2	60.0	8.1	0.17	ND	87.3
29	金	6.8	11.3	2.5	7.0	31.0	32.8	64.8	7.7	0.14	ND	87.3
30	土	8.7	9.8	2.9	6.9	24.9	26.9	52.8	8.5	0.17	ND	78.8
最大値		22.8	17.4	8.6	7.2	40.9	44.0	67.2	8.5	0.53	0.04	103.9
最小値		6.8	9.8	0.5	6.8	22.1	23.3	50.4	6.2	0.07	ND	62.2
平均値		15.2	14.3	1.7	7.0	35.8	37.4	59.6	7.6	0.13	ND	93.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

