

水質試験結果表(取水分)

2025年1月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	水	7.3	7.5	3.0	7.0	21.8	28.5	64.0	14.4	0.19	ND	92.9
2	木	7.1	8.0	1.2	7.0	24.8	29.9	64.8	13.9	0.14	ND	97.8
3	金	6.5	8.0	2.3	7.0	24.1	28.9	72.4	13.6	0.16	ND	97.9
4	土	7.0	7.3	3.6	6.9	23.1	27.3	66.8	12.8	0.20	ND	92.0
5	日	6.7	7.5	1.3	7.0	26.6	30.8	53.6	11.8	0.11	ND	92.6
6	月	6.1	7.8	1.7	7.2	27.5	32.6	60.0	12.9	0.12	ND	97.4
7	火	6.5	7.6	6.6	6.8	23.7	28.3	56.8	12.6	0.32	0.01	90.8
8	水	2.2	6.5	4.4	6.9	22.1	26.5	55.6	11.9	0.21	ND	86.5
9	木	3.6	5.7	2.9	6.9	23.2	30.6	60.0	15.7	0.16	0.01	101.7
10	金	2.9	4.9	3.1	6.8	25.0	32.0	60.4	17.0	0.16	ND	111.3
11	土	3.0	5.3	0.6	7.0	27.1	28.9	42.0	9.0	0.03	ND	81.1
12	日	2.3	6.2	1.1	7.2	28.2	31.0	51.6	9.8	0.09	ND	86.1
13	月	6.3	6.3	0.8	7.2	28.8	32.6	46.0	9.5	0.07	ND	87.0
14	火	5.3	6.3	1.4	7.2	28.3	31.2	52.8	9.4	0.08	ND	88.0
15	水	5.4	6.5	4.5	6.8	23.8	29.1	55.6	13.9	0.20	0.01	101.5
16	木	2.5	5.8	4.0	6.8	22.6	27.7	52.8	13.0	0.20	ND	92.4
17	金	5.7	6.6	3.4	6.9	23.2	30.2	54.8	13.5	0.17	0.01	99.9
18	土	6.3	6.5	1.3	7.0	25.9	27.9	46.0	9.3	0.08	ND	83.1
19	日	5.5	6.5	0.7	7.3	29.1	29.5	43.6	7.6	0.04	ND	82.1
20	月	5.2	7.1	0.9	7.3	28.7	30.4	44.8	8.6	0.06	ND	87.3
21	火	13.0	7.1	1.2	7.1	27.2	28.5	39.6	7.9	0.06	ND	84.2
22	水	5.4	7.1	1.3	7.2	25.8	29.1	39.2	7.3	0.06	ND	74.1
23	木	5.8	7.0	1.3	7.3	26.4	28.7	37.2	6.3	0.06	ND	74.5
24	金	3.9	7.3	1.5	7.2	26.7	28.5	36.8	6.9	0.07	ND	75.3
25	土	6.8	7.5	1.0	7.1	26.4	28.5	34.8	6.9	0.05	ND	73.2
26	日	7.0	7.4	0.9	7.2	28.1	30.8	37.2	6.8	0.05	ND	79.2
27	月	4.1	7.3	0.9	7.1	28.7	31.4	45.6	7.6	0.05	ND	80.9
28	火	4.5	7.2	1.0	7.2	27.6	30.8	38.8	7.0	0.06	ND	76.3
29	水	3.5	7.1	4.4	7.0	26.6	30.6	51.6	15.9	0.20	ND	115.1
30	木	4.7	5.3	4.5	6.8	25.7	32.4	63.6	16.1	0.23	0.01	115.6
31	金	3.4	5.3	2.0	7.0	25.9	30.8	49.6	12.3	0.12	ND	95.0
最大値		13.0	8.0	6.6	7.3	29.1	32.6	72.4	17.0	0.32	0.01	115.6
最小値		2.2	4.9	0.6	6.8	21.8	26.5	34.8	6.3	0.03	ND	73.2
平均値		5.3	6.8	2.2	7.0	25.9	29.8	50.9	11.0	0.12	ND	90.1

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2025年1月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8～8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	水	7.3	7.5	0.5	6.8	20.9	28.3	57.6	13.5	0.02	ND	97.7
2	木	7.1	7.6	0.4	6.9	22.1	29.7	64.4	14.6	0.02	ND	97.5
3	金	6.5	8.0	0.5	6.9	24.4	30.6	66.4	14.7	0.03	ND	99.1
4	土	7.0	7.4	0.4	6.9	22.7	29.3	42.8	13.6	0.02	ND	95.3
5	日	6.7	7.5	0.6	7.2	27.0	29.9	49.6	10.5	0.05	ND	86.6
6	月	6.1	7.7	0.8	7.2	28.0	31.4	48.8	9.6	0.05	ND	85.0
7	火	6.5	7.5	1.1	6.8	22.0	27.7	54.4	13.3	0.05	ND	99.7
8	水	2.2	6.6	1.7	6.7	19.2	25.3	50.0	12.6	0.06	ND	87.3
9	木	3.6	5.6	1.2	6.8	21.1	28.5	49.2	15.1	0.05	ND	97.8
10	金	2.9	4.8	1.4	6.7	22.4	29.9	57.2	18.7	0.07	ND	110.4
11	土	3.0	5.2	0.6	7.1	25.8	29.3	44.0	10.7	0.03	ND	90.2
12	日	2.3	6.0	0.5	7.3	27.6	30.2	52.4	11.2	0.04	ND	91.3
13	月	6.3	6.3	0.6	7.1	28.1	32.0	50.8	12.7	0.06	ND	104.2
14	火	5.3	6.3	1.0	7.0	24.6	29.3	58.8	13.8	0.04	ND	103.2
15	水	5.4	6.5	1.1	6.8	22.3	31.2	60.4	15.6	0.05	ND	108.1
16	木	2.5	5.9	1.3	6.7	19.1	25.9	56.4	17.9	0.05	ND	106.2
17	金	5.7	6.7	1.4	7.0	21.3	29.3	50.4	17.1	0.05	ND	104.9
18	土	6.3	6.5	0.8	7.1	25.5	29.5	50.8	10.1	0.04	ND	85.5
19	日	5.5	6.5	0.5	7.3	28.1	32.4	44.0	9.6	0.03	ND	80.7
20	月	5.2	6.8	0.6	7.3	28.8	33.6	50.0	8.2	0.05	ND	84.2
21	火	13.0	7.0	1.1	7.2	28.1	31.0	38.8	7.7	0.05	ND	84.6
22	水	5.4	7.1	1.1	7.3	26.5	27.9	36.4	7.6	0.05	ND	74.8
23	木	5.8	7.0	1.1	7.3	26.2	28.9	34.4	6.5	0.05	ND	73.6
24	金	3.9	7.2	1.1	7.2	26.6	29.1	38.8	6.0	0.04	ND	74.6
25	土	6.8	7.5	0.7	7.2	25.8	27.9	34.4	7.1	0.03	ND	73.4
26	日	7.0	7.1	0.6	7.3	27.2	28.3	40.0	6.9	0.04	ND	77.8
27	月	4.1	7.1	0.7	7.2	28.6	30.2	42.0	7.2	0.04	ND	81.0
28	火	4.5	7.1	1.1	7.2	28.1	30.6	44.0	8.6	0.06	ND	92.2
29	水	3.5	7.2	1.2	7.1	25.5	34.0	57.6	17.4	0.05	ND	123.9
30	木	4.7	5.2	1.1	6.8	23.1	31.4	59.6	18.6	0.06	ND	120.8
31	金	3.4	5.1	1.1	6.9	23.0	33.0	62.4	19.4	0.05	ND	123.0
最大値		13.0	8.0	1.7	7.3	28.8	34.0	66.4	19.4	0.07	ND	123.9
最小値		2.2	4.8	0.4	6.7	19.1	25.3	34.4	6.0	0.02	ND	73.4
平均値		5.3	6.7	0.9	7.0	24.8	29.9	49.9	12.1	0.04	ND	94.0

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所