

水質試験結果表(取水分)

2025年3月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	土	8.5	6.4	1.3	7.4	29.8	32.0	55.6	8.7	0.07	ND	87.7
2	日	8.1	7.8	1.6	7.3	27.4	30.8	57.6	9.7	0.12	ND	87.3
3	月	5.1	6.8	5.5	7.1	21.3	26.7	60.0	12.2	0.30	0.02	89.8
4	火	4.2	5.8	5.0	7.0	21.1	25.5	46.4	10.2	0.20	0.01	77.8
5	水	5.3	6.1	4.4	6.9	22.9	27.7	44.8	9.3	0.12	ND	83.1
6	木	7.1	6.5	6.7	6.9	19.7	24.9	53.6	10.7	0.29	0.01	81.2
7	金	10.1	6.4	3.1	7.0	21.3	26.3	46.4	8.6	0.14	ND	73.3
8	土	2.6	6.6	1.4	7.1	23.7	29.5	42.4	8.5	0.11	ND	77.6
9	日	8.8	6.5	1.4	7.3	25.5	30.8	46.4	7.3	0.10	ND	80.6
10	月	7.3	7.7	1.9	7.3	25.9	31.2	47.2	7.7	0.12	ND	80.3
11	火	8.2	7.7	2.3	7.2	26.1	29.1	58.8	8.3	0.14	ND	79.1
12	水	14.1	7.6	2.0	7.1	24.9	29.3	44.8	7.9	0.11	ND	78.2
13	木	15.0	8.6	5.0	7.2	21.4	30.4	42.8	9.2	0.26	0.01	77.6
14	金	13.3	8.4	4.6	7.0	20.7	24.1	47.6	9.0	0.19	ND	71.5
15	土	7.6	8.4	1.4	7.2	21.8	24.9	43.6	7.1	0.08	ND	69.7
16	日	5.9	7.5	1.2	7.2	22.6	26.3	41.6	7.2	0.06	ND	72.3
17	月	3.6	7.6	6.0	7.1	21.2	25.5	46.8	9.2	0.29	0.01	79.5
18	火	6.3	6.9	8.0	7.0	20.4	24.5	50.0	9.8	0.36	0.01	78.2
19	水	3.8	7.9	6.5	7.0	21.6	26.1	54.0	11.4	0.29	ND	87.1
20	木	4.9	6.5	2.0	7.2	22.9	25.9	45.6	8.0	0.11	ND	72.5
21	金	11.5	7.2	1.9	7.2	24.9	28.5	42.4	7.4	0.10	ND	73.6
22	土	15.3	8.5	1.2	7.2	24.6	27.9	45.2	7.2	0.08	ND	75.6
23	日	17.9	10.0	2.0	7.2	23.2	27.5	53.2	10.4	0.13	ND	88.2
24	月	12.0	9.4	3.5	7.1	21.4	23.1	50.8	7.6	0.20	ND	68.5
25	火	16.5	9.6	7.2	7.1	20.6	23.9	53.6	9.3	0.30	0.01	74.8
26	水	16.7	10.1	12.9	7.1	19.2	22.3	47.2	8.3	0.45	0.02	68.1
27	木	21.7	9.7	14.7	6.9	18.1	21.1	62.4	8.3	0.48	0.02	65.1
28	金	12.5	10.8	61.5	7.0	17.3	19.5	111.2	9.6	1.49	0.11	68.8
29	土	13.0	10.5	55.5	7.3	40.8	45.6	154.4	8.6	1.47	ND	111.7
30	日	6.3	12.0	29.2	7.5	51.6	55.7	121.2	9.0	0.89	ND	135.0
31	月	12.0	10.4	22.1	7.2	38.0	42.4	101.2	10.2	0.72	ND	116.7
最大値		21.7	12.0	61.5	7.5	51.6	55.7	154.4	12.2	1.49	0.11	135.0
最小値		2.6	5.8	1.2	6.9	17.3	19.5	41.6	7.1	0.06	ND	65.1
平均値		9.8	8.1	9.1	7.1	24.6	28.7	58.7	8.9	0.32	0.01	81.6

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2025年3月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8～8.6	75以下	120以下	250以下	80以下	0.3以下	0.2以下	
1	土	8.5	6.1	1.2	7.5	27.8	31.4	44.4	9.0	0.07	ND	86.6
2	日	8.1	7.5	1.1	7.4	29.1	32.6	58.4	8.4	0.05	ND	87.9
3	月	5.1	6.6	0.9	7.2	23.1	29.9	54.8	11.0	0.05	ND	86.2
4	火	4.2	5.9	1.4	6.7	18.2	26.5	46.8	11.8	0.04	ND	81.7
5	水	5.3	6.0	1.2	7.0	21.6	29.7	45.6	10.6	0.05	ND	80.1
6	木	7.1	6.3	1.4	6.7	17.6	25.3	43.2	11.1	0.05	ND	78.4
7	金	10.1	6.5	1.2	6.9	18.8	25.3	44.8	10.2	0.05	ND	77.3
8	土	2.6	6.5	0.6	7.0	22.3	26.7	44.8	8.5	0.03	ND	78.5
9	日	8.8	6.2	0.7	7.2	24.4	28.5	48.4	7.6	0.04	ND	79.8
10	月	7.3	7.2	0.8	7.2	25.6	28.9	44.8	8.4	0.05	ND	80.6
11	火	8.2	7.8	0.9	7.1	24.8	30.6	52.0	8.2	0.04	ND	81.2
12	水	14.1	7.6	1.0	7.1	23.9	28.1	46.4	8.6	0.05	ND	80.8
13	木	15.0	8.8	1.1	7.0	19.5	28.9	44.0	11.8	0.04	ND	88.3
14	金	13.3	8.8	1.3	6.7	17.6	24.1	48.0	12.6	0.06	ND	84.6
15	土	7.6	8.2	0.4	7.1	20.4	25.7	37.6	8.6	0.02	ND	71.2
16	日	5.9	7.0	0.7	7.2	21.8	26.9	38.4	7.2	0.04	ND	72.0
17	月	3.6	7.1	0.6	6.9	20.2	25.9	45.6	10.1	0.03	ND	79.9
18	火	6.3	6.7	1.4	6.8	17.9	24.3	46.4	11.8	0.06	ND	83.7
19	水	3.8	8.1	0.9	6.8	19.5	27.3	45.6	12.7	0.04	ND	88.0
20	木	4.9	6.4	1.2	7.0	20.5	26.7	44.0	9.9	0.04	ND	75.5
21	金	11.5	7.3	0.8	7.2	23.4	27.7	41.6	6.8	0.04	ND	74.6
22	土	15.3	8.4	0.6	7.2	24.6	28.7	43.6	8.5	0.03	ND	77.2
23	日	17.9	9.5	0.5	7.1	22.6	29.7	55.2	12.2	0.02	ND	93.4
24	月	12.0	9.6	0.8	6.9	19.9	25.5	51.2	11.0	0.03	ND	83.5
25	火	16.5	9.6	1.4	6.9	18.3	24.5	52.4	10.7	0.05	ND	77.4
26	水	16.7	9.9	1.8	6.8	16.1	23.3	42.4	10.6	0.06	ND	73.2
27	木	21.7	9.8	1.4	6.8	17.5	21.1	43.2	10.4	0.04	ND	72.9
28	金	12.5	11.0	2.1	6.8	16.7	20.7	44.8	12.1	0.06	ND	80.6
29	土	13.0	10.2	1.5	7.6	41.8	44.6	90.4	16.0	0.11	ND	142.9
30	日	6.3	11.8	1.2	7.7	58.5	61.3	106.0	15.1	0.04	ND	167.9
31	月	12.0	11.4	0.9	7.6	60.1	62.1	114.0	14.4	0.03	ND	169.3
最大値		21.7	11.8	2.1	7.7	60.1	62.1	114.0	16.0	0.11	ND	169.3
最小値		2.6	5.9	0.4	6.7	16.1	20.7	37.6	6.8	0.02	ND	71.2
平均値		9.8	8.1	1.1	7.1	24.3	29.8	51.9	10.5	0.05	ND	88.2

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。

濁度およびpH以外の基準については参考値とする。

本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所