

水質試験結果表(取水分)

2025年4月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	火	6.8	9.0	6.1	7.2	21.2	24.7	47.2	6.2	0.27	0.01	65.1
2	水	9.6	9.0	5.3	7.2	22.5	25.7	50.0	6.3	0.26	0.01	71.0
3	木	14.3	9.3	5.2	7.3	21.5	25.7	46.4	7.4	0.31	0.02	72.7
4	金	14.9	9.1	4.0	7.2	20.4	22.9	45.2	6.8	0.21	ND	62.1
5	土	11.1	9.0	2.3	7.3	19.7	23.1	42.8	5.1	0.15	ND	60.1
6	日	14.0	9.5	2.3	7.0	20.3	23.7	41.6	5.3	0.14	ND	61.4
7	月	13.5	9.8	3.8	7.0	19.5	21.9	43.2	6.6	0.21	0.01	60.0
8	火	17.3	9.7	3.6	7.1	20.7	22.9	42.0	6.5	0.17	ND	59.3
9	水	17.6	9.6	4.3	6.9	20.0	21.9	44.8	6.7	0.17	ND	62.7
10	木	14.0	10.1	4.2	7.1	19.2	22.1	40.0	6.4	0.20	ND	58.4
11	金	12.2	10.8	7.9	7.0	19.7	23.9	52.8	8.2	0.24	0.01	72.2
12	土	13.1	10.7	4.8	6.9	19.6	23.7	52.8	8.6	0.28	0.01	71.7
13	日	15.1	11.3	4.8	6.9	19.4	23.1	49.2	7.8	0.28	0.01	67.3
14	月	14.3	10.0	76.9	6.7	17.7	19.5	133.2	7.2	1.54	ND	61.7
15	火	13.4	11.3	36.8	6.8	19.1	23.5	84.4	9.0	1.29	ND	72.1
16	水	14.4	9.8	28.8	6.8	19.8	24.3	83.6	10.9	1.06	ND	80.4
17	木	20.1	11.1	17.1	6.9	21.2	26.1	71.2	10.1	0.71	ND	80.3
18	金	19.2	12.4	12.9	6.9	21.5	24.7	72.4	9.0	0.57	ND	79.1
19	土	21.2	13.0	8.4	6.8	19.7	22.3	58.4	8.8	0.45	0.02	73.0
20	日	21.8	13.3	10.8	6.9	18.7	22.9	56.4	8.2	0.44	0.02	67.0
21	月	21.0	12.7	13.4	6.9	19.1	22.9	58.8	8.4	0.58	0.03	70.0
22	火	22.4	12.6	11.4	6.8	19.3	23.9	50.8	8.1	0.57	0.03	71.4
23	水	17.9	13.8	12.1	6.7	20.1	23.1	59.6	9.5	0.41	0.02	76.3
24	木	14.0	12.9	24.6	6.7	18.4	21.3	70.8	9.3	0.92	0.06	67.2
25	金	17.6	12.6	14.6	6.9	20.5	24.1	65.6	8.7	0.58	0.03	74.8
26	土	14.9	12.3	7.4	6.9	20.9	24.5	63.2	8.5	0.36	0.01	77.4
27	日	18.1	12.5	8.2	6.9	21.9	26.5	60.0	8.8	0.38	0.02	80.1
28	月	20.0	13.2	9.2	6.9	22.3	26.9	60.8	8.8	0.44	0.01	81.8
29	火	15.3	12.6	6.1	7.0	21.6	26.3	60.4	8.7	0.36	0.01	78.7
30	水	16.3	12.2	7.1	6.9	21.9	26.7	55.6	8.1	0.35	0.01	80.5
最大値		22.4	13.8	76.9	7.3	22.5	26.9	133.2	10.9	1.54	0.06	81.8
最小値		6.8	9.0	2.3	6.7	17.7	19.5	40.0	5.1	0.14	ND	58.4
平均値		15.8	11.2	12.1	6.9	20.2	23.8	58.8	7.9	0.46	0.01	70.5

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2025年4月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8～8.6							
1	火	6.8	8.9	0.7	6.7	18.2	25.9	43.6	9.5	0.03	ND	73.9
2	水	9.6	8.8	1.0	6.9	19.7	27.3	45.2	9.0	0.05	ND	72.6
3	木	14.3	8.9	0.8	6.9	18.6	25.7	38.8	8.2	0.05	ND	68.5
4	金	14.9	8.9	1.2	6.9	18.4	23.9	37.2	8.5	0.05	ND	66.2
5	土	11.1	9.0	0.9	6.8	17.8	23.3	39.6	8.1	0.04	ND	63.9
6	日	14.0	9.5	0.6	6.9	18.3	23.3	39.2	7.7	0.02	ND	64.5
7	月	13.5	10.0	0.6	6.8	18.5	23.9	42.8	8.7	0.03	ND	73.5
8	火	17.3	9.9	1.1	6.9	17.4	23.3	42.4	8.3	0.05	ND	65.2
9	水	17.6	9.6	1.1	6.7	18.4	25.7	46.0	10.9	0.05	ND	76.8
10	木	14.0	10.3	1.3	6.7	17.1	23.3	41.6	9.6	0.05	ND	68.9
11	金	12.2	10.4	1.3	6.9	18.8	25.5	47.6	12.2	0.05	ND	86.7
12	土	13.1	10.8	0.9	6.7	16.4	22.7	47.6	10.7	0.04	ND	73.9
13	日	15.1	11.2	0.8	6.7	16.2	22.5	45.2	9.8	0.03	ND	70.0
14	月	14.3	10.5	2.0	6.8	16.2	21.9	51.6	11.6	0.08	ND	80.1
15	火	13.4	11.3	1.6	6.9	17.2	23.3	43.2	13.0	0.06	ND	86.3
16	水	14.4	10.1	2.0	6.8	18.7	26.5	57.6	15.3	0.09	ND	97.4
17	木	20.1	11.0	1.0	7.0	19.6	27.9	55.2	13.9	0.05	ND	92.7
18	金	19.2	12.2	0.9	6.9	20.5	26.5	52.0	12.3	0.04	ND	92.6
19	土	21.2	13.0	0.8	6.7	19.5	25.1	53.6	12.1	0.03	ND	88.5
20	日	21.8	13.3	0.7	6.9	18.3	22.7	47.6	11.6	0.02	ND	82.7
21	月	21.0	12.7	1.0	7.0	18.8	22.5	54.4	12.2	0.04	ND	83.5
22	火	22.4	12.7	1.0	6.9	18.5	23.7	44.8	11.4	0.05	ND	82.4
23	水	17.9	13.6	1.0	6.7	19.1	24.5	58.8	11.7	0.03	ND	86.8
24	木	14.0	12.7	2.0	6.6	15.3	21.5	49.2	12.6	0.08	ND	79.1
25	金	17.6	12.5	1.3	6.7	17.7	24.3	46.4	11.8	0.05	ND	85.2
26	土	14.9	12.3	1.1	6.8	18.7	24.5	52.4	11.5	0.06	ND	84.6
27	日	18.1	12.7	0.6	7.0	19.5	24.9	52.8	11.2	0.03	ND	85.1
28	月	20.0	13.1	0.9	6.8	20.1	25.5	55.2	12.0	0.03	ND	85.2
29	火	15.3	12.5	1.1	7.0	19.5	24.9	50.8	10.7	0.07	ND	81.0
30	水	16.3	12.2	1.4	6.8	20.1	25.1	54.8	11.2	0.07	ND	85.4
最大値		22.4	13.6	2.0	7.0	20.5	27.9	58.8	15.3	0.09	ND	97.4
最小値		6.8	8.8	0.6	6.6	15.3	21.5	37.2	7.7	0.02	ND	63.9
平均値		15.8	11.2	1.1	6.8	18.4	24.4	47.9	10.9	0.05	ND	79.4

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所