

水質試験結果表(取水分)

2025年5月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日											
1	木	22.8	12.9	6.7	6.7	22.0	26.5	56.4	8.4	0.32	0.01	79.1
2	金	19.0	14.2	9.4	6.8	21.4	26.3	66.8	8.0	0.48	0.01	78.9
3	土	20.6	12.5	4.0	7.1	17.5	18.5	38.8	5.0	0.22	0.01	50.2
4	日	21.2	13.5	2.1	7.1	18.4	19.7	33.2	4.7	0.13	ND	52.1
5	月	18.3	13.0	2.9	6.9	19.0	19.1	36.0	6.1	0.17	ND	53.7
6	火	14.7	13.5	2.8	7.0	19.2	22.9	36.8	5.3	0.16	ND	54.8
7	水	18.4	12.7	7.0	6.9	18.4	20.5	39.2	5.9	0.29	0.01	52.4
8	木	20.8	12.4	5.6	6.9	18.0	20.1	37.2	4.5	0.25	0.01	51.9
9	金	20.3	13.4	4.2	6.8	19.1	21.1	38.8	5.2	0.20	ND	54.0
10	土	23.4	14.1	4.5	6.9	18.5	20.5	34.8	6.5	0.22	ND	53.5
11	日	24.5	13.9	5.8	6.7	15.7	16.5	31.6	5.0	0.23	0.01	44.7
12	月	16.4	14.0	8.7	6.8	18.2	19.7	36.0	5.5	0.34	0.02	51.7
13	火	20.6	13.2	4.1	7.0	18.8	20.9	39.6	5.5	0.17	ND	52.6
14	水	21.3	14.4	4.5	6.9	20.3	21.9	38.0	7.3	0.20	0.01	56.5
15	木	24.1	15.1	4.2	6.9	21.6	23.1	39.2	6.7	0.19	0.01	58.2
16	金	24.4	15.6	3.9	6.9	20.7	23.7	43.2	7.2	0.19	ND	59.1
17	土	19.9	16.5	1.8	6.8	21.2	23.1	37.6	6.6	0.10	ND	61.0
18	日	27.9	16.0	7.9	7.0	18.3	19.1	40.8	5.3	0.34	0.03	50.9
19	月	21.9	16.1	3.8	6.8	20.1	21.9	38.4	6.1	0.19	0.01	56.1
20	火	27.3	16.8	3.9	6.8	22.3	23.9	41.2	5.9	0.20	ND	61.7
21	水	29.1	17.8	3.3	6.9	22.3	24.7	40.0	7.0	0.19	ND	62.8
22	木	24.9	18.6	2.9	6.9	22.6	25.5	40.4	6.9	0.16	ND	63.3
23	金	23.6	17.4	3.0	7.0	22.4	25.1	44.0	7.3	0.15	ND	62.0
24	土	20.3	17.4	1.4	6.8	22.9	25.3	40.0	5.6	0.10	ND	65.7
25	日	17.3	16.7	2.0	6.9	22.6	23.7	38.0	6.1	0.11	ND	64.7
26	月	21.4	15.6	7.2	6.8	20.9	21.7	45.6	6.1	0.28	0.01	59.0
27	火	19.2	15.1	2.8	6.8	22.5	24.3	41.2	6.4	0.14	ND	62.7
28	水	27.4	16.9	2.2	6.9	23.3	21.9	40.4	6.0	0.12	ND	64.6
29	木	23.1	17.8	2.0	6.9	23.4	22.5	40.8	6.6	0.12	ND	66.2
30	金	27.0	17.6	2.2	6.8	23.5	22.1	46.8	6.3	0.11	ND	66.9
31	土	21.3	17.2	1.2	6.8	24.1	25.1	40.4	6.8	0.09	ND	68.3
最大値		29.1	18.6	9.4	7.1	24.1	26.5	66.8	8.4	0.48	0.03	79.1
最小値		14.7	12.4	1.2	6.7	15.7	16.5	31.6	4.5	0.09	ND	44.7
平均値		22.0	15.2	4.1	6.9	20.6	22.3	40.7	6.2	0.20	ND	59.3

本試験結果はJIS.K.0101(工業用水試験法)による

福井臨海工業用水道管理事務所

水質試験結果表(送水分)

2025年5月

項目		気温 [℃]	水温 [℃]	濁度 [度]	pH [-logH]	酸消費量 [mg/L]	全硬度 [mg/L]	全蒸発残留物 [mg/L]	塩化物イオン [mg/L]	鉄 [mg/L]	マンガン [mg/L]	電気伝導度 [μ S/cm]
日付	曜日			20以下	5.8～8.6							
1	木	22.8	13.0	0.8	6.7	21.2	26.5	56.0	12.1	0.04	ND	90.7
2	金	19.0	14.2	0.6	6.8	20.7	25.9	54.0	11.6	0.03	ND	91.5
3	土	20.6	12.3	1.2	7.1	15.3	21.9	36.0	8.6	0.06	ND	57.2
4	日	21.2	13.0	0.4	6.8	15.4	20.5	33.2	8.3	0.02	ND	54.4
5	月	18.3	13.0	0.5	6.8	15.7	21.7	35.6	6.8	0.02	ND	55.9
6	火	14.7	13.2	0.6	6.8	16.6	21.9	35.2	7.4	0.03	ND	56.7
7	水	18.4	12.3	1.0	6.6	15.9	20.7	35.2	7.9	0.04	ND	56.2
8	木	20.8	12.3	1.9	6.7	15.3	19.5	37.6	7.4	0.07	ND	55.8
9	金	20.3	13.1	1.7	6.6	16.4	23.3	33.6	7.1	0.06	ND	57.0
10	土	23.4	13.5	1.0	6.9	15.9	21.5	34.4	8.8	0.03	ND	56.7
11	日	24.5	13.3	1.6	6.7	12.7	16.7	29.2	7.7	0.06	ND	49.8
12	月	16.4	13.4	1.4	6.6	14.9	19.7	33.6	7.8	0.05	ND	53.3
13	火	20.6	13.2	1.7	6.7	16.1	21.5	41.2	6.3	0.06	ND	56.0
14	水	21.3	14.2	1.2	6.7	17.6	21.5	37.2	7.9	0.04	ND	58.6
15	木	24.1	15.1	1.1	6.7	18.8	22.7	38.4	7.0	0.04	ND	60.9
16	金	24.4	15.4	1.3	6.6	18.4	22.9	34.4	8.1	0.05	ND	60.6
17	土	19.9	16.0	0.5	6.8	19.3	22.3	34.4	6.1	0.02	ND	61.2
18	日	27.9	15.9	0.9	6.8	16.1	21.5	34.8	6.9	0.03	ND	58.9
19	月	21.9	15.9	0.7	6.7	17.2	23.7	35.6	7.6	0.03	ND	57.2
20	火	27.3	16.6	1.0	6.7	19.7	24.7	40.0	7.8	0.04	ND	62.7
21	水	29.1	17.4	1.0	6.9	20.5	25.7	42.0	8.6	0.04	ND	64.1
22	木	24.9	18.2	1.1	6.8	21.3	25.5	42.4	8.4	0.05	ND	64.8
23	金	23.6	17.2	1.2	6.7	20.5	25.5	38.4	8.1	0.05	ND	64.6
24	土	20.3	17.0	0.7	6.8	21.5	27.1	36.8	6.2	0.04	ND	66.1
25	日	17.3	16.2	0.8	6.9	21.9	23.3	37.2	6.1	0.05	ND	65.5
26	月	21.4	15.5	1.0	6.6	18.3	21.5	43.2	6.9	0.04	ND	62.1
27	火	19.2	14.8	1.2	6.7	20.5	22.5	40.8	7.3	0.05	ND	64.2
28	水	27.4	16.7	1.1	6.9	22.1	22.3	40.0	6.2	0.05	ND	66.2
29	木	23.1	17.6	1.1	6.8	23.2	22.1	41.2	7.4	0.06	ND	67.9
30	金	27.0	17.3	1.3	6.8	23.2	22.5	42.8	6.7	0.08	ND	67.7
31	土	21.3	17.4	0.9	6.9	23.8	23.1	40.8	6.5	0.07	ND	68.3
最大値		29.1	18.2	1.9	7.1	23.8	27.1	56.0	12.1	0.08	ND	91.5
最小値		14.7	12.3	0.4	6.6	12.7	16.7	29.2	6.1	0.02	ND	49.8
平均値		22.0	15.0	1.0	6.8	18.6	22.6	38.6	7.7	0.05	ND	62.3

鉄イオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
マンガンイオン濃度が0.01mg/L未満の場合、ND(未検出)とする。
本試験結果はJIS.K.0101(工業用水試験法)による。

福井臨海工業用水道管理事務所